

Clarification to prospective Bidder's query against NIB-118 dtd:19/12/2014:

Sl. No.	Bidders' query	NEEPCO's Reply
1.	<p>Refer page 3 of volume 2 Part-I of your bid documents you have indicated the type & quantity of modules.</p> <p>Again in corrigendum you have increase the guaranteed generation to 3.3288 MU in total.</p> <p>On detailed calculation at our end for 2.0MW project we have noticed that the numbers you have indicated is not at all matching. In view of that kindly confirm which specification we should follow.</p> <p>And on the other hand the asked 19% CUF in that region is too high considering the available record of solar irradiation as well as data that you have included in the Bid documents. The reasonable CUF in that area is between 15 to 16 %</p>	<p>Bid conditions and subsequent corrigendum shall prevail.</p>

