



North Eastern Electric Power Corporation Ltd.
(A Government of India Enterprise)
An ISO 9001, 14001 & OHSAS 18001 Corporation

CONTRACT AND PROCUREMENT WING

KOPILI H.E. PLANT: DIMA HASAO DISTRICT :: UMRONGSO – 788931

Website-www.neepco.gov.in,

Phone. 03670-288241, Fax: 03670-288254/288240

CORRIGENDUM -II DATED 25.07.2014

TO

NIT No.: KHEP/ C&P (E)/ 2014/ 208 Dtd. 13.06.2014

The following modification has been incorporated in the tender specification for “ **manufacture, shop testing, supply and delivery of Stainless Steel Gate Valves as per specification and quantity**” required for 2x25MW Khandong Power Station at Kopili Hydro Electric Plant, NEEPCO Ltd. , Umrongso, Assam.

- i) The clause no. 2.0 under Section IV of Technical Specification in the detail tender specification may please be read as follows-

The Specifications for Stainless Steel gate valves (ASME Class 150) is given below:

Sl. No	Part's details	Material of Constructions
1	Body	ASTM A351 Gr. CF8M
2	Wedge	ASTM A351 Gr. CF8M
3	Stem	ASTM A182 Gr. F316
4	Gasket – Cl.150	Graphite with SS 316 insert Spirally – wound SS 304 with graphite filter
5	Bonnet	ASTM A351 Gr. CF8M
6	Stud	ASTM A193 Gr. B8 Cl.2
7	Stud Nut	ASTM A194 Gr. 8
8	Packing	Graphite with braided end rings
9	Eye Bolt	SS 316
10	Eye Bolt Nut	ASTM A 194 Gr. 8
11	Gland	SS 316
12	Gland Flange	SS 316
13	Yoke Sleeve (Stem Nut)	ASTM A439 Type D2
14	Grease Fitting	SS 304
15	Retainer Nut	SS 304
16	Hand Wheel	ASTM A 536 Gr. 60-40-18/ ASTM A 602 Gr. M3210
17	Hand Wheel Nut	Ss 304
18	Name Plate	Ss304

The valves should conform to the following standard:

- Manufacturing standard API600/ API 603
- Testing and inspection standard API598
- Face to face as per ASME B 16.10
- Shell wall thickness ASME B 16.34
- End connections flanged as per ANSI B 16.5 Class 150 R.F

u) A duly signed copy of this corrigendum along with a copy of tender specification must be enclosed in the techno commercial part of the bid submitted by the bidder.

Not to be published

(C. P. Saikia)
Sr. Manager (E/M), C&P (E)
KHEP, NEEPCO Ltd., Umrongso

Memo No. NEEPCO/KHEP/C&P (E/M)/W-10/2014-15/ 1667-72 dated 25.07.2014
Copy to –

1. The HOP, KHEP, Umrongso – for favour of kind information please.
- ✓ 2. The DGM (IT)-I, NEEPCO Ltd., Shillong - with a request to upload the corrigendum dated 25.07.2014 to NIT no.: KHEP/ C&P (E)/ 2014/ 208 (copy enclosed) in the NEEPCO website.
3. The Sr. Manager(E), Khandong P.S - for information please.
4. The Manager (F&A), KHEP, NEEPCO Ltd, Umrongso - for information.
5. The Dy. Manager (C), Vigilance, KHEP, NEEPCO Ltd, Umrongso. – for information.
6. Notice Board, Administrative building, KHEP, Umrongso.


(C. P. Saikia)
Sr. Manager (E/M), C&P
KHEP, NEEPCO Ltd., Umrongso