



ISO-9001-14001-45001
Mini Ratna Category-I

नॉर्थ ईस्टर्न इलेक्ट्रिक पावर कॉर्पोरेशन लिमिटेड
NORTH EASTERN ELECTRIC POWER CORPORATION LIMITED
(भारत सरकार का उद्यम) (A Govt. of India Enterprise)



135मे.वा.अगरतला गैस टरबाइन कंबाइंड साइकिल पावर प्लांट
135 MW AGARTALA GAS TURBINE COMBINED CYCLE POWER PLANT

संयंत्र प्रमुख का कार्यालय/ OFFICE OF THE HEAD OF PLANT
रामचन्द्रनगर, त्रिपुरा (प)/RAMCHANDRA NAGAR, TRIPURA (W)-799008



CIN - U40101ML 1976GOI001658,

NO. NEEPCO/AGTCCPP/HOP/T-25(D)/VOL-I/2019-2020/ 161

DATE : 21/11/2019

To,
The Principal Chief Conservator of Forests(C),
Govt. of India, Ministry of Environment & Forests,
North Eastern Regional Office, Low-U-Sib,
Lumbatngen, Near MTC Workshop,
Shillong - 793 021.

Sub : 135 MW Agartala Gas Turbine Combined Cycle Power Plant - Six Monthly Report
on status of Environment Clearance (1st Oct,2018 to 31st March,2019).

Sir,

This has reference to the Office Memorandum No.J-1311/1/92-IA Dtd.23/01/1992 of the MOE&F, Govt. of India conveying the Environment Clearance and adherence to the various referred conditions, the Status Report of compliance on conditions by this Project are as under :-

Sl. No.	Stipulations as brought out under Memorandum No.J-13011/1/IA Dtd.23/01/1992 of the MOE&F, Govt. of India	Status of compliance by Agartala Gas Turbine Combined Cycle Power Plant of NEEPCO
2(i)	Only natural gas is used in the main feed stock.	Only natural gas is used in the main feed stock.
(ii)	Zero discharge concepts with respect to liquid effluents may be followed and as such no liquid effluent will be allowed to be discharged in the water bodies. Treated liquid effluent should be used/recycled in the plant/irrigation of the green belt/agricultural fields etc.	After commissioning of STGs in 2015-16 liquid effluent is generated and discharged in environment after proper treatment. A scheme is already envisaged to recycle the treated effluent water.
(iii)	Adequate steps should be taken for presentation and control of fire and explosion hazards likely to be caused due to storage and used of inflammable materials like natural gas.	Fire protection system for machine already exists. Fire tenders from Tripura State Fire Service Stationed in Plant area all the round to combat fire.
(iv)	Affected families due to acquisition of land should be properly compensated in consultation with the State Govt.	The land has been purchased directly from the Govt. of Tripura and no families have been affected due to the acquisition.
(v)	The NOX emissions should be exceed the specified standards of 50 ppm. As the site is located within 25 km. of the sanctuary.	Within limit
(vi)	The gaseous emissions from various units should conform to the standards prescribed by the concerned authorities from time to time. At no time the emission level should be beyond the stipulated standards. In the event of failure of any	These parameters are within stipulated norms.

CIN NO. U40101ML1976GO1001658

Regd. Office : Brookland Compound, Lower New Colony, Shillong - 793 003
Phone No. CMD's Office (0364) 2224487/2226453, Fax - 0364-2226417

[Handwritten signature]

	pollution control system adopted by the unit, the respective unit should be shutdown and should not be restarted until the control measure are rectified to achieve the desired standard efficiency.	
(vii)	Adequate No. of Monitoring stations should be provided in consultation with the state Pollution control Board. Further, stack emissions should be monitored periodically. The date of stack emissions and ambient air quality should be sent to the State Pollution Control Board once in 3 months and to this Ministry once in 6 months.	Action has been taken to monitor. Quality of water is monitored at regular interval. There is minimum sound noise beyond the Power House. After installation of CEMS and online data uploading, stack emission can be viewed online on Real Time basis by CPCB and SPCB.
(viii)	A green belt of adequate width not less than 100 meters) and density should be provided all around the Power station.	A green belt with an average width of 100 meters around Power Station including office and Colony Complex with plantation of 45,081 (approx.) plants are maintained.
(ix)	A separate Environment Management Cell with suitably qualified staff to carry out the various functions should be set up under the control of Senior Executives, who will report directly to the Head of the Organization.	An Environment Management Cell is working in the Plant.
3.	Adequate financial provision should be made for implementation of these stipulations and the details of such provisions communicated to this Ministry within three months Financial provisions so made will not be utilized for any other purpose.	Funds are available.

We are also enclosing herewith the test reports (as given below) which was carried out by the Green Tech Environmental Engineer & Consultants, Guwahati in the month of May, 2019.


Assuring our best commitments.

Thanking you,

Enclo:-

- 1) Test Report of Sound Level Monitoring.
- 2) Test Report of Ambient Air.
- 4) Water Test Report.

Yours faithfully,


CGM(E/M) & Head of Plant,
AGTCCPP, NEEPCO Ltd.,
R.C. Nagar, Tripura (West).

CIN NO. U40101ML1976GO1001658

Regd. Office : Brookland Compound, Lower New Colony, Shillong – 793 003
Phone No. CMD's Office (0364) 2224487/2226453, Fax – 0364-2226417



ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स

GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS

नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in



TC-5

Format No:GEEC/FM/47A

URL NO.: TC599119000000891F			
Report No:GEEC/FL/22/SLM/2019/05/05		Date:	03/06/2019
Name of the Industry	Agartala Gas Turbine Combined Cycle Power Plant	Lab Id.:	GEEC/SLM/2019/05/05
Address		NEEPCO Limited, AGTCCPP, Ramchandranagar, Tripura (West)	
Noise Level Report			
Monitoring Location:	Plant	Date of Monitoring:	16/05/2019
Weather/Wind:	Calm & Clear	Sound Level Meter Model	SLM-100, Envirotech
Monitored By:	Mr. Rohan Singh	Sl.No.	13-DTH-2007
Calibration certificate No:	ECL/GTEE/2018-19/MECH/1115	Calibration valid upto:	12/07/2019
Measurement Results			
Sl. No.	Location	Sound Parameters Leq (dBA)	
At Source			
1	Near Unit I	90	
2	Near T & P Store	91.2	
3	Near Turbine	88.6	
4	Near Cooling Tower	93	
5	Near SDM Tank	83.4	
6	Near DM Water Tank	87.5	
7	Near Solar Control Room	71.4	
Away from Source			
8	Near ACC	68.4	
9	Near STG Building	68.4	
10	Near Office	57.8	
11	Near Station -2	64.2	
12	Health Care Unit	71.8	
13	Near Parking Area	65.4	
14	Near DG Room	63.4	
15	Near office	62.8	
Remark:		CPCB Limit Day time Leq < 75 dBA	
		Authorised by: CEO (Pranjal Buragohain)	

The results relate only to the item tested.

The test report shall not be reproduced except in full, without written approval of the laboratory.

The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

मुख्य कार्यालय: बीपी चालिहा रोड, मेलचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640
TeleFax: 0361 2300278

Page 01/01

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स

GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS


नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in



TC-59

Format No:GEEC/FM/47A

URL NO.: TC599119000000892F			
Report No:GEEC/FL/22/SLM/2019/05/07		Date:	03/06/2019
Name of the Industry	Agartala Gas Turbine Combined Cycle Power Plant	Lab Id.:	GEEC/SLM/2019/05/07
Address		NEEPCO Limited, AGTCCPP, Ramchandranagar, Tripura (West)	
Noise Level Report			
Monitoring Location:	Office & Residential Area	Date of Monitoring:	16/05/2019
Weather/Wind:	Calm & Clear	Sound Level Meter Model	SLM-100, Envirotech
Monitored By:	Mr.Rohan Singh	Sl.No.	13-DTH-2007
Calibration certificate No:	ECL/GTEE/2018-19/MECH/1115	Calibration valid upto:	12/07/2019
Measurement Results			
Sl. No.	Location	Sound Parameters Leq (dBA)	
		Day Time	Night Time
1	Guest House	54.8	40.4
2	B Type (B9AB & B4A/B)	53.2	39.2
3	Main Gate	55.0	37.4
4	Park	53.8	39.4
5	Recreation Club	52.4	38.3
6	Near Water Tank	53.7	39.8
7	Near Tennis Court	54.3	37.3
9	Shiv Mandir Area	50.4	37.2
10	Near C Type (C-10/11)	52.5	39.6
11	Near Welfare Centre	54.2	37.3
12	Near C Type (C-1)	53.2	38.2
Remark:		CPCB Limit Day time Leq < 55 dBA and Night Time < 45 dBA	
		Authorised by:  (Pranjal Buragohain)	

The results relate only to the item tested.

The test report shall not be reproduced except in full, without written approval of the laboratory.

The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

Page 01/01

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS

नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in



TC-599

Format No.: GEEC/FM/4

TEST REPORT

ULR Number: TC599119000000894P			
Ref. No.: GEEC/W/2019/05/16		Date of Reporting:	31/05/2019
Customer Name:	Agartala Gas Turbine Combined Cycle Power Plant	Lab. ID No.:	GEEC-WS/19/05/16
Customer Address:	Agartala Gas Turbine Combined Cycle Power Plant Ramchandranagar PO NEEPCO, Agartala, Tripura (W)-79908	Date of Sampling:	16/05/2019
Sampling Location:	Boiler SWAS # 1	Sample Receipt Date:	20/05/2019
Sample Description:	Water	Test Start Date:	20/05/2019
Sample Drawn By:	Mr. Rohan Singh	Test Completion Date:	30/05/2019
Sample Condition:	Sealed	Sampling Method:	GEEC/SOP/02

Sl. No.	DESCRIPTION	METHOD	UNIT	RESULTS	LIMITS
1	pH	IS 3025 Part 11 1983(RA:2012)	—	8.66	IS:10496- 1983 8.5-9.5
2	TDS	IS 3025 Part 16 1984(RA:2012)	mg/l	BDL	0.05
3#	Total Hardness as CaCO ₃	IS 3025 Part 21 2009	mg/l	BDL	Nil
4	Iron	IS 3025 Part 53 2003(RA:2014)	mg/l	<0.01	0.01
5	Conductivity	IS 3025 Part 14 1984(RA:2012)	mg/l	<0.1	0.3
6	Chloride	IS 3025 Part 32 1988(RA:2014)	mg/l	<2	4

***** End of Report*****

Authorised by: Laboratory In-charge

Date: 31/05/2019
(Dr. Belinda Lahori)

- * The results relate only to the item tested.
- * BDL = Below Detection Limit, TDS = 1 mg/l, Hardness = 1 mg/l.
- * The parameters marked with # are not under the scope of NABL.
- * The test report shall not be reproduced except in full, without written approval of the laboratory.
- * The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

PAGE 1 of 1

मुख्य कार्यालय: बीपी चालिहा रोड, मेलाचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640
TeleFax: 0361 2300278

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS

नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in



TC-599

Format No.: GEEC/FM/49

TEST REPORT

ULR Number: TC599119000000895P

Ref. No.: GEEC/W/2019/05/17	Date of Reporting:	31/05/2019
Customer Name:	Agartala Gas Turbine Combined Cycle Power Plant	Lab. ID No.: GEEC-WS/19/05/17
Customer Address:	Agartala Gas Turbine Combined Cycle Power Plant Ramchandranagar PO NEEPCO, Agartala, Tripura (W)-79908	Date of Sampling:
Sampling Location:	Boiler SWAS # 2	Sample Receipt Date:
Sample Description:	Water	Test Start Date:
Sample Drawn By:	Mr. Rohan Singh	Test Completion Date:
Sample Condition:	Sealed	Sampling Method:

Sl. No.	DESCRIPTION	METHOD	UNIT	RESULTS	LIMITS IS:10496- 1983
1	pH	IS 3025 Part 11 1983(RA:2012)	—	8.83	8.5-9.5
2	TDS	IS 3025 Part 16 1984(RA:2012)	mg/l	BDL	0.05
3 [#]	Total Hardness as CaCO ₃	IS 3025 Part 21 2009	mg/l	BDL	Nil
4	Iron	IS 3025 Part 53 2003(RA:2014)	mg/l	<0.01	0.01
5	Conductivity	IS 3025 Part 14 1984(RA:2012)	mg/l	<0.1	0.3
6	Chloride	IS 3025 Part 32 1988(RA:2014)	mg/l	2.1	4

***** End of Report *****

Authorised by: Laboratory In-charge



- * The results relate only to the item tested.
- * BDL = Below Detection Limit, TDS = 1 mg/l, Hardness = 1 mg/l.
- * The parameters marked with # are not under the scope of NABL.
- * The test report shall not be reproduced except in full, without written approval of the laboratory.
- * The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

PAGE 1 of 1

मुख्य कार्यालय: बीपी चालिहा रोड, मेलाचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640
TeleFax: 0361 2300278

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS

नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in



TC-5

Format No.: GEEC/F

TEST REPORT

ULR Number: TC599119000000897P

Ref. No.: GEEC/W/2019/05/19	Date of Reporting:	31/05/2019
Customer Name:	Agartala Gas Turbine Combined Cycle Power Plant	Lab. ID No.: GEEC-WS/19/05/19
Customer Address:	Agartala Gas Turbine Combined Cycle Power Plant Ramchandranagar PO NEEPCO, Agartala, Tripura (W)-79908	Date of Sampling: 16/05/2019
Sampling Location:	Basin Tap (Guest House of Colony)	Sample Receipt Date: 20/05/2019
Sample Description:	Ground Water	Test Start Date: 20/05/2019
Sample Drawn By:	Mr. Rohan Singh	Test Completion Date: 30/05/2019
Sample Condition:	Sealed	Sampling Method: GEEC/SOP/02

SL. NO.	DESCRIPTION	METHOD	UNIT	RESULTS	IS-10500:2012	
					Requirement (Desirable Limit)	Permissible Limit in the absence of alternate source
1	pH	IS 3025 Part 11 1983(RA:2012)	—	6.59	6.5 to 8.5	-
2	Turbidity	IS 3025 Part 10 1984(RA:2012)	NTU	1	5	10
3	TDS	IS 3025 Part 16 1984(RA:2012)	mg/l	192	500	2000
4#	Total Hardness as CaCO ₃	IS 3025 Part 21 2009	mg/l	60	300	600
5	Iron	IS 3025 Part 53 2003(RA:2014)	mg/l	0.2	0.3	1
6	Chlorides	IS 3025 Part 32 1988(RA:2014)	mg/l	40	250	1000
7	Calcium	IS 3025 Part 40 1991(RA:2014)	mg/l	10	75	200
8	Sulphates	IS 3025 Part 24 1986(RA:2014)	mg/l	60	200	400
9	Alkalinity	IS 3025 Part 23 1986(RA:2014)	mg/l	16	200	600

***** End of Report *****

Authorised by: Laboratory In-charge

Date: 31/05/2019
(Dr. Belinda Lahori)

- * The results relate only to the item tested.
- * The parameters marked with # are not under the scope of NABL.
- * The test report shall not be reproduced except in full, without written approval of the laboratory.
- * The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

PAGE 1 of 1

मुख्य कार्यालय: बीपी चालिहा रोड, मेलाचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS

नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in



TC-5991

Format No.: GEEC/FM/4

TEST REPORT

ULR Number: TC599119000000896P

Ref. No.: GEEC/W/2019/05/18

Customer Name:	Agartala Gas Turbine Combined Cycle Power Plant	Date of Reporting:	31/05/2019
Customer Address:	Agartala Gas Turbine Combined Cycle Power Plant Ramchandranagar PO NEEPCO, Agartala, Tripura (W)-79908	Lab. ID No.:	GEEC-WS/19/05/18
Sampling Location:	Tap (Office)	Date of Sampling:	16/05/2019
Sample Description:	Ground Water	Sample Receipt Date:	20/05/2019
Sample Drawn By:	Mr. Rohan Singh	Test Start Date:	20/05/2019
Sample Condition:	Sealed	Test Completion Date:	30/05/2019
		Sampling Method:	GEEC/SOP/02

SL. NO.	DESCRIPTION	METHOD	UNIT	RESULTS	IS-10500:2012	
					Requirement (Desirable Limit)	Permissible Limit in the absence of alternate source
1	pH	IS 3025 Part 11 1983(RA:2012)	-	6.92	6.5 to 8.5	-
2	Turbidity	IS 3025 Part 10 1984(RA:2012)	NTU	1	5	10
3	TDS	IS 3025 Part 16 1984(RA:2012)	mg/l	212	500	2000
#	Total Hardness as CaCO ₃	IS 3025 Part 21 2009	mg/l	65	300	600
5	Iron	IS 3025 Part 53 2003(RA:2014)	mg/l	0.21	0.3	1
6	Chlorides	IS 3025 Part 32 1988(RA:2014)	mg/l	44	250	1000
7	Calcium	IS 3025 Part 40 1991(RA:2014)	mg/l	12	75	200
8	Sulphates	IS 3025 Part 24 1986(RA:2014)	mg/l	64	200	400
9	Alkalinity	IS 3025 Part 23 1986(RA:2014)	mg/l	20	200	600

***** End of Report *****

Authorised by: Laboratory In-charge

(Dr. Belinda Lahon)

* The results relate only to the item tested.

* The parameters marked with # are not under the scope of NABL.

* The test report shall not be reproduced except in full, without written approval of the laboratory.

* The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

PAGE 1 of 1

मुख्य कार्यालय: बीपी चालिहा रोड, मेलाचकर, शिवसागर, असम-785640

Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640

TeleFax: 0361 2300278

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स

GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS




नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in

TC-5991

GEEC/FM/49A

ULR Number: TC599119000000888P			
Report No: GECC/FL/22/STK/2019/05/20		Date:	03/06/2019
Name of the Industry:	AGARTALA GAS TURBINE POWER PLANT	Lab Id	GEEC/STK/2019/05/20
Address	NEEPCO, Ramchandra Nagar, TRIPURA (WEST)	Date of Sampling	16/05/2019
		Date of Receipt	21/05/2019
		Test Start Date	21/05/2019
		Test End Date	22/05/2019
STACK MONITORING REPORT			
Stack Details:	HRSG#1	Stack Height (GL) m (Approx)	30
Fuel Used	N.G.	Stack Dia, m	3.5
Sample Porthole height (GL) m	24.05	Area in m ²	9.625
Flow Characteristics			
Ambient Temp, °C	32.5	Velocity in m/s	13.2
Stack Temp, °C	119	Flow rate m ³ /s	127.05
Emission Details			
Parameter	Results	CPCB Standards The Environment (Protection) Rules, 1986	
Particulate Matter, mg/Nm ³	20	-	
Sulphur Dioxides, (SO ₂) in mg/Nm ³	< 4	-	
Oxides of Nitrogen (NOx) in ppm	22	100	
Carbon Monoxides, (CO) in %	0.02	-	
Carbon Dioxide, (CO ₂) %	6.2	-	
Oxygen, O ₂ %	14.8	-	
Sampling and analysis is carried out as per IS: 11255 (Part-1, 2, 3 & 7) 1985, IS: 13270:1992(Reaffirmed 1999)			
Equipment Details:	Stack Monitoring Kit: SMS-4 Make: Polltech Pvt.Ltd. & Orsat Apparatus		
Monitored by:	Mr. Rohan Singh		
Remarks:	Parameters tested are within the limit as per CPCB / MoEF Norms		
		Authorised by: Lab-in-Charge  (Dr. Belinda Lahen)	

The results relate only to the item tested.

The test report shall not be reproduced except in full, without written approval of the laboratory.

The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

Page 01/01

मुख्य कार्यालय: बीपी चालिहा रोड, मेलाचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640
TeleFax: 0361 2300278

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स

GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS


नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in



TC-5991

GEEC/FM/49A

ULR Number: TC599119000000889P			
Report No: GECC/FL/22/STK/2019/05/21		Date:	03/06/2019
Name of the Industry:	AGARTALA GAS TURBINE POWER PLANT	Lab Id	GEEC/STK/2019/05/21
Address	NEEPCO, Ramchandra Nagar, TRIPURA (WEST)	Date of Sampling	16/05/2019
		Date of Receipt	21/05/2019
		Test Start Date	21/05/2019
		Test End Date	22/05/2019
STACK MONITORING REPORT			
Stack Details:	HRSG#2	Stack Height (GL) m (Approx)	30
Fuel Used	N.G.	Stack Dia, m	3.5
Sample Porthole height (GL) m	24.05	Area in m ²	9.625
Flow Characteristics			
Ambient Temp, °C	32.5	Velocity in m/s	12.2
Stack Temp, °C	120	Flow rate m ³ /s	117.43
Emission Details			
Parameter	Results	CPCB Standards The Environment (Protection) Rules, 1986	
Particulate Matter, mg/Nm ³	21	-	
Sulphur Dioxides, (SO ₂) in mg/Nm ³	< 4	-	
Oxides of Nitrogen (NOx) in ppm	28	100	
Carbon Monoxides, (CO) in %	0.01	-	
Carbon Dioxide, (CO ₂) %	5.1	-	
Oxygen, O ₂ %	15.9	-	
Sampling and analysis is carried out as per IS: 11255 (Part-1, 2, 3 & 7) 1985, IS: 13270:1992(Reaffirmed 1999)			
Equipment Details:	Stack Monitoring Kit: SMS-4 Make: Polltech Pvt.Ltd. & Orsat Apparatus		
Monitored by:	Mr. Rohan Singh		
Remarks:	Parameters tested are within the limit as per CPCB / MoEF Norms		
		Authorised by: Lab in-Charge	
		 Date: (Dr. Belinda Lahon)	

The results relate only to the item tested.

The test report shall not be reproduced except in full, without written approval of the laboratory.

The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS



नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in

TC-5991

GEEC/FM/49A

ULR Number: TC599119000000890P			
Report No: GECC/FL/22/STK/2019/05/22		Date:	03/06/2019
Name of the Industry:	AGARTALA GAS TURBINE POWER PLANT	Lab Id	GEEC/STK/2019/05/22
Address	NEEPCO, Ramchandra Nagar, TRIPURA (WEST)	Date of Sampling	16/05/2019
		Date of Receipt	21/05/2019
		Test Start Date	21/05/2019
		Test End Date	22/05/2019
STACK MONITORING REPORT			
Stack Details:	HRSG#3	Stack Height (GL) m (Approx)	30
Fuel Used	N.G.	Stack Dia, m	3.5
Sample Porthole height (GL) m	24.05	Area in m ²	9.625
Flow Characteristics			
Ambient Temp, °C	32.5	Velocity in m/s	11.4
Stack Temp, °C	126	Flow rate m ³ /s	109.73
Emission Details			
Parameter	Results	CPCB Standards The Environment (Protection) Rules, 1986	
Particulate Matter, mg/Nm ³	17	-	
Sulphur Dioxides, (SO ₂) in mg/Nm ³	< 4	-	
Oxides of Nitrogen (NOx) in ppm	38	100	
Carbon Monoxides, (CO) in %	0.01	-	
Carbon Dioxide, (CO ₂) %	4.3	-	
Oxygen, O ₂ %	16.7	-	
Sampling and analysis is carried out as per IS: 11255 (Part-1, 2, 3 & 7) 1985, IS: 13270:1992(Reaffirmed 1999)			
Equipment Details:	Stack Monitoring Kit: SMS-4 Make: Polltech Pvt.Ltd. & Orsat Apparatus		
Monitored by:	Mr. Rohan Singh		
Remarks:	Parameters tested are within the limit as per CPCB / MoEF Norms		
		Authorised by: Lab-in-Charge Date:..... Dr. Belinda Lahon	

The results relate only to the item tested.

The test report shall not be reproduced except in full, without written approval of the laboratory.

The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

Page 01/01

मुख्य कार्यालय: बीपी चालिहा रोड, मेलाचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640
TeleFax: 0361 2300278

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स

GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS



नारायण पथ, चम्पक नगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in

TC-5991

GEEC/FM/49A

ULR Number: TC599119000000893P			
Report No: GECC/FL/22/STK/2019/05/23		Date:	03/06/2019
Name of the Industry:	AGARTALA GAS TURBINE POWER PLANT	Lab Id	GEEC/STK/2019/05/23
Address	NEEPCO, Ramchandra Nagar, TRIPURA (WEST)	Date of Sampling	16/05/2019
		Date of Receipt	21/05/2019
		Test Start Date	21/05/2019
		Test End Date	22/05/2019
STACK MONITORING REPORT			
Stack Details:	HRSG#4	Stack Height (GL) m (Approx)	30
Fuel Used	N.G.	Stack Dia, m	3.5
Sample Porthole height (GL) m	24.05	Area in m ²	9.625
Flow Characteristics			
Ambient Temp, °C	32.5	Velocity in m/s	10.3
Stack Temp, °C	114	Flow rate m ³ /s	99.14
Emission Details			
Parameter	Results	CPCB Standards The Environment (Protection) Rules, 1986	
Particulate Matter, mg/Nm ³	15	-	
Sulphur Dioxides, (SO ₂) in mg/Nm ³	< 4	-	
Oxides of Nitrogen (NOx) in ppm	32	100	
Carbon Monoxides, (CO) in %	0.01	-	
Carbon Dioxide, (CO ₂) %	6	-	
Oxygen, O ₂ %	15	-	
Sampling and analysis is carried out as per IS: 11255 (Part-1, 2, 3 & 7) 1985, IS: 13270:1992(Reaffirmed 1999)			
Equipment Details:	Stack Monitoring Kit: SMS-4 Make: Polltech Pvt.Ltd. & Orsat Apparatus		
Monitored by:	Mr. Rohan Singh		
Remarks:	Parameters tested are within the limit as per CPCB / MoEF Norms		
		Authorised by: Lab in-Charge (Dr. Belinda Lahon)	

The results relate only to the item tested.

The test report shall not be reproduced except in full, without written approval of the laboratory.

The test report cannot be used as an evidence in a court of law without prior written approval of the laboratory.



ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स

GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS



नारायणपथ, चम्पकनगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in

TC5991

Format No.: GEEC/FM/48

TEST REPORT

ULR NO.: TC599119000000885P			
Test Report No:	GEEC/AA/2019/05/19	Date of Reporting:	31/05/2019
Customer Name:	Agartala Gas Turbine Combined Cycle Power Plant	Lab. ID No.:	GEEC/AA/2019/05/19
Customer Address:	Agartala Gas Turbine Combined Cycle Power Plant Ramchandranagar, PO NEEPCO, Agartala, Tripura (W)-79908	Date of Sampling:	16/05/2019 to 17/05/2019
Sampling Location:	Near Power House	Ambient Temperature:	Max.
Wind Direction/ Weather Condition:	Calm and Clear		Min.
Sampling Condition:	In GFA and PTFE Filter Paper		32.5°C
Equipments Details:	RDS and ADS Fine Dust Sampler	Sample Receipt Date:	21/05/2019
Monitored By:	Mr. Rohan Singh	Test Start Date:	21/05/2019
		Test End Date:	31/05/2019

AMBIENT AIR QUALITY

Sampling and Analysis carried out as per GEEC/SOP/01

Sl. No.	Parameters	Unit	Results	Limits	Test Method
1	Particulate Matter (PM ₁₀)	µg/m ³	68	100	IS 5182(23)
2	Particulate Matter (PM _{2.5})	µg/m ³	42	60	CPCB Guidelines
3	Sulphur Dioxide (SO ₂)	µg/m ³	6	80	IS 5182(2)
4	Nitrogen Dioxide (NO ₂)	µg/m ³	9	80	IS 5182(VI)
5*	Ozone (O ₃)	µg/m ³	20	180	CPCB Guidelines
6*	Carbon Monoxide (CO)	mg/m ³	<1.5	2	IS 5182(22)
7	Lead (Pb)	µg/m ³	<0.01	1	IS 5182(22)
8*	Benzene (C ₆ H ₆) µg/m ³	µg/m ³	<1	5	CPCB Guidelines
9*	Benzo(a)Pyrene (BaP)- Particulate Phase only	ng/m ³	<1	1	CPCB Guidelines
10*	Arsenic (As)	ng/m ³	<1	6	CPCB Guidelines
11*	Nickel (Ni)	ng/m ³	<1	20	CPCB Guidelines
12*	Ammonia (NH ₃)	µg/m ³	<5	400	CPCB Guidelines

***** End of Report *****

Authorised by: Lab -in-Charge

(Dr. Belinda Lahon)

* The results relate only to the item tested.

* The parameters marked with * are not under the scope of NABL.

* The test report shall not be reproduced except in full, without written approval of the laboratory.

* The report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

मुख्य कार्यालय: बीपी चालिहा रोड, मेलचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640
TeleFax: 0361 2300278

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स

GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS



नारायणपथ, चम्पकनगर, गुवाहाटी, असम-781028

House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in

TC5991

Format No.: GEEC/FM/48

TEST REPORT

ULR NO.: TC599119000000886P				
Test Report No:	GEEC/AA/2019/05/20	Date of Reporting:	31/05/2019	
Customer Name:	Agartala Gas Turbine Combined Cycle Power Plant	Lab. ID No.:	GEEC/AA/2019/05/19	
Customer Address:	Agartala Gas Turbine Combined Cycle Power Plant Ramchandranagar, PO NEEPCO, Agartala, Tripura (W)-79908	Date of Sampling:	16/05/2019 to 17/05/2019	
Sampling Location:	Guest House (Colony)	Ambient Temperature:	Max.	Min.
Wind Direction/ Weather Condition:	Calm and Clear		32.5°C	23.2°C
Sampling Condition:	In GFA and PTFE Filter Paper	Sample Receipt Date:	21/05/2019	
Equipments Details:	RDS and ADS Fine Dust Sampler	Test Start Date:	21/05/2019	
Monitored By:	Mr. Rohan Singh	Test End Date:	31/05/2019	

AMBIENT AIR QUALITY

Sampling and Analysis carried out as per GEEC/SOP/01

Sl. No.	Parameters	Unit	Results	Limits	Test Method
1	Particulate Matter (PM ₁₀)	µg/m ³	62	100	IS 5182(23)
2	Particulate Matter (PM _{2.5})	µg/m ³	36	60	CPCB Guidelines
3	Sulphur Dioxide (SO ₂)	µg/m ³	<5	80	IS 5182(2)
4	Nitrogen Dioxide (NO ₂)	µg/m ³	8	80	IS 5182(VI)
5*	Ozone (O ₃)	µg/m ³	30	180	CPCB Guidelines
6*	Carbon Monoxide (CO)	mg/m ³	<1.5	2	IS 5182(22)
7	Lead (Pb)	µg/m ³	<0.01	1	IS 5182(22)
8*	Benzene (C ₆ H ₆) µg/m ³	µg/m ³	<1	5	CPCB Guidelines
9*	Benzo(a)Pyrene (BaP)- Particulate Phase only	ng/m ³	<1	1	CPCB Guidelines
10*	Arsenic (As)	ng/m ³	<1	6	CPCB Guidelines
11*	Nickel (Ni)	ng/m ³	<1	20	CPCB Guidelines
12*	Ammonia (NH ₃)	µg/m ³	<5	400	CPCB Guidelines

***** End of Report *****

Authorised by: Lab-in-Charge

(Dr. Belinda Lahon)

* The results relate only to the item tested,

* The parameters marked with * are not under the scope of NABL.

* The test report shall not be reproduced except in full, without written approval of the laboratory.

* The report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

मुख्य कार्यालय: बीपी चालिहा रोड, मेलचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640
TeleFax: 0361 2300278

ग्रीन टेक एनवायर्नमेंटल इंजीनियर और कंसल्टेंट्स

GREEN TECH ENVIRONMENTAL ENGINEER & CONSULTANTS



नारायणपथ, चम्पकनगर, गुवाहाटी, असम-781028
House No-11, Champaknagar, Narayan Path, Bhetapara, Guwahati-781028, www.greentecheec.in
Telefax -0361 2300278 Mobile: 9435046677, 9954089052, E-mail: green_pranjal@hotmail.com, info@greentecheec.in TC5991

Format No.: GEEC/FM/48

TEST REPORT

ULR NO.: TC599119000000887P

Test Report No:	GEEC/AA/2019/05/21	Date of Reporting:	31/05/2019
Customer Name:	Agartala Gas Turbine Combined Cycle Power Plant	Lab. ID No.:	GEEC/AA/2019/05/21
Customer Address:	Agartala Gas Turbine Combined Cycle Power Plant Ramchandranagar, PO NEEPCO, Agartala, Tripura (W)-79908	Date of Sampling:	16/05/2019 to 17/05/2019
Sampling Location:	Agartala Guest House(Rly Station)	Ambient Temperature:	Max.
Wind Direction/ Weather Condition:	Calm and Clear		Min.
Sampling Condition:	In GFA and PTFE Filter Paper	Sample Receipt Date:	21/05/2019
Equipments Details:	RDS and ADS Fine Dust Sampler	Test Start Date:	21/05/2019
Monitored By:	Mr. Rohan Singh	Test End Date:	31/05/2019

AMBIENT AIR QUALITY

Sampling and Analysis carried out as per GEEC/SOP/01

Sl. No.	Parameters	Unit	Results	Limits	Test Method
1	Particulate Matter (PM ₁₀)	µg/m ³	74	100	IS 5182(23)
2	Particulate Matter (PM _{2.5})	µg/m ³	45	60	CPCB Guidelines
3	Sulphur Dioxide (SO ₂)	µg/m ³	7	80	IS 5182(2)
4	Nitrogen Dioxide (NO ₂)	µg/m ³	11	80	IS 5182(VI)
5*	Ozone (O ₃)	µg/m ³	10	180	CPCB Guidelines
6	Carbon Monoxide (CO)	mg/m ³	<1.5	2	IS 5182(22)
7	Lead (Pb)	µg/m ³	<0.01	1	IS 5182(22)
8*	Benzene (C ₆ H ₆) µg/m ³	µg/m ³	<1	5	CPCB Guidelines
9*	Benzo(a)Pyrene (BaP)- Particulate Phase only	ng/m ³	<1	1	CPCB Guidelines
10*	Arsenic (As)	ng/m ³	<1	6	CPCB Guidelines
11*	Nickel (Ni)	ng/m ³	<1	20	CPCB Guidelines
12*	Ammonia (NH ₃)	µg/m ³	<5	400	CPCB Guidelines

***** End of Report *****

Authorised by: Lab-in-Charge

(Dr. Belinda Lahon)

- * The results relate only to the item tested.
- * The parameters marked with * are not under the scope of NABL.
- * The test report shall not be reproduced except in full, without written approval of the laboratory.
- * The report cannot be used as an evidence in a court of law without prior written approval of the laboratory.

मुख्य कार्यालय: बीपी चालिहा रोड, मेलचकर, शिवसागर, असम-785640
Head Office: B. P. Chaliha Road, Melachakar, Sivasagar, Assam-785640
TeleFax: 0361 2300278