

UPDATED SALIENT FEATURES OF KAMENG HEP – 600 MW (4X150 MW)

| | |
|---------------------------------------|---|
| Name of the Project | Kameng Hydroelectric Project |
| Installed Capacity | 4X150 MW |
| Type of Development | Run of River |
| Location | West Kameng District, Arunachal Pradesh |
| Latitude and Longitude | Bichom Dam: Lat - 27°18'02.97"N, Long - 92°37'21.83"E Tenga Dam: Lat - 27°13'25.12"N, Long - 92°39'28.09"E Power House: Lat - 27°09'53.54"N, Long - 92°40'57.40"E (As per Google Earth) |
| River | Bichom and Tenga River |
| Hydrology | |
| At 90% dependable year | 1976 -77 |
| Annual Inflow (cum) | 4534.52 |
| Catchment Area (sq.km) | 2277(Bichom) & 1019(Tenga) |
| Reservoir | |
| Maximum Water Level (m) | 771.49m (Bichom Dam), 771.67m (Tenga Dam) |
| Full Reservoir Level (m) | 770 (Bichom Dam), 770 (Tenga Dam) |
| Minimum Drawdown Level (m) | 764.5 (Bichom Dam), 763 (Tenga Dam) |
| Gross/Live Storage (MCM) | 25.03 / 5.718 (Bichom Dam), - / 0.50 (Tenga Dam) |
| Dam | |
| Type | Concrete Gravity Dam |
| Length / Height (m) | 264.15 / 69(Bichom Dam), 103 / 24.5(Tenga Dam) |
| Top Level (m) | 773m (Bichom Dam), 773m (Tenga Dam) |
| Deepest Foundation Level (m) | 704m (Bichom Dam), 748.60m (Tenga Dam) |
| Average River Bed Level (m) | 706m (Bichom Dam), 756m (Tenga Dam) |
| Design Flood (Cumec) | 9216 (Bichom Dam), 3862 (Tenga Dam) |
| Spillway | |
| Bichom Dam | Ogee shaped concrete spillway having 6 nos. Radial gates of size 9m x 11.8m and crest level at EL. 735m |
| Tenga Dam | Flat apron type concrete spillway having 2 nos. Radial gates of size 14m x 14m and crest level at EL. 756m |
| Intake | |
| Gate No & Size (m) | 2 & 5.82(W) x 6.7(H) for Bichom Dam; 1 & 2.75(W) x 2.25(H) (at Tenga intake) and 1 & 1.8(W) x 2.0(H) (at Drop Shaft) for Tenga Dam |
| Head Race Tunnel | |
| Shape & Type | Modified Horse Shoe, Concrete Lining |
| Length & Diameter | 14.5278 km and 6.7m |
| Design Discharge (Cumec) | 140 |
| Invert Level at Intake (m) | 750m |
| Slope | 1 in 1000 |
| Velocity (m/s) | 4 m/s |
| Surge Shaft | |
| Type | Restricted Orifice type Surge Shaft located at the end of low pressure tunnel |
| Diameter (m) / Depth (m) | 25/60 (Surge Shaft) & 3.75/10 (Orifice) |
| Penstock/ High Pressure Tunnel | |
| Type | Combination of Underground- Over Ground- Underground Steel Lined Pressure Tunnel |
| Number | 1 no. of 5.3m diameter of length 601.1m taking off from Surge Shaft, bifurcating into 3.75m diameter (at Valve House) of length 1415.813m & 1415.497m and then each |

P.C. 03/07/15

✓

ANNEXURE I

| | |
|---------------------------------------|--|
| | bifurcating into 2.65m diameter of length 52.15m each into feed units |
| Power House | |
| Type | Surface |
| Size | 120m x 37.3m |
| Turbine | Francis |
| TG Efficiency | 92.98 % |
| Installed Capacity | 4 x 150 MW |
| Net Head | 492.75m |
| Average Tail Water Level | 234.637m |
| Tail Race Channel / Tunnel | |
| Type & Shape | Open Channel |
| Length / Width (m) | 50 / 70 |
| GENERATING PLANT AND MACHINERY | |
| EOT crane | |
| Make | FAFECO, Baroda |
| No, Capacity (T), Span (m) | 2, 190 / 35, 17.75 |
| Main Inlet Valve | |
| Make | BHEL |
| No. / Type / Dia (m) | - / Spherical / 2.0 |
| Turbine | |
| Rated Output (MW) | 153.83 |
| Net Rated Head (m) | 501.22 |
| Net Max. /Mini. Head (m) | 531.5 / 501.22 |
| Runner Inlet/Outlet Dia (m) | 3.1 / 2.046 |
| Efficiency at full load (%) | 95.46 |
| Specific Speed (rpm) | 72.49 |
| Design Discharge(Cumec/ unit) | 32.94 |
| Generator | |
| Make | BHEL |
| No & Type | -/ semi Umbrella type |
| Rated Output (MW) | 150.75 |
| Rated Voltage (KV) | 13.8 |
| Rated Stator Current (A) | 1128 |
| PF | 0.9(lagging) |
| Efficiency at full load (%) | 98.93 |
| Excitation System | Static, Synchronous |
| Generator Transformer | |
| Make | BHEL |
| No & Type | 12+ 1(spare) & Oil immersed, ODWF, Outdoor |
| Rating (MVA), Type | 63, Single Phase |
| Voltage Ratio (KV) | 13.8 / 400 / $\sqrt{3}$ |
| Switchyard | |
| Switching Scheme | Double Main and transfer Bus |
| Bus Reactor | 1 No., 80 MVAR |
| Number of Bays | 10 (4 Nos. GT Bays, 1 No. BC Bay, 1 No. Transfer Bay, 2 Nos. line bays, 1 No. Bus Reactor Bay and 1 No. 400/132kV ICT Bay) |
| Misc. Aspects | |
| Date of CCEA approval | 02/12/2004 |
| Scheduled Completion Time as per CCEA | 5 Years from date of CCEA |
| Original (As per CCEA) | Dec' 09 |

*P. P. Patel
03/07/15*

✓

ANNEXURE I

| | |
|---|--|
| Estimated Cost (Rs Crore) as per CCEA | 2496.90 |
| Civil Cost (Rs Crore) | 1678.59 |
| E & M Cost (Rs Crore) | 569.22 |
| Tariff (Paisa / kWh) as per CCEA approved cost | 148 (First year); 123 (Levelised) |
| Proposed RCE at Dec'14 PL | Rs 6476.34 Crs |
| Tariff (Paisa / kWh) as per proposed RCE | 484 (First year); 441 (Levelised) |
| Revised (as per proposed RCE) Unit wise commissioning date | April 16 May 16 June 16 June 16 Unit I Unit II Unit III Unit IV |
| Design Energy (MU) | 3353 |
| Average Energy | - |
| Generated /annum (MU) | - |
| Firm Power (MW) | 163 |

*Forokh
03/07/15*

✓