



ISO 9001 & 14001
OHSAS 18001

NORTH EASTERN ELECTRIC POWER CORPORATION LTD.

(A Govt. of India Enterprise)

O/o HEAD OF PROJECT AGARTAL GAS TURBINE PLANT

R.C NAGAR, Khayerpur, PIN: 799008

AGARTALA, TRIPURA(W): Ph:0381-2391268 Fax:0381-2391269

CORRIGENDUM NO:01

NIB No: 06/AGTP/HOP dtd07/07/2015(e- tender)

This is for information that:


1.Under Section –V ,Technical Specification of the said NIB ,The type of Solar PV module should be poly Crystalline Silicon PV module conforming the latest edition of IEC61215/IS 14286 &IEC 61730.

2.The terms Warranty/ Guarantee, clause number 5.0 under SECTION –III Terms & Condition of contract may be read as “ **Warranty:** The contractor shall warrant that all equipments(including mechanical Structure) shall be new unused and free from defect in materials and workmanship for a period of 5(five) years immediately upon the satisfactory commissioning. Any design, manufacturing, installation defect observed and found not working in a span of 5 (five) years shall have to be replaced/repared/rectified by the executing agency without any extra cost to NEEPCO”.

instead of

The contractor shall warrant that equipments shall be new unused and in accordance with the contract documents and free from defect in materials and workmanship for a period of twelve(12) calendar months commencing immediately upon the satisfactory commissioning. Any defect observed and found not working in a span of 12(twelve months) shall have to be replaced/repared/rectified by the executing agency without any extra cost to NEEPCO”.

Other terms & conditions of the NIB will remain unchanged.


16/7/2015

(Mrs S.Deb)

Manager(E/M)

AGTP,NEEPCO Ltd

Email:agtpcp2015@gmail.com

Sankari.deb@rediffmail.com