

Rehabilitation of Penstock in Kameng HEP using combination of CFRP and GFRP



Corrigendum XII  
NIB No. NEEPCO/PEN/IND/001  
Date: 09/05/2019

### Corrigendum XII

With reference to **NIB No. NEEPCO/PEN/IND/001**, following revision have been made in Bid document Part 5 Technical Specification & Design, section 2 Additional Scope of Work:

1. Clause No. 2.9.5 may be read as below:

*“The structural analysis document including thickness & no of layers is to be submitted to the Corporation/Consultant for review and approval. The bidder has to consider that the factor of safety on CFRP shall be 5”*

2. Design should be checked for external pressure considering a factor of safety of 2.

All other terms and conditions contained in the Detailed Bid Documents shall remain unchanged.

A handwritten signature in blue ink, appearing to read 'D. Prasad'.

Director General  
Indian Society for Trenchless Technology  
908, Hemkunt Chambers,  
89, Nehru Place, New Delhi 110019