

NORTH EASTERN ELECTRIC POWER CORPORATION LTD

(A Govt. of India Enterprise)

OFFICE OF THE DGM (E/M)

AGTCCPP, NEEPCO LTD, R C NAGAR, AGARTALA
TRIPURA (W), PIN: 799008

CORRIGENDUM NO. 02, Dt. 17.03.2016 TO NIT NO. 01 (Dt. 27.02.2016)

The NIT No. 01, Dt. 27th Feb 2016 circulated vide Memo No. NEEPCO/AGTCCPP/DGM (E/M)/T-1/2015-16/150-157, Dt. 27.02.2016 followed by Corrigendum No. 01 is modified by adding following clauses under terms and conditions and by adding a condition under **"Technical Specification" (Annexure-I)** as follows:

Sample of Insulation Materials: The Bidders shall send 2 (two) samples of insulation materials alongwith the tender. Size of the sample should be 2 inch X 2 inch. **Without sample, tenders are liable to cancellation.**

Test Certificate: The insulation materials must conform to the following tests:
The bidders shall agree to submit following test reports:

- i) Thermal withstandability test for withstanding 550°C to 650°C
- ii) Thickness Test as per ASTM D1777
- iii) Weight test as per ASTM D3776

Technical Specification (Annexure-I): Following is added under Technical Specification:

6. Weight: 4000 gm/sqm.

LAST DATE AND TIME OF SUBMISSION OF TENDER: On or before 12:00 hrs of **31/03/2016**. In case, the due date happens to be a holiday/bandh, the tender shall be received till 12:00 hours of next working day.

DATE OF TIME OF OPENING OF TENDER: The Tender shall be opened on 15:30 hrs **31/03/2016**. In case, the due date happens to be a holiday/bandh, the tender shall be opened at 15:30 hours of next working day.

(N. BASUMATARY),
DGM (E/M)-AGTCCPP,
NEEPCO Ltd., R C Nagar,
Agartala, Tripura (W)-799008