



North Eastern Electric Power Corporation Ltd.
(A Government of India Enterprise)
An ISO 9001, 14001 & OHSAS 18001 Corporation

CONTRACT & PROCUREMENT CELL

Website-www.neepco.gov.in, Email: contract_khep@rediffmail.com
Phone: 03670-288241, Fax: 03670-288254/288240

CORRIGENDUM DATED 09.02.2017

To

NIT No. KHEP/C&P(E)/2017/267 dated 25.01.2017

For

**DESIGN , MANUFACTURING, TESTING, SUPPLY AND DELIVERY
OF STAINLESS STEEL , WIRE WOUND SUPER DUPLEX AND SS 316 GRADE
BEARING COOLER TUBES REQUIRED FOR
BHEL MAKE 25 MW HYDRO TRUBINE GENERATOR UNITS OF
KHANDONG AND KOPILI STAGE _II POWER STATIONS
AT KHEP, NEEPCO LTD., UMRONGSO**

The following corrections in the captioned tender are incorporated regarding the technical specification of materials to be supplied.

1. The technical specification/ dimensions of the Cooler Tubes and quantity requirement of against each type of cooler specified under Section -IV (TECHNICAL SPECIFICATION) of the bid document may please be read as under-

S.N.	Technical Specification of the items	Quantity (nos.)
1	Stainless Steel Super Duplex Wire Wound "U" Tube for LGB (Lower Guide Bearing) Cooler for Oil Cooler. Size : 12.7 mm OD X 20 SWG Thick X 372 mm Long Tested Pressure : Above 10.5 Kg/ cm ² for 30 minutes Working Medium : Water	1330
2	Stainless Steel 316 Grade Wire Wound "U" Tube for UGB (Upper Guide Bearing) Cooler for Oil Cooler. Size : 12.7 mm OD X 20 SWG Thick X 272 mm Long Tested Pressure : Above 10.5 Kg/ cm ² for 30 minutes Working Medium : Water	150
3	Stainless Steel Super Duplex Wire Wound "Straight " Tube for Generator Air Cooler. Size : 19.05 mm OD X 1.0mm Thick X 2413 mm Long Tested Pressure : Above 10.5 Kg/ cm ² for 30 minutes Working Medium : Water	365

Note: Quantity indicated above is tentative and may vary at the time of placement of order.

U. S. S. S. S. S.
09/02/2017

2. The above correction of dimensions at sl. no. 1 shall also be reflected in **PRICE Schedule** under Section –VII of the bid document . Accordingly, the same may please be read as follows. Bidders are requested to quote their price for the items **in the price bid form** as per the Corrigendum only and mentioned the same in the remarks column.

PRICE SCHEDULE

(Schedule of Items and Price)

S.N.	Item Description	Quantity (nos.)	Unit Ex-Works Rate(Rs.)	Amount (Rs.)	Remarks (Applicable taxes & duties , freight & insurance charges shall be clearly mentioned under this column)
1	Stainless Steel Super Duplex Wire Wound “U” Tube for LGB (Lower Guide Bearing) Cooler for Oil Cooler. Size : 12.7 mm OD X 20 SWG Thick X 372 mm Long Tested Pressure : Above 10.5 Kg/ cm ² for 30 minutes Working Medium : Water	1330	Price to be quoted in the price bid form as per the dimension of the items stated in Corrigendum dated 09.02.2017		
2	Stainless Steel 316 Grade Wire Wound “U” Tube for UGB (Upper Guide Bearing) Cooler for Oil Cooler. Size : 12.7 mm OD X 20 SWG Thick X 272 mm Long Tested Pressure : Above 10.5 Kg/ cm ² for 30 minutes Working Medium : Water	150	Price to be quoted in the price bid form as per the dimension of the items stated in Corrigendum dated 09.02.2017		
3	Stainless Steel Super Duplex Wire Wound “Straight” Tube for Generator Air Cooler. Size : 19.05 mm OD X 1.0mm Thick X 2413 mm Long Tested Pressure : Above 10.5 Kg/ cm ² for 30 minutes Working Medium : Water	365	Price to be quoted in the price bid form as per the dimension of the items stated in Corrigendum dated 09.02.2017		

Note:


1. The bidder shall quote only Ex- work price. All applicable taxes & duties, freight & insurance, packing forwarding (if any) charges shall be separately indicated in the price bid.

W. S. S. S.
09/02/2017

2. If the bidder is eligible for any concessional taxes and duties, they should invariably mention this in the bid. The price bids would be evaluated on the basis of information supplied by the bidder and hence the actual payment of taxes & duties and freight & Insurance charges shall be limited to the extent mentioned in the bid or in subsequent confirmation.
3. If the bidder did not mention the price(s) of any item, then his offer may either be considered as incomplete .
4. For all items, prices should be quoted in the above schedule based on requirement.

All other terms & conditions of the bid document shall remain same.

Not to be published


Sr. Manager (E/M), C&P
KHEP, NEEPCO Ltd., Umrongso
Dima Hasao District, Assam

Not in original-

Memo No.: NEEPCO/KHEP/C&P (E)/W-10/2016-17/2977-83

Dated 09.02.2017

Copy to:

1. The HOP, KHEP, NEEPCO Ltd. -for favour of kind information please.
2. **The GM (IT), NEEPCO Ltd., Shillong - with a request to upload the Corrigendum dated 09.02.2017 to NIT no. 267 (copy enclosed) in the NEEPCO website.**
3. The Sr. Manager (E/M), Khandong P.S.- for information please.
4. The Head of Finance, KHEP, Umrongso- for information and necessary action. He is requested to depute a Finance representative at the time of opening of the bid.
5. The Manager (C), Vigilance Wing, KHEP- for information.
6. The DY. Manager(E/M) , Khandong P.S. Maintenance – for information.
7. Tender file (W-10) for record.


09/02/2017

(C. P. Saikia)
Sr. Manager (E/M), C&P (E)
KHEP, NEEPCO Ltd., Umrongso
Dima Hasao, Assam