

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	03-10-2025 19:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	03-10-2025 19:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	90 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Power
विभाग का नाम/Department Name	North Eastern Electric Power Corporation Limited
संगठन का नाम/Organisation Name	North Eastern Electric Power Corporation Limited
कार्यालय का नाम/Office Name	Kameng Hydro Power Station
कुल मात्रा/Total Quantity	1
वस्तु श्रेणी /Item Category	High Mast Lighting Tower for large area with LED Flood Lighting System (Q3)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Exemption for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Exemption for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Certificate (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)

बिड विवरण/Bid Details	
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन / Past Performance	80 %
बिड से रिवर्स नीलामी सक्रिय किया/ Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/ RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/ Type of Bid	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय / Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/ Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/ Arbitration Clause	No
सुलह खंड/ Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	25000

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be

in favour of Beneficiary, wherever it is applicable.

लभार्थी /Beneficiary :

NEEPCO Ltd

Kameng Hydro Power Station, NORTH EASTERN ELECTRIC POWER Corporation Limited, NORTH EASTERN ELECTRIC POWER Corporation Limited, Ministry of Power. OR The bidder may directly deposit the EMD amount in Bank account of Kameng Hydro Power Station. The bank details are as under. a. Name of Payee- NEEPCO Ltd. b. Account No- 11846902143 c. Name of Bank- State Bank of India d. Name of Branch- Bhalukpong, West Kameng, Arunachal Pradesh-790 114 e. IFS code- SBIN 0008516 Documentary evidence in support of deposit of EMD amount shall be attached in techno commercial bid and a copy of the proof of EMD deposit shall be sent by mail without fail.

(Neepeco Ltd)

विभाजन/Splitting

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

Reserved for Make In India products

Reserved for Make In India products	Yes
-------------------------------------	-----

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Bid reserved for Make In India products: : Procurement under this bid is reserved for purchase from Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. However, eligible micro and small enterprises will be allowed to participate. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020 . In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

3. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match

L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

4. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

6. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

High Mast Lighting Tower For Large Area With LED Flood Lighting System (1 pieces)

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Height of High Mast Tower (in Meters)	20
	Installation and commissioning (Installation and commissioning work at multiple locations shall follow as per the guidelines of State/Central Govt rules and regulations as applicable)	Yes. Including Civil work at site
	Onsite warranty (in Years)	2
High mast System	No of sections	2
	Effective length of each section (in m)	10
	Material construction: The mast shall be manufactured using special steel plates, conforming to	355 grade as per BSEN10 025

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Bottom diameter (in mm) - Minimum	610, 540, 570
	Plate thickness for Middle (in mm) - Minimum	4
	Plate thickness for Bottom (in mm) - Minimum	5, 6
	No of longitudinal welds / section (in Nos)	1
	Diameter of base plate (in mm) - Minimum	840, 740, 770
	Thickness of base plate (in mm) - Minimum	30, 25
Wind Load	Maximum Wind load	50 m/sec
Door Opening	Size of opening and closing door at base compartment of high mast (in mm) - Minimum	1200 x 250, 1200 x 300
Junction Box	Ingress protection for Junction Box i.e. IP Class (as per IS/IEC:60529:2001 latest) Test Report from Central Government lab/NABL/ILAC accredited lab and report shall furnish to buyer on demand	IP 65
	No of core	3, 4
	Cable category	FR
	Size of cable (in Sq mm)	1.5, 4
	Conductor material shall be	Copper
Winch	The winch shall have provision for manual operation in case of failure of the motor	Yes
Stainless Steel Wire Rope	The breaking load of each rope shall be at full load as per the relevant standard	>=2400 Kg, >=2250Kg
Electrical System, Cable and Cable Connections	No. of cores	4
	Cable shall be	Armoured
	Conductor material shall be	Copper
	Cable Category	1, C1, C2
	Incoming power cable from feeder panel to base compartment of mast and cable shall conforming to	IS:7098 (Part 1):1988 latest

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Feeder pillar Panel	Feeder pillar panel for each mast	Yes
	Feeder panel shall be suitable for	415 V, 3 phase, 4 wire, 50 Hz, AC
	The control panels shall be	Stand mounted
	Ingress protection for feeder pillar panel i.e IP Class (as per IS/IEC:60529:2001 latest).Test Report shall furnish from Central Government lab/NABL/ILAC accredited lab to buyer on demand	IP 55
	It shall be fabricated out of	14 SWG CRCA sheet steel
	Thickness of sheet (in mm)	2
	The panels shall be given pre-treatment and powder coated and color shall be	Grey
	The stand shall be painted in	Black color
	Cable entry shall be at the	Bottom
	The panels shall have	knock outs of the required cable
	Laminated circuit diagram shall be pasted	inside of the door
	Feeder pillar shall have pad locking arrangement	Yes
	Earth terminal	12 mm dia. Bolts
	Panel shall have a sloping cover to avoid accumulation of dust	Yes
	Panel shall be provided with incoming & outgoing MCCB / MCB of appropriate rating and in desired quantity depending on total no of circuits in use	yes
	Timer for automatic ON & OFF of lights with pilot lamps shall be provided	Yes
	Bus bars material	Yes. Copper
	No of Cores	3, 4
	Size of cable (in Sq.mm)	2.5
	Cable Shall be	Armoured

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	The conductor material shall be	Copper
	cable category	1, C1, C2, No without feeder pillar panel
LED FLOOD LIGHT LUMINAIRE	No. of Luminaires for each high mast lighting tower (in Nos)	8
	LED Rating/System Wattage/Rated Power for each luminaire	250W
	Luminaire System Efficacy (Lumen/watt)	>= 100 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP65
	Mounting brackets (included)	Adjustable
	Input operating Voltage range and frequency	90 to 300 Volts AC at 50Hz+/-2Hz
	Rated voltage	230 V AC 50 Hz
	Colour temperature	6000K (+/- 500K)
	Optic lense material (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense, NA
	Operating temperature range	-20 deg C to +50 deg C
	The luminaire shall be protected against surges and transients(Internal)	>=5KV
	The luminaire shall be protected against surges and transients of >=10KV (External)	Yes
	Number of electronic control gear per luminaire (power supplies)	4 Nos.
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm, 100 cm

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Mrigendra Phukan	790114,Kameng Hydro Power Station Kimi, West Kameng	1	90

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

3. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

Bill of Quantity (BOQ)

SI No.	Item Description	Unit	Qty
	(A) SUPPLY		
1	Design, Manufacture, Supplying, testing and commissioning of 20M High Mast system with its accessories, Mast shaft shall be in two sections of plate thickness 3mm for Top section and 4 mm for bottom, cross section of Mast: 20-sided polygon, section length: The mast height shall be 20 meters, with minimum diameters of 150 mm at the top and 360 mm at the bottom. The PCD of the mast flange shall be minimum 460 mm. M30 foundation bolt length of 850 mm, hot dip galvanised and the structure shall be suitable for wind loading as per IS-875, pt-3, 1987. It should also include accessories for high mast including head frame, steel rope 6 mm dia (7/19 construction), trailing cable, double drum winch, galvanised Lantern carriage arrangement suitable for 08 Nos luminaries 300 W LED Flood Light control gearbox and provision for twin dome LED aviation obstruction lights (AOL)etc. The mast shall have an integral power tool installed inside the base compartment for its operation including supply of foundation bolts manufactured from special steel along with nuts, washer, anchor plates and templates etc. as per specification.	Each	1
2	Supplying of 300W LED Flood Light made up of pressure die cast aluminium housing with toughened glass and high-powered LEDs, silicon potted gel driver with BIS approved, IP66, secondary lenses and protection system 10kV SPD included as per specification. Make Philips/Havells	Each	9

3	Supply of twin LED dome aviation obstruction lights as per specification. Make Philips /Havells	set	1
4	Supplying and erection of Control panel (Feeder pillar) housing 63 A TPN MCB income r, single dial timer, contactor circuit for the automatic control of luminaries, outgoing terminals and control circuit for the power tool motor etc. as per specification	Each	1
5	(A) FOUNDATION		
	Design and Construction of RCC civil foundation for the high mast considering the safe soil bearing capacity at site at 10T/ sq meter at 2-meter depth with all materials and labour including PCC foundation for Feeder pillar as required.	Lot	1
	(B) ERECTION		
	Erection of the High mast and all auxiliary equipment including Feeder Pillar and wiring of Luminaries complete with all materials & labour as per specification.	Each	1
	(C) EARTHING		
	Earthing with GI Pipe earthing for high mast with 2.5 m long 40 mm dia GI pipe including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. with charcoal/ coke and salt as per IS 3043 including connection to the high mast terminals with 25 x 3 mm GI strip with all materials and labour as per specification. Make Jindal/Tata/Nezone	Lot	2
	(D) SUPPLY, LAYING/TRENCHING & TERMINATION		
i	Power supply cable of 1. kV grade, 5 core x 4 Sq. mm and 3 core x 2.5 sq.mm EPR coated, PCP sheathed flexible copper cable including supply, laying/trenching and termination as per specification. Make KEI/Polycab	Lot	1
ii	Power supply cable of 1.1 kV grade, 4 core x 16 Sq. mm and 4 core x 2.5 Sq.mm XLP E insulated armoured copper cable including supply, laying/trenching and termination as per specification. Make KEI/Polycab	Lot	1
iii	Providing service connection with 3.5 core A2XFY, 25 sq.mm armoured U. G. Cable including supply, laying/trenching and termination as per specification. Make KEI/Polycab	Mtr	100

Bidders to note.

1. Bidders should download the detailed bid document uploaded as buyer added ATC.
2. Technical specifications, BOQ and terms and conditions as furnished in buyer uploaded additional ATC shall prevail over GeM.
3. All communications shall be at the email address- cnpkahps@rediffmail.com

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---