

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	10-04-2025 17:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	10-04-2025 17:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	180 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Power
Department Name/विभाग का नाम	North Eastern Electric Power Corporation Limited
Organisation Name/संगठन का नाम	North Eastern Electric Power Corporation Limited
Office Name/कार्यालय का नाम	Kameng Hydro Power Station
क्रैता ईमेल/Buyer Email	indrajitdas@neepco.co.in
Total Quantity/कुल मात्रा	1
Item Category/मद केटेगरी	Electrification works of Hospital Building as per BOQ and Specifications
GeMARPTS में खोजी गई स्ट्रिंग / Searched Strings used in GeMARPTS	Electrification works of Hospital Building at Kameng HPS, Kimi
GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS	Category not available on GeM for the text string uploaded by the buyer
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Certificate (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

Bid Details/बिड विवरण	
Do you want to show documents uploaded by bidders to all bidders participated in bid?/	No
Past Performance/विगत प्रदर्शन	80 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
Type of Bid/बिड का प्रकार	Two Packet Bid
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation
Financial Document Required/वित्तीय दस्तावेज की आवश्यकता है।	Yes
Arbitration Clause	No
Mediation Clause	No

EMD Detail/ईएमडी विवरण

Required/आवश्यकता	No
-------------------	----

ePBG Detail/ईपीबीजी विवरण

Required/आवश्यकता	No
-------------------	----

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any

Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

3. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

4. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

5. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

Electrification Works Of Hospital Building As Per BOQ And Specifications (1 Lot)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

Buyer Specification
Document/क्रेता विशिष्टि दस्तावेज़

[Download](#)

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dhan Chandra Manta	790114, Kameng Hydro Power Station Kimi, West Kameng	1	45

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

Bid Document

1.0 Plant Information:

1.1 About NEEPCO:

North Eastern Electric Power Corporation Limited (NEEPCO), A Wholly owned Subsidiary of NTPC Ltd., is a power sector enterprise with projects located in the various states of the North East.

1.2 Access to Plant Area:

The Kameng Hydro Power Station is located in the West Kameng District of the State of Arunachal Pradesh in India. The nearest railhead is Bhalukpung in Arunachal Pradesh. The nearest airport is Tezpur, with limited services from Kolkata, the nearest major airport is Guwahati.

The Project office i.e. Office of the Head of Plant is located at Kimi, West Kameng District, Arunachal Pradesh, PIN-790114.

The approximate distances by road between the following locations are:

Guwahati to Bhalukpung : 242 km

The Power Plant is approachable via Balipara which is on National Highway 52.

-

2.0 Scope: The work pertains to internal electrification of hospital building at Kameng Hydro Power Station, West Kameng District, Arunachal Pradesh. The scope includes supply and delivery of material as per specifications, installation, fitment, laying of supplied material, testing and commissioning of internal electrification of the hospital building before handing over.

Detail item description given in **Annexure-I -BOQ & Specifications**.

The internal electrification shall cover the following key aspects:

Electrical Wiring: Wiring shall be carried with FRLS PVC insulated copper conductor single core cable in recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point to meet safety standards.

Lighting Systems: The energy efficient 36W, 6500K, 2' x 2' LED Ultra-modern recess mounting luminaire with high performance LEDs, suitable for mounting with Armstrong/Grid ceiling has been considered for adequate lighting.

Power Outlets: Power outlets shall be provided as per standard practice.

UPS Outlet: Adequate numbers of UPS outlets shall be provided.

Internet and CCTV Camera: Surveillance camera, internet and telephone connections shall be provided.

RG 6 outlet: TV cable points in Male and Female wards shall be provided.

Safety Measures: Safety features such as, MCCB, RCCB, MCB and proper earthing of entire building shall be provided.

Service Connection: Shall be provided with 1.1 kV grade, 3.5 x 35 sq.mm. UG cable.

3.0 Warranty: For a period of 12 (Twelve) months from the date of successful completion of works in all respect. If any defect arises during this period, such as manufacturing defects or bad workmanship, the supplier has to replace the same at free of cost.

4.0 Completion Period: The works in all respect shall be completed within 45 days from successful handing over of the work front/site to the Contractor.

5.0 Contract Performance Guarantee

5.1 Within 15 (Fifteen) days from the date of issue of Letter of Intent (Order in GeM portal), the Contractor shall furnish a Bank Guarantee in prescribed format, for an amount equal to 10 (ten) percent of the Contract value by way of Guarantee for the due and faithful performance of the Contract. The Performance Guarantee shall be initially kept valid for such period to cover 90 (ninety) days beyond the warranty period.

5.2 The Bank Guarantee shall be issued either by a Nationalized Bank/Scheduled Bank incorporated in India. The prescribed proforma for the Bank Guarantee for Contract Performance shall be provided to the L1 bidder after placement of LOI (PO in GeM portal).

5.3 The Bank Guarantee submitted in lieu of Performance Guarantee will be returned to the Contractor without any interest at the end of the 90 (ninety) days after the Warranty Period, subject to fulfillment of the scope of supply and delivery in all respects.

5.4 In case BG is not submitted, an amount equivalent to 10% of basic price of material shall be deducted as security deposit. The security deposit shall be released without interest after expiry of defect liability period i.e. warranty period + 90 days.

6.0 Liquidated Damage- If completion of work /delivery of material is delayed beyond the time schedule, due to reasons attributable to the supplier, the Purchaser, shall, without prejudice to his right, recover liquidated damages by reducing the contract price by ½ % (half percent) per week or part thereof of delay in delivery time subject to maximum of 10% (ten percent) of the Contract price. However, liquidated damages shall be waived in case of Force Majeure conditions.

7.0 Force Majeure: The “Force Majeure” risks are those which are beyond the control of either the buyer (NEEPCO) or the Seller(vendor).

8.0 Variation in Quantity:

- 8.1 The Purchaser reserves the right to vary the quantities of items or group of items to be ordered as specified in the accompanying Technical specification as may be necessary during the execution of the contract. However, such variations unless otherwise specified in the accompanying technical specifications, shall not be subject to any limitations for individual items or group of items. The total price variations under the contract shall be limited to plus or minus twenty (+/-20%) percent of the contract price.
- 8.2 The contract price, based on the unit rates available in the contract, shall be adjusted for the change in quantities as above. The base unit rates as identified in the contract shall however remain constant during the currency of the contract.
- 8.3 In case, such unit rates are not available in the agreement for variation in quantity; the same shall be settled as per the formula laid down in this section.

9.0 Withholding payment:

- (a) The Purchaser may withhold the whole or part of any payment for the work claimed by the Contractor, which in the opinion of the Purchaser, is necessary to protect himself from any loss on account of:
- (i) Defective work not remedied.
 - (ii) Claim filed against the Contractor, if any.
 - (iii) Any or part of the contract remain unfinished or withholding/ stoppage of work.
 - (iv) If legal case is instituted by local Government or default of the Contractor.
- (b) When grounds for withholding payment are removed, payment of the amount due to the Contractor shall be made by the Purchaser without delay.

10.0 Assignment & Subletting of Contract:

- (a) The Contractor shall not assign or sublet the Contract or any part thereof to other than those vendors / Sub-Contractors already identified / qualified / approved in the Contract. However, under compelling circumstances, the Contractor may after informing the Engineer and after getting his prior written approval, assign or sublet the Contract or any part thereof provided that such assignment shall not relieve the Contractor from any of his obligations, duties and responsibilities under the Contract.
- (b) In case of items where Sub-Contractors/ vendors have not been identified, the Contractor shall assign or sublet the Contract or any part thereof only after informing the Engineer-in-Charge and after getting his prior written approval. For the purpose of approval, the Contractor shall submit the experience list of the Sub-Contractors/ vendors under consideration by the Contractor to the Engineer-in-Charge along with other requirements/ particulars desired by the Engineer-in-Charge.

11.0 Extra Work:

Extra items of work shall not vitiate the Contract. The Contractor shall have to execute such items of work which, in the opinion of the Engineer-in-Charge, is unavoidable for proper execution of the work and for performance of the plant.

If the analogous rates of such works are available in the Contract, payment for such work will be made at those rates. If, however, the rates of such work are not available in the Bill of Quantities of the Contract Agreement, these will be determined as per the following procedure:

- (a) Cost of materials including transportation
- (b) Cost of labour as per Govt. approved labour rates prevailing in the State for skilled, unskilled labourer.
- (c) Charges for material and other essential accessories etc. to be deployed
- (d) Overhead at the rate of 10% (ten) on (a+b+c)
- (e) 10% (ten) profit on a+b+c
- (f) Total Charges payable = (a+b+c+d+e)

12.0 Terms of Payment:

- (a) In case Bank Guarantee is submitted 100% of total price shall be released after completion of works in all respect.

- (b) In case Bank Guarantee is not submitted 90% of total price shall be released after completion of works in all respect.

13.0 Rejection of Defective Material- In Case material is found defective at the time receipt, the same shall be replaced by the supplier at his own cost and responsibility.

14.0 Credential of Bidder: - Contractors/vendors with previous experience of execution of similar works of internal electrification of buildings in NEEPCO shall be preferred. Bidder or his representative shall visit for survey of site before submitting their tender.

15.0 Site Visit: -Bidder shall visit site before submitting their tenders for realistic assessment of technical requirements as per site conditions. A site visit report duly endorsed by concerned officials of NEEPCO shall be submitted in the technical bid. Without site visit report bids shall not be accepted.

16.0 Technical Requirement: - Bidder shall submit detailed specifications, make and model of quoted material in their technical bid failing which their tender shall be rejected.

Annexure-I

BOQ & Specifications

BOQ & Specifications			
Sl.No.	Description of Items	Unit	Qty
BOQ FOR ELECTRIFICATION OF HOSPITAL BUILDING			

1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.		
1a	Group A	Point	25
1b	Group B	Point	38
1c	Group C	Point	29
2	Wiring for group controlled (looped) light point/fan point/exhaust fan point/ call bell point (without independent switch etc.) with 1.5 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed PVC conduit, and earthing the point with 1.5 sq. mm FRLS PVC insulated copper conductor single core cable etc as required		
2a	Group A	Point	3
2b	Group B	Point	5
2c	Group C	Point	6
3	Wiring for light/ power plug with 2X4 sq. mm FRLS PVC insulated copper conductor single core cable in recessed medium class PVC conduit alongwith 1 No 4 sq. mm FRLS PVC insulated copper conductor single core cable for loop earthing as required.	Metre	38 5
4	Wiring for circuit/ submain wiring along with earth wire with 2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire FRLS PVC insulated copper conductor, single core cable in recessed medium class PVC conduit as required	Metre	12 0
5	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.		
5A	2 X 6 sq. mm + 1 X 6 sq. mm earth wire	Metre	55
5B	4 X 6 sq. mm + 2 X 6 sq. mm earth wire	Metre	60
6	Supplying and fixing of size 20 mm dia of medium class PVC conduit along with accessories in recess including cutting the wall and making good the same in case of recessed conduit as required.	Metre	35 7
7	Wiring for circuit/ submain wiring alongwith earth wire with 2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit for UPS points as required	Metre	80
8	Supplying and fixing following size/ modules, GI box along with modular base & cover plate for modular switches in recess etc as required.		

8a	2 Module (75mmX75mm)	Each	37
8b	3 Module (100mmX75mm)	Each	12
8c	4 Module (125mmX75mm)	Each	6
8d	6 Module (200mmX75mm)	Each	17
9	Supplying and drawing following 02 (two) pair 0.5 mm dia FRLS PVC insulated annealed copper conductor, unarmored telephone cable in the existing surface/ recessed steel/ PVC conduit as required.	Metre	80
10	Supplying and drawing co-axial TV cable RG-6 grade, 0.7 mm solid copper conductor PE insulated, shielded with fine tinned copper braid and protected with PVC sheath in the existing surface/ recessed steel/ PVC conduit as required.	Metre	50
11	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.		
11a	5/6 amps switch 1 Module	Each	22
11b	15/16 amp switch 1 Module	Each	21
11c	3 pin 5/6 amp socket outlet 2 Module	Each	22
11d	6 pin 15/16 amp socket outlet 2 Module	Each	34
11e	Telephone socket outlet 1 Module	Each	9
11f	TV antenna socket outlet 1 Module	Each	2
11g	Bell Push 1 Module	Each	8
11h	20A AC Starter 2 Module	Each	13
11i	RJ 45 CAT 6 Data socket 1 Module	Each	9
12	Supplying and drawing of UTP 4 pair CAT 6 LAN Cable in the existing surface/ recessed steel/ PVC conduit as required		
12a	4 pair UTP CAT 6- 1 run of Cable	Metre	76
12b	4 pair UTP CAT 6- 2 run of Cable	Metre	55
12c	4 pair UTP CAT 6- 3 run of Cable	Metre	50
13	Supplying and fixing 3 pin, 5 amp ceiling rose on the existing junction box/ wooden block including connection etc as required	Each	5

14	Installation, testing and commissioning of ceiling fan, including wiring the down rods of standard length (upto 30 cm) with 1.5 sq. mm FRLS PVC insulated, copper conductor, single core cable, including providing and fixing phenolic laminated sheet cover on the fan box etc. as required. The Ceiling Fan shall be provided by NEEPCO	Each	20
15	Supplying and fixing two module stepped type electronic fan regulator on the existing modular plate switch box including connections but excluding modular plate etc. as required.	Each	20
16	Supplying and fixing extra down rod of 1500 mm length stainless steel 20 mm dia for ceiling fan as required.	Each	20
17	Installation of exhaust fan upto 450 mm sweep in the existing opening, including making good the damage, connection, testing, commissioning etc. as required.	Each	5
18	Extra for fixing the louvers/ shutters complete with frame for a exhaust fan of all sizes.	Each	5
19	Supplying and fixing modular blanking plate on the existing modular plate & switch box excluding modular plate as required	Each	20
20	Supplying and fixing following way, Horizontal type, TPN, sheet steel, MCB distribution board, 415 volts, on surface/ recess, complete with tinned 100A copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator)		
20a	4 Way (4 + 12), Double door	Each	2
21	Supplying and fixing following way, Horizontal single pole and neutral, sheet steel, MCB distribution board, 240 volts, on surface/ recess, complete with tinned 100A copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator)		
21a	6 way, Double door	Each	3
21b	8 way, Double door (1 for UPS)	Each	2
22	Supplying and fixing of following ways surface/ recess mounting, vertical type, 415 volts, Double Door TPN MCB distribution board of sheet steel, dust protected, duly powder painted, inclusive of 200 amps tinned copper bus bar, common neutral link, earth bar, with a provision of TP/FP 'G' Frame MCCB as incomer and SP/TP MCB's as outgoing (but without MCCB & MCB's) as required . (Note : Vertical type TPN MCB distribution board is normally used where 3 phase outlets are required.)		
22a	4 Way (4 + 12), Double door	Each	1
23	Earthing with G.I. earth pipe 4.5 metre long, 40 mm dia including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. with charcoal/ coke and salt as required.	Each	3

24	Providing and laying earth connection from earth electrode with 6 SWG dia G.I. Wire in 15 mm dia G.I. pipe from earth electrode including connection with G.I. thimble excavation and re-filling as required.	Mtr	30
25	Providing and fixing 6 SWG dia G.I. wire on surface or in recess for loop earthing as required.	Mtr	12
26	Laying of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV g grade of size 35 sq. mm direct in ground including excavation, sand cushioning, protective covering and refilling the trench etc as required. The cable shall be provided by NEEPCO	Mtr	30
27	Laying of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV g grade of size 35 sq.mm. in the existing RCC/ HUME/ METAL pipe as required.	Mtr	5
BOQ FOR LIGHT FIXTURES, CCTV CAMERA, MCCB, RCCB ETC FOR HOSPITAL BUILDING			
1	Supply and making necessary connections of following protection devises of make L&T/Philips/Schneider/Havell's as required.		
1a	6A SP MCB, C- Curve	Each	20
1b	20A SP MCB, C- Curve	Each	16
1c	16A SP MCB, C- Curve	Each	12
1d	32A SP MCB, C- Curve	Each	5
1e	40A TP MCB, C- Curve	Each	2
1f	32A Double Pole RCCB 'AC' Type, 30 mA	Each	5
1g	40A Four Pole RCCB 'AC' Type, 30 mA	Each	2
1h	100 A 'G' Frame TP MCCB with 10 kA rms Short-circuit Breaking Capacity Icu at 415 V, Ics = 50% Icu at 415 V (kA rms)	Each	1
2	Supplying & installation of 36W, 6500K, 2' x 2' LED Ultra-modern recess mounting luminaire with high performance LEDs, suitable for mounting with Armstrong/Grid ceiling.	Each	74
3	Supplying and installation of 10 user Nurse Wired call bell Unit	Each	1
4	Supplying and installation of Surveillance camera bullet type	Each	5
5	Supplying and installation of Surveillance camera Dome type	Each	4

Annexure-II

Schedule of Deviations from Specifications

Departures from the Specification shall be set out by the tenderer, clause by clause, in this Schedule. Unless specifically mentioned in this schedule, the tender shall be deemed to conform to Purchaser's specification.

SI No.	Item Under BOQ & Specifications	Requirement as per Bid Specifications	Deviation & Exception from Bid Specification	Reasons / Justifications for deviation

Certified that the above listed deviations and exceptions are exhaustive and the contract shall be executed as per the tender specifications, excepting for the above deviations and exceptions in the event of placing an order on us.

.....
.....
.....

(Place and Date)
Signature)

(S

Other Terms & Conditions

1. Buyer reserves the right to reject any /all bid without assigning any reasons thereof.
2. Bidder shall have valid Electrical Supervisory License.
3. Successful bidder has to submit a detailed Price schedule indicating GST separately against each item in the lot after receipt of order.
4. All future correspondences shall be to the following email address-
 - a) emgkahep@rediffmail.com

b) cnpkahps@rediffmail.com

-

-

3. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---