

**NO. NEEPCO/AGBP/U&WC/T-36/2014-15/**

**DTD. 13/11/2014.**

**NOTICE INVITING LIMITED TENDER**

**NILT.NO. 02**

**DTD 13/11/2014**

Sealed limited tender with 90(ninety) days validity are invited from the local experience electrical firms duly indicating technical particulars, specification, term and conditions for the work "permanent internal wiring and electrification of proposed Training Centre at Mitsubishi Campus of AGBP, NEEPCO Ltd" as indicated in Annexure.

**The quotation must accompany with the following:**

1. Valid electrical contractor license.
2. Valid electrical supervisor license.
3. P.F. Registration certificate.
4. PAN No.
5. Vat Registration certificate.

The sealed quotation can be submitted either by post or by your authorized representative. The sealed quotations will be received up to 15:00 hrs on 12.12.2014 in the office of the undersigned. The quotations shall be opened at 15:30 hrs on the same day i.e. 12.12.2014 in the office of the undersigned in presence of bidders or their representative if there be any. In case the date for receipt & open of quotations happens to be any holiday or 'bandh', the quotations shall be received & opened at same time on next working day.

**TERMS & CONDITIONS:**

1. **Scope of work:** The scope of this contract shall include "permanent internal electrification of proposed Training Centre at Mitsubishi Campus of AGBP, NEEPCO Ltd", Bokuloni dist. Dibrugarh, Assam.
2. **Location of the work:** The work has to be carried out inside the plant area of AGBP, NEEPCO Ltd, Bokuloni, Dibrugarh, Assam.
3. **Price:** The bidder should quote their rates legibly both in figures and words. In case of discrepancy arise in figure and words, the price written in words shall be considered for purpose. The rates of the items should be indicated clearly in figure and words without overwriting. In case of any correction/overwriting the same should be duly signed by the bidder. The rates shall be firm during the currency of the contract.



- 4 **Tax:** Details of taxes & duties as applicable should be mentioned clearly in the quotation and the related documents to tax must be submitted with the quotation. Documents related to tax must be submitted with the offer.
- 5 **Payment:** No advance payment shall be made. 90% payment shall be made on successfully completion of the works as per the specification and another 10% value of the contract shall be deducted from the bill in lieu of security deposit and shall be released after completion of warranty period.
- 6 **Guarantee/Warranty:** The contractor shall guarantee the materials against any manufacturing defects for a period of 06 months from the date of completion of the work. In case any defect or malfunction of the materials are found within the guarantee/warranty period, the same shall be intimated to the vendor promptly and the vendor shall replace the same at free of cost..
- 7 **Tools & plants:** The contractor shall arrange the tools & Plants required for execution of the work.
- 8 **The contractor** shall be solely responsible for arranging adequate safety of the personal while at work and to be adhered to relevant safety regulations.
- 9 **Materials:** Materials to be used for the work shall be provided by the contractor as per specific brand mentioned subject to the acceptance of the site engineers.
- 10 **Time of completion:** The work shall be completed within 30 (thirty) days from the date of handing over the site.
- 11 **Liquidity damage:** - Liquidity damage would be charged 0.5% per week subject to maximum 10% if the work will be not completed within stipulated period.
- 12 **The Contractor shall** ensure full compliance to various India laws and statutory Regulation to extent applicable as stated below, but not limited to in force from time to time.
  - a) Workman's compensation Act 1948.
  - b) Payment of wages Act.
  - c) Contract labour (Regulation & Abolition) Act 1970.
  - d) Provident fund and Miscellaneous Provision Act 1952.
- 13 **The corporation** bears no responsibility whatsoever towards the contractor's personnel for any loss /damage caused by any accident during the works. For any such eventuality the responsibility lies solely on the contractor.



The bid shall be submitted in single part with sealed envelope and should be superscripted as "Quotation for permanent internal electrification for proposed Training Centre at Mitsubishi Campus of AGBP, NEEPCO Ltd" against NILT No. 02 dtd 13/11/2014. The quotation not at par with our terms & conditions will be summarily rejected.

The Corporation is not bound to accept the lowest quotation & reserves the right to cancel any or all the quotations without assigning any reason thereof.

Sr. Manager(E/M), U&WC,  
AGBP, NEEPCO Ltd., Bokuloni,  
Dibrugarh, Assam

NIO:

MEMO.NO. NEEPCO/AGBP/U&WC/T-36/2014-15/ 381-384 DTD. 14/11/14

Copy for favour of kind information to:

1. The HOP, AGBP, NEEPCO LTD., Bokuloni.
2. The Sr. Manager (F&A), AGBP, NEEPCO Ltd., Bokuloni. The administrative approval received vide U.O.NO.NEEPCO/HOP/W-14 (A)/1700 dtd 07.11.2014. He is requested to depute personnel from F&A Wing during time of opening the quotations.
- ✓ 3 The Sr. Manager (IT), AGBP, NEEPCO Ltd., Bokulani, for publish in website.
- 4 The Manager (Vig), AGBP, NEEPCO Ltd., Bokuloni.

Sr. Manager (E/M)  
U & W Complex  
AGBP NEEPCO Ltd.  
Bokuloni, Dibrugarh, Assam

# Specification

# Annexure-1


Item no.	Item Description	Unit	Qty	Rate	Amount
1. 1.1 (Pg no.- 21)	Wiring for light/fan/ call bell point with 2x1.5 sq. mm. P.V.C. insulated single core unsheathed industrial (Multistrand) cable FR conforming to IS-694: 1990 with flexible bright annealed electrolytic copper conductor for voltage grade up to 1100 volts (Finolex/RR Kabel or Equivalent Make as approved by the Deptt.) with flat 19 mm ISI marked casing 'n' capping (AKG / Precision / Presto Plast / Polycab /MW or equivalent make as approved by the Deptt.) in surface system, including 6 Amp flush type switch/ bell push (Anchor Penta/ Gold medal/ Kolor kany.Kom/ Havells or equivalent make as approved by the Deptt.) GI/ MS switch board (ISI marked) half conceal on wall with phenolic laminated sheet cover, ceiling rose (Anchor/ Gold medal/ Kolor kany.Kom/ Havells or equivalent make as approved by the Deptt.) etc. complete as directed and specified by the Deptt.				
1.1.1	Short point up to 3.00 metre. Length	Each	6		
1.1.2	Medium point up to 6.00 metre. Length.	Each	21		
1.1.3	Long point up to 10.00 metre. Length.	Each	29		
2. SB.2.1 0 (Pg no- 681)	Wiring for 5 pin 6 amp plug with 1.5 sq mm P.V.C insulated single core unsheathed industrial (Multistrand) cable HFFR/ZHFR conforming to IS-694:1990 with flexible bright annealed electrolytic copper conductor for voltage grade up to 1100 volts (Finolex/RR Kabel or Equivalent Mke as approved by the Deptt.) including providing and fixing 5 pin 6 Amp socket outlet (Anchor penta/Gold medal/Kolor kanny.Kom/Havells or equivalent make as approved by the Deptt. and 6 amp flush type switch (Anchor or equivalent make) earthing the 3rd pin of the socket as required on the switch board in surface/ recessed P.V.C. conduit wiring system. When fitted on same board of light and fan	Each	8		
3. 1.3(Pg no.- 22)	Wiring for 5/6 pin 16 Amps power plug point with 4 sq. mm. P.V.C insulated single core unsheathed industrial (Multistrand) cable FR conforming to IS-694: 1990 with flexible bright annealed electrolytic copper conductor for voltage grade up to 1100 volts (Finolex/ RR Kabel or Equivalent Make as approved by the Deptt.) with flat 19 mm ISI marked casing 'n' capping (AKG/ Precision/ Presto Plast/ Polycab/ MW or equivalent make as approved by the Deptt.) in surface system, including providing and fixing 5/6 pin 16 Amps flush type socket outlets and 16 Amps flush type switch (Anchor penta/ Gold medal/				

	Kolor kany.Kom/ Havells or equivalent make as approved by the Deptt.), GI/MS switch board (i.s.i marked) with phenolic laminated sheet cover earth continuity with 2.5 sq. mm cable to the 3rd pin of the socket as required complete.				
1.3.1	Medium point up to 6.00 metre. Length.	Each	2		
1.3.3	Long point up to 10.00 metre. Length.	Each	11		
4. 1.8(Pg no.- 25)	Wiring for drawing sub-main line with P.V.C insulated single core unsheathed industrial (Multistrand) cable FR conforming to IS-694 : 1990 with flexible bright annealed electrolytic copper conductor for voltage grade up to 1100 volts (Finolex/ RR Kabel or Equivalent Make as approved by the Deptt.) in surface flat ISI marked casing 'n' capping (AKG/ Precision/ Presto Plast/ Polycab/ MW or equivalent make as approved by the Deptt.) system including earth continuity				
1.8.1	With 2 x 2.5 sq. mm. + earth continuity with 1 x 1.5 sq. mm. in flat 19 mm ISI marked casing 'n' capping system.	Metre	180		
1.8.2	With 2 x 4 sq. mm. + earth continuity with 1 x 2.5 sq. mm. cable in flat 19 mm ISI marked casing 'n' capping system.	Metre	90		
5 SB.5.3 0 (Pg no- 719)	Supplying and fixing of Phillips QCZ 801 TYPE flush type circular ceiling fittings (or equivalent as approved by the Deptt.) complete with Shade, holder, back plate and LAMP holder, 20 Watt CFL lamp including connections as required.	Each	18		
6. 23.3.9 (Pg no- 373)	CRFW12236(255) 2X36 W CFL Crompton make in surface/recessed mounted IP 65 bottom openable Clean room luminaries with clear UV resistant acrylic with 2x36 W CFL. Or equivalent (Equivalent will be selected by the deptt considering the mother items rate) PHILIPS/WIPRO/JAQUAR make	Each	6		
7. 23.1.3 (Pg. no.- 365)	Striplite luminaries complete with VPIT copper ballast/ Electronic ballast and decorative end cap and 1x36/ 40 watt Fluorescent tube.(Crompton Greaves make) Model- DSG1114LDB CROMGOLD/ DSG1114LDBN CROMGOLD NEW/ DSG1214EB ENERGYGOLD/ DSG1314EB CG GOLD/ DSG 1414EB PLANET GOLD with Power Lux Lamp/ Super Save/ Super Brite Lamp or equivalent (Equivalent will be selected by the deptt considering the mother items rate) PHILIPS/ WIPRO/ BAJAJ/ Havells/ HPL/ SOLAR/ JAQUAR make	Each	19		

*Handwritten signature*

8. ECBC 1.1 (Pg no- 993)	Supplying including fitting and fixing of following star rated A.C. Ceiling fan complete with all accessories like down rod, canopy, etc. of following sweeps with making necessary connection cable, as approved by the Deptt. etc. as required complete and as directed by the Department as required complete etc. [without regulator]. (ORIENT PSPO make/Usha/CROMPTON/Havells/ATC/V GAURD make)				
ECBC1. 1.2	Energy efficient 5-star 1200 mm sweep Fusion 5 star (Havells or equivalent make)	Each	13		
9. 27.6 (Pg no.- 419)	Supplying fitting and fixing of ceiling fan regulator including connections etc. complete as required.				
27.6.2	Electronic Type	Each	13		
10. 15.1 (Pg no- 137)	Supplying with fitting and fixing sheet steel, phosphatised, powder painted Single door surface mounting MCB DB incorporated with bus-bar, Neutral link, Earth bar and din rail, etc. fitted on wall with grouting nuts and bolts as reqd. complete with making necessary connections as approved, specified and directed by the deptt.				
15.1.1. 3	8 way SPN single door	Each	3		
11. 16.1 (Pg no- 161)	Supplying with fitting and fixing single Pole 10 KA 240/415V 50 Hz MCB of the following capacity complete with making necessary connection as approved, specified and directed by the deptt.				
16.1.1	B Series (Schneider MG, legrand, Hager, Crabtree Xpro make)				
16.1.1. 1	6 to 32A	Each	21		

  
 Sr. Manager (E/M)  
 U & W Complex  
 AGBP NEEPCO Ltd.  
 Bokuloni, Dibrugarh, Assam

  
 उप प्रबंधक (वि/या)  
 Dy. Manager (E/M)  
 उप० कर्मशाला प्रभाग/U & W Complex  
 ए. जी. बी. पी., नीको लि०  
 AGBP, NEEPCO Ltd.  
 बकुलनी, दिब्रुगढ़  
 Bokuloni, Dibrugarh