

Clarification No. 01 Dated 24.02.2022 to Bidders Queries
NIB No. 411 Dated 09.02.2022.

Name of Work: Tender for renewal of Industrial All Risk (IAR) Insurance Policy for the Assets of Assam Gas Based Power Station (291 MW), Bokuloni, Assam, for a period of 1(one) year w.e.f. 00:00:00 Hours of 19.04.2022.

Sl. No.	Bidders Queries	NEEPCO's Response
1	There is transmission line involved, kindly provide details of the same like - number of poles and length	Distance of 11 KV Transmission line from Intake to AGBPS is 12 Km. Number of poles = 199 Nos.
2	Whether Pipeline exposure is limited within the compound? If outside, also please provide details on the same.	Water conductor system i.e. the pipeline available from River Buridihing to Plant premises is 11 KM. <ul style="list-style-type: none"> • 1 KM length of 600 mm Diameter pipeline and, • 10 KM length of 2 x 50 mm Diameter of pipeline. This is outside of the compound, from Intake to AGBPS. Pipe line is not exposed within the compound. However, the length of exposed pipeline outside plant premises is around 700 meter. Natural gas carrying pipelines are limited within the plant premises.
3	Whether the residential building is within the plant compound?	Residential buildings are outside the plant premises adjacent to plant area, and the same are included in the asset list.
4	For the Addon Coverage - Prevention of Access, please confirm the limit of indemnity. As per tender it says as per actuals whether entire SI under BI is proposed?	Prevention of Access shall cover entire SI under BI, however, it shall be as per Actual (within Treaty Limitations).
5	As understood from the data available there is requirement of SAT as well. Kindly confirm on the same.	May please refer to Clause 1.0, Clause 2.0(i)(B) & Clause 8.0, of Section-IV: Scope of Insurance Coverage of the Bid document.
6	Considering the requirement of Risk Inspection and conclusion with report, we shall also place a request for extension of bid submission timeline till 16 th March 2022, considering the Risk Inspection can be conducted by 1 st week of March.	The tender timeline stipulated in the Bid document shall prevail.

Am
24/02/2022

Am
24/02/2022