

Pre Bid Clarification No.06 dated 03.11.2020 against NIB No.370 dated 31.08.2020

Sl. No.	Queries of Bidders	NEEPCO's Clarification on Exclusions proposed by Bidders
1.	Any HT Power cables of Powerhouse.	Agreed. The same is as per bid specification and record notes of discussion on Cabling system of Pre Bid Meeting dated 09/10/20.
2.	Motor Control Panels/Starter Panels for any of the Turbine Auxiliaries Pumps/Motors.	Bidder may refer to record notes of discussion on Starter Panels of Pre Bid Meeting dated. 09/10/20.
3.	HT & LT Power cables, Control cables, Instrument cables, Cable termination accessories, cable trays and its accessories etc. for Valve House, Dam & Admin Building.	Bidder may refer to record notes of discussion on Cabling system of Pre Bid Meeting dated. 09/10/20.
4.	Any Optic Fiber Cable (OFC) & their accessories related to Valve House, Dam, Administration Building.	Supply and laying of OFC to Valve house, DAM & Admn. Building only is not in bidder's scope. All other accessories, interface requirements for achieving the desired functionality is in bidder's scope.
5.	Any other Power, Control & Instrument cables required for interfacing of equipment not in BHEL scope.	Bidder may refer to record notes of discussion on Cabling system of Pre Bid Meeting dated. 09/10/20.
6.	Cable trays, it's related accessories & support structure for laying of cables not in BHEL scope of supply.	Bidder may refer to record notes of discussion on Cabling system of Pre Bid Meeting dated. 09/10/20.
7.	Grounding system (Underground earthing system/Mat/Grid/Risers/Earthing Pits/Ring main/ Protective earthing//Lightning protection etc.), Soil Resistivity testing etc.	Bidder may refer to Sl. 18 of record notes of discussion on Cabling system of Pre Bid Meeting dated. 09/10/20. Separate electronic earthing, if required, shall be in bidder's scope.
8.	Any software pertaining to systems/items.	Not agreed. All software required for complete functionality of works envisaged are in bidder's scope.
9.	Any Minor or Major civil work.	Bidder may refer to Sl. 63, 96, 97 & 98 of Pre-Bid Clarification No. 2. dated 08/10/20.
10.	Any system study requirement.	Not agreed. Requirements as per bid stipulation shall prevail.