

Pre Bid Technical Clarification No-2 against NIB No.377 dated 26.11.2020

Sl.No.	Bid Stipulation	Bidder's Query	NEEPCO Reply
1.	Section-IV, Vol-2, Turbine Component-PTS Clause No: 1.9.3 Design calculation:	Bidders scope does not includes the supply of Turbine hence, we reiterate our request to remove the requirement to perform the transient analysis. Kindly confirm.	The Bidder need not submit transient analysis as required under various clauses of the Bid document.  However, the Guide vane operating timing shall be maintained as per the existing timings.
2.	Section-IV, Vol-2, Part-I, General Technical Specification Clause No.1.2: Scope of Work, Bidder should note that: Point No.7	As desired by tender, Bidder will hire the agency for "checking of the adequacy & healthiness of existing Civil structures and foundations, by their residual strength mapping, using advanced and proven Tekla Building Information Modelling (BIM) software or any other suitable method", however being E&M supplier Bidder do not have the expertise in Civil work, so further coordination for comment/clarification on report/recommendation of Civil agency will be directly between NEEPCO & that civil agency. Please confirm. Further please be inform that, Bidder will be providing all input related to Generator Foundation loads.	Residual strength mapping of foundation and structures on which equipment under scope of this tender will be installed, need to be carried out by the bidder. Bidder may engage third party with BIM software for the purpose, who would be furnished with all relevant required data. The third party so engaged shall interact directly with the corporation for the required residual strength mapping reports/reccomandations.