

Pre Bid Technical Clarification No.7 against NIB No.377 dated 26.11.2020

Sl. No.	Bid Stipulation	Bidder's Query	NEEPCO's Reply
1.	Section-IV/Vol-3, Part-III/ Bill of Material/ Generator. "Labyrinth clearance with runner monitoring device"	Kindly remove the requirement of "Labyrinth clearance with runner monitoring device" mentioned under "Section-IV/ Vol-3, Part-III/ Bill of Material/ Generator" as bidder is not supplying the Runner, Labyrinth & its associated components and not feasible in the existing machine. Please confirm.	'Labyrinth clearance with runner monitoring device" appearing in BOM for Generator at Page 574/639, SOR for Generator at Page 485/639 and TDS-SCADA at page 566/639 shall stand deleted.