

Pre Bid Technical Clarification No. 9 against NIB No.377 dated 26.11.2020

<b>Sl. No.</b>	<b>Bid Stipulation</b>	<b>Bidder's Query</b>	<b>NEEPCO's Reply</b>
1.	<p>Section IV, Vol - 2, Part -II-03 Generator and Aux - PTS, Page 352</p> <p>Liquidated damages for shortfall in output and efficiency of Generator</p>	<p>The rate of liquidated damages for shortfall in Output and Efficiency is defined in Clause 1.5.1.3, Section-IV, Vol - 2, Part -II-03 Generator and Aux - PTS. However, the same is not capped with respect to the Contract Value. In new Hydropower plants tenders also the performance LDs (output &amp; efficiency of Turbine &amp; Generator put together) is always limited to max 10% (in general) of the Contract value. Therefore, we again request NEEPCO to kindly add the following in the clause to limit the liability of the bidder (on account of performance of the Generator): Maximum penalty due to shortfall in the tested values of rated output and the weighted average efficiency of Generator shall be limited to 10% of the total Contract Value.</p>	<p>Bid specification shall prevail.</p> <p>The LD rate considered in the specification is a function of tariff and has no relation to the contract price. Any shortfall in efficiency and output will be incurred by the corporation till the useful life of the unit /s. Therefore, this standard clause do not have any capping limit but has a rejection limit for the generator.</p>
2.	<p>Section-IV, Vol-2, Part-II-01 Turbine Component-PTS, clause 1.12.1 page 305 Section-IV, Vol-2, Part-II-03 Generator and Aux -PTS, clause 1.11.1 page 377 Section-IV, Vol-2, Part-II-05 Protection System -PTS, clause 1.11.1 page 429 Section-IV, Vol-2, Part-II-06 Control &amp; Monitoring (SCADA) System -PTS, clause 1.9 page 473 Section-IV, Vol-2, Part-II - 00 General Technical Requirement-PTS Clause 9.9.1 (page 276 / 639)</p>	<p>We understand that the tools &amp; tackles list stipulated in the tender under different components/packages is the recommended list and the prices for the same shall not be part of price evaluation.</p>	<p>Bidder may refer to clauses. 10.1.7 (Page-476/639), 10.2.2.2 (Page-478/639), 10.3.12.2 (Page-487/639).</p> <p>Special tools &amp; tackles list stipulated in the tender under different components/packages and the recommended list shall be supplied and quoted along with the break-up. The prices for the same shall be part of price evaluation.</p>

Pre Bid Technical Clarification No. 9 against NIB No.377 dated 26.11.2020

<p>The Contractor shall propose the list of special tools including their make and detailed specification as recommended by manufacturer(s), to be accepted by the Employer. The proposed list of special tools must include the following in addition to tools recommended by manufacturer(s) The Contractor shall list and supply all special tools. List of such tools including their make and detailed specification as recommended by manufacturer(s), shall be subject to approval by the Purchaser. The proposed list of special tools must include the following in addition to tools recommended by manufacturer(s): Special Tools shall be supplied by the Contractor as necessary for erection, installation, operation and maintenance, etc. of each item of equipment supplied under this Contract</p>		
--	--	--