



**Clarification No. 02 Dated 30.04.2021**  
**NIB No. 382 Dated 12.04.2021.**

**Name of Work:** Tender for undertaking Industrial All Risk (IAR) Insurance Policy for the assets of Kameng Hydro Electric Plant (600 MW), West Kameng District, Arunachal Pradesh, for a period of 1(one) year w.e.f. 00:00:00 Hours of 17.06.2021.

Reference is drawn to Minutes of Pre-Bid Meeting Dated 26.04.2021 on the matter of Risk Inspection of the Plant recorded at Sl.No. 1(d) of the MOM. Following additional clarifications are provided for information of all bidders.

Sl. No.	Issues	NEEPCO's Clarification
1	Fire Protection system at Dam site.	Portable Fire Extinguishers have been placed at Dam site.
2	Warning Boards for evacuation during emergency in Power House.	Assembly points for evacuation from Power House have been earmarked with display boards.
3	Fire Protection of Lube Oil System & Hydraulic Oil System and Fire Fighting system in Power House.	All equipment and systems of Power House are protected by pressurized Hydrant system, high velocity water spray, water sprinkler system and portable fire extinguisher along with automatic fire alarm and detection system. In addition, one number water cum foam fire tender is also present in Power House Complex for any eventuality.
4	Illumination of Dam site.	Permanent illumination system at the Dam site is nearing completion.
5	Flame Proof lighting in Battery Room of Power House.	All light fittings in Battery Room of Power House are of flame proof type.
6	Access to Transformer Yard and various floors of the Power House.	The Transformer Yard and different floors of the Power House are kept free from obstruction for easy access.

  
30/04/2021

  
30/04/2021