

**Clarification No. 01 Dated 06.06.2022 to Bidders Queries**  
**NIB No. 422 Dated 24.05.2022.**

**Name of Work:** Tender for Undertaking Standard Fire and Special Perils Insurance policy for the Assets of Khandong Stage-II Power Station (23 MW), KhPS-II, Umrongso, Assam, for a period of 1(one) year w.e.f. 00:00:00 Hours of 19.06.2022.

Sl. No.	Bidders Queries	NEEPCO's Response
1	Why this policy of Khandong Stage-II is same as Kopili Stage-II.	The nomenclature of Kopili Stage-II Power Station has been changed to " <b>Khandong Stage-II Power Station</b> ", with installed capacity of 23 MW.
2	Reason for reduction in Sum Insured from last year.	May please refer to Clause 2.0(iii), Section-II, Information for Bidders of the Bid Document.
3	Whether Plant is operational as of now or shut down?	May please refer to Clause 2.0(iii), Section-II, Information for Bidders of the Bid Document.
4	What Special precaution client has taken to avoid the similar losses in future. We understand there are two large claim at the same location in last 5 years.	<p>In order to avoid the similar losses in future, following safety protocol are being maintained during repair and maintenance works of water conductor system:-</p> <ol style="list-style-type: none"><li>1. Emergency response time shall be kept as low as possible during repair and maintenance of gates by staggering repair &amp; maintenance activities.</li><li>2. Emergency power supply shall be ensured to all control gates during repair and maintenance.</li></ol> <p>Further, the bidders may note that the two claims pertain to two different locations.</p>
5	Whether it is limited tender or open tender?	<p>May please refer to Clause 1, Section-I, NIB of the Bid Document.</p> <p>Open Tender is invited from the IRDAI registered Non-life Insurers.</p>

*PRM*  
06/06/2022

*[Signature]*  
06/06/2022