



**Clarification No. 02 Dated 08.06.2022 to Bidders Queries**  
**NIB No. 422 Dated 24.05.2022.**

**Name of Work:** Tender for Undertaking Standard Fire and Special Perils Insurance policy for the Assets of Khandong Stage-II Power Station (23 MW), KhPS-II, Umrongso, Assam, for a period of 1(one) year w.e.f. 00:00:00 Hours of 19.06.2022.

Sl. No.	Bidders Queries	NEEPCO's Response
1	Photographs/Videos of the Plant site.	Few Photographs of the Plant is enclosed at <b><u>Annexure-I.</u></b>
2	Present Status of the Plant.	<p>In addition to the information provided under clause No. 2.0 (iii), Section-II, Information for Bidders of the bid document, the bidders may note the following additional information.</p> <ol style="list-style-type: none"><li>1. Debris Clearance inside Power House Building, Tail Pool, Draft Tube has been completed.</li><li>2. Emergency DG set has been restored after minor repairing.</li><li>3. The Generator Stator and Rotor and the auxiliaries have been dismantled and cleaned and dry out operation is in progress.</li><li>4. Damaged Electronic components are being restored through BHEL, the OEM.</li></ol>

  
08/06/2022

  
08/06/2022

## Annexure-I





