

NIB No. 369 dated 29/08/2020 – Pre Bid Clarification No. 1

Sl. No.	Stipulations of Bid Document	Bidder's query	NEEPCO's clarifications
	<p>Clause No. 3.1.1, Detailed NIB: The bidder must have successfully executed at least 1 (one) single contract for 220 KV Voltage Class Three Phase Generator Step Up Transformer of at least 63 MVA capacity, which shall include Design, Engineering, Manufacture, Supply, Testing & Commissioning and which is in successful operation as Generator Step Up Transformer for a period of at least 3 (three) consecutive years within a period of 7 (Seven) years ending last day of the month previous to the one in which this NIB is floated. Details, including year wise value of works executed, clients' proof of satisfactory completion of work and operation of such installations shall have to be furnished.</p>	<p>We have successfully executed contract of Three Phase Auto Transformer of voltage class above 220KV and MVA rating above 63MVA. Hence, we proposed documentary evidence of Single phase Auto Transformer of 220KV voltage class or above and 63MVA or above in addition for the referred clause.</p>	<p>Bid stipulation shall prevail.</p>
	<p>Clause No. 3.1.2, Detailed NIB The Bidder must have successfully conducted short circuit Withstand test (special test) as specified in IS 2026 or equivalent standards on similar type 220 KV Voltage Class Generator Transformers of same or higher MVA rating within a period of 5(Five) years as on last date of submission of bid.</p>	<p>We have successfully conducted short circuit withstand test of Single phase Generator Transformer of voltage class above 220KV and MVA rating above 63MVA from KEMA, Netherland. Hence, we proposed Short circuit Test reports of Single phase Generator Transformer of voltage class above 220KV and MVA rating above 63MVA in addition for the referred clause.</p> <p>Further, we would request you to accept short circuit report carried out within last 7 (Seven) years as per accepted norms of NTPC, PGCIL and other utilities.</p>	<p>Bid stipulation shall prevail.</p>


 17/09/2020
 Manager (E/M), CSP