

**CLARIFICATIONS 1 AGAINST NIB No. 345 DTD. 20/01/2020**



Sl. No.	Clause ref.	Clause as per bid document	Bidder's query	NEEPCO's clarification
1.	DNIB, Cl. No. 2	<p>Brief Scope: Design, Engineering, Manufacture, Shop Testing, Inspection at manufacturer's works before dispatch, Packing &amp; Forwarding, Transportation to Site including Transit Insurance, Loading &amp; Unloading, Storage including Intermediate Storage &amp; Storage Insurance, and Supervision of Complete Erection, Testing and Commissioning of the following Generator Transformer complete with all accessories/ fittings and spare parts as specified in the Bid Document for Doyang HE Power Plant(3X25MW), Wokha, Nagaland, India.</p> <p>i) 1 No. 28.5 MVA, OFWF, 11/132 kV, 3 phase Generator Transformer.</p>	<p>Scope of work should exclude:</p> <p>Storage, preservation &amp; conservation of equipment at site. Our Scope to be limited to Design, Engineering, Manufacturing, Testing at Works &amp; Supply to site the above equipment &amp; Spares if any.</p>	<p>Bid condition shall prevail.</p>
2.	DNIB: Cl. 3.3.1	<p>B. The Bidder must have successfully conducted short circuit Withstand test (special test) as specified in IS 2026 or equivalent on similar type of generator transformers (same or higher MVA rating, same voltage class etc.), within a period of 10(Ten) years ending last day of the month previous to the one in which this NIB is floated.</p> <p><b>Note:</b></p> <p>a) Documentary evidence in support of cl. No. 3.1.1(A) shall be furnished only from any Power Utilities / Central or State Govt. PSEs in India.</p> <p>b) Valid short circuit withstand test (special test) certificate conducted in CPRI or in equivalent NABL accredited labs shall be furnished</p>	<p>Waiving off the SC Test requirement:</p> <p>In this regard, please note that we are attaching SC Test Report carried out on 70/35/35 MVA 132KV/6.9-6.9 KV Three Phase Generator Transformer in April 2011 at CPRI Bangalore. As the above clause calls for same Voltage Class for SC Withstand Test, kindly clarify whether this Certificate is acceptable or not for Qualification (Voltage Class is different in Secondary side)</p>	<p>Bid stipulation shall prevail.</p> <p>Submitted SC report is found not to be of Generator Transformer/ Requirement is of SC report of Generator Transformer.</p>

महाप्रबंधक (वै./यां.)  
 General Manager (E/M)  
 कार्यपालक निदेशक (सी एण्ड पी) का कार्यालय  
 O/o The Executive Director (C&P)  
 नीपको लि., शिलांग / NEEPCO Ltd., Shillong-3

General Manager (E/M)  
 The Executive Director (C&P)  
 NEEPCO Ltd., Shillong-3



3.	Sec-II, Cl. 21.1	The Bidders shall quote the basic Prices on “ <b>Firm Price</b> ” basis in the format of Price Schedules given at Section-VII and strictly as per Scope of the Proposal/ Schedule of Requirement at Section-IV of the Bid Document. <b>The basic prices shall remain FIRM during the entire period of the Contract and no escalation shall be allowed on the same.</b>	Price Basis: We request you to kindly modify the Price Basis to Variable as per IEEMA PVC latest Clause without any ceiling considering the base date 1 month prior to bid submission date. This is in view of long Delivery Schedule requirement of 12 months	Bid condition shall prevail.
4.	Sec-II, Cl. 26 (a)	The tender will be finalized through Tender Cum Auction i.e. through the tender followed by reverse auction.	Reverse Auction Clause: As the above item is a raw material intensive nature & estimation of the cost has to be done after design during Bid submission stage, we request you to waive off the Reverse Auction clause, as per NIT Document.	Bid condition shall prevail.
5.	Sec-II, Cl. 14.1	A bid guarantee equivalent to INR 7.30 Lakhs (Indian Rupees Seven Lakhs Thirty Thousand) only shall accompany each bid.	Earnest Money Deposit Amount Rs. 7,30,000/- . Kindly confirm whether we can submit EMD Amount through Bank Guarantee.	Confirmed. BG can be submitted against EMD amount.

  
  
**Dr. General Manager (EM)**  
 O/o The Executive Director (C&P)

महाप्रबंधक (वै./या.)  
**General Manager (EM)**  
 कार्यपालक निदेशक (सी एंड पी) का कार्यालय  
 O/o The Executive Director (C&P)  
 नीपको लि., शिलांग / NEEPCO Ltd., Shillong-3