

Clarification No. 01 Dated 13.05.2022 to Bidders Queries
NIB No. 421 Dated 02.05.2022.

Name of Work: Tender for renewal of Industrial All Risk (IAR) Insurance Policy for the Assets of Tripura Gas Based Power Station (101 MW), TGBPS, Monarchak, Tripura, for a period of 1(one) year w.e.f. 00:00:00 Hours of 23.06.2022.

| Sl. No. | Bidders Queries | NEEPCO's Response |
|---------|--|--|
| | Claim Related Query: | |
| 1 | Share Root Cause Analysis [RCA] report. | RCA Report attached separately as Annexure-I . |
| 2 | Any Consequential Damage. | Damaged of STG Control Valve Spindles. |
| 3 | Status of reinstatement – STG. | STG tripped on 11:06 Hrs of 03/07/2020. STG restored and Synchronized on 00:16 Hrs. of 23/08/2020. Till date STG is running satisfactorily. |
| 4 | Who has done Repair & Reinstatement. | Control valves repaired at SV Turbo Engineering Works (P) Ltd., #D1 & E2, Industrial Estate, Patancheru, Greater Hyderabad, Telangana-502319. Restoration done at TGBPS site by NEEPCO engineer. |
| 5 | Period of Shut Down. | From 11:06 Hrs. of 03/07/2020 to 00:16 Hrs. of 23/08/2020 (Total 51 days shutdown of STG) |
| 6 | Post loss measures taken/ Preventive measures taken after claim. | 1. Both the Governor Control valves repaired and installed at steam turbine. 2. Adequate spares of Governor System purchased and kept ready for future use. 3. A new set of Control Valve assembly procured and kept at TGBPP Store for future use. 4. Order has been placed for major overhauling of STG. 70% spares already been received at TGBPS Store. |
| | To share the Inspection report of the plant. If Inspection Report of the Plant is not available, share the following details: | |
| 7 | Power Purchase Agreement details. | Power Purchase Agreement attached at Annexure-II . |
| 8 | Performance Data [PAF, Plant Heat Rate, outage hour (planned & forced), PLF, etc. for last three years]. | Performance Data attached at Annexure-III . |
| 9 | Location & Distance of ONGC well & number of lines connected to the plant. | ONGC GGS Khedabari to Monarchak: 10 KM (6 Nos. active well) and Trishna to Monarchak: 8 KM (02 Nos. well). |
| 10 | Daily Requirement of Gas [MMSCMPD] for Full Load. | 0.5 MMSCMD |
| 11 | Gas Receiving Pressure & Temperature. | 19 Kg, 32° C. |
| 12 | Does ONGC has Gas Conditioning Skid at your site. | Yes |
| 13 | Gas Boosting Compressor [Running: Standby]. | One unit Running & One unit Standby. |
| 14 | On line Gas Chromatography facility is there or not. | Yes |
| 15 | OEMs of the packages like GTG, STG, HRSG, HV Transformers, etc. with technical details. | Details of OEMs of the packages attached at Annexure-IV . |
| 16 | Lead time of Gas Turbine, Generator, HRSG, Steam Turbine, Generator, Transformers. | One year from techno commercial order. |
| 17 | Any O&M contract, if yes specify the name & period. | 1. M/s. Swamiana International (P) Ltd., Kolkata: Assistance for O&M of GTG and STG. Annual Maintenance Contract. |

| | | |
|----|---|--|
| | | <p>2. M/s. GET Water Solution(P) Ltd., Chennai: Assistance for O&M of Water system, DM Plant, PT Plant, ETP Plant etc. Annual Maintenance Contract.</p> <p>3. Local Contractor: Round the clock operation of Fire Tender and firefighting system. Annual Maintenance Contract.</p> <p>4. M/s. Pranjana Associate, Guwahati: Maintenance contract for Fire detection and Protection system and fire fighting system.</p> |
| 18 | Control system of GTG & STG package. | Attached under Annexure-IV . |
| 19 | DC Back up Facility, Capacity test frequency. | Details attached at Annexure-V . |
| 20 | Details of transmission line like distance [inside & outside the plant], number of towers, crossing any water body/ hilly terrain or not. | <p>1. Monarchak- Rukhia 132 KV Line:28.96 KM</p> <p>2. Monarchak-Banduar 132 KV Line: 41.45 KM</p> <p>3. Monarchak-Rabindranagar 132 KV double circuit lines.2.6 KM each.</p> <p>Power evacuation is under TSECL.</p> |
| 21 | MOC/Bypass Management System. | Not available. |
| 22 | Maintain of SOP. | As per Manual/OEM Guidelines. |
| 23 | Safe system of Work: Isolation, LOTO, PTW, LWC, SFF, etc. | Isolation, PTW |
| 24 | Maintenance procedure & philosophy of equipment & interlocks. | Details attached at Annexure-VI . |
| 25 | Off load preservation practices. | GT & ST Kept on Turning condition and HRSG kept on wet preservation. |
| 26 | Condition based monitoring facility. | Not available |
| 27 | Details of Major & Critical Spare. | Details attached at Annexure-VII . |
| | Details of Fire Safety [Active & Passive]. | <p>Active:</p> <p>1. Automatic Fire detection and Co2 extinguishing system at GTG & STG.</p> <p>2. Emulsifier system at Transformer yards and cable galleries</p> <p>Passive:</p> <p>1. Fire Water & Foam Tender</p> <p>2. CO & DCP cylinders are in place</p> <p>3. Sand buckets & Hose pipes are placed in different locations.</p> <p>On Site & Off site Emergency Plan are in place.</p> |
| 28 | Overall Security system. | NEEPCO security plus Meghalaya Home Guard. Vital installation kept under CCTV surveillance. |
| 29 | Latest Risk Inspection Report. | As Risk Inspection Report is not available, relevant details are provided at Sl. No. 7 to 28 for information and reference. Further, for risk inspection of the Plant, Clause 1.0(b), Section-V: Conditions of Insurance Policy and Clause 2.0(iv), Section-II: Information for Bidders of the Bid Document may please be referred. |

ARM

13/05/2022

Incident Report/Root Cause Analysis

Tripping of STG at Tripura Gas Based Power Plant, Monarchak, Tripura, NEEPCO Ltd.

Dated 22-07-2020

Date and Time of Incident: 03-07-2020 at 11:06 Hrs.

Location: Steam Turbine governing system.

| | | |
|---|---|---|
| 1 | Introduction (brief notes about Steam Turbine trip) | Gas Turbine was commissioned on 11-03-2015 and the Date of Commercial Operation (COD) of Gas Turbine is 24-12-2015. Steam Turbine was commissioned on 14-01-2016 and the Date of Commercial Operation (COD) of Steam Turbine is 31-03-2017. Total capacity of TGBPP, Monarchak is 101 MW. Entire Power generating from this plant is being sold to Tripura State. |
| 2 | Affected Building/machinery | Governing System of Steam Turbine. |
| 3 | Main Activities | Generation of Electricity. Gas Turbine: 65.42 MW & Steam Turbine: 35.58 MW. Total: 101 MW. |
| 4 | Antecedent Conditions of tripping of STG. | (I) Gas Turbine Gen: 62.6MW (II) Gas Press: GBC SUC. PR. 19.33/DISCH. PR.- 31.06 Kg/Sq.CM (III) Fuel gas Temp: GT INLET-87°C (IV) GT Exhaust Temp: 629°C (V) Gas Flow rate: 0.4433MMSCMD (VI) Gas Press: GT INLET 31.06Kg/sq. CM (VII) Steam Turbine Gen: 29.1MW (VIII) Steam Press: HP-75.9, IP-25.5, LP- 4.4KG/CM ² (IX) Steam Flow rate: HP-104.8, IP-7.5, LP- 6.9 TON/HR. (X) STG Condenser CW Temp (Inlet):37°C (XI) STG Condenser Cooling Water Temp (Outlet):42.7°C (XII) GT Generator Current: 3276A (XIII) STG Generator Current: 1562A (XIV) Line in service: L2, L3 and L4 (XV)ST-2 in service (XVI) SAT 1 & 2 in service. (XVII) Raw Water Reservoir Level: 74% (XVIII) Clarified water Tank Level: 68% (XIX) DM Water Tank 1 & 2 Level: 87% (XX) Lube Oil Pressure: PUMP DICSH. 8.6KG/CM ² , HDR PR. 2.14 KG/CM ² . (XXI) Vibration record: TUR- FRNT-26 MICRON, REAR-47 MICRON. GEN-FRNT-39 MICRON, REAR-18 MICRON |

| | | |
|----|--------------------------------|---|
| 5 | Maintenance schedule | Minor overhaul not more than 3years or 20,000 to 25,000 operating hours. Intermediate overhaul after 5 to 6 years or 40,000 to 50,000 operating hours. Major overhaul after 10 to 12 years or 100,000 operating hours. |
| 6 | Last Maintenance activities | Minor overhaul carried out on 24-07-2019 (at running hours: 19000 Hrs.) |
| 7 | Electrical System | Found to be in order. |
| 8 | Other utilities like EOT Crane | Found to be in order. |
| 9 | Fire Protection system | Automatic Fire Protection System in force with additional Co2, DCPs, Sand buckets are in place. |
| 10 | Brief details of the incident | <p>Both GT & ST tripped at 11:06 Hrs. of 03/07/2020 due to rotor earth fault in GT. After rectification work, Gas turbine started immediately and synchronized at 13:38 Hrs. on the same day.</p> <p>During checking before starting steam turbine, it was observed that one HP Governor Valve spindle of Steam Turbine got damaged. On further checking of the operation it is found that the second Control Valve Assembly is also not working.</p> <p>Governor Control valve spindle got bent and stuck. As per the standard practice, all possible measures taken as per procedure for rectification but could not be able to rectify at site due to non-availability of high precession lathe and drill machine and induction heating system. In order to avoid further damage to the equipment, it was decided by the competent authority to send both the control valves assembly to Hyderabad for repairing.</p> <p>Spare control valve normally do not kept in stock. Spare Control valve is also not included under mandatory spare list recommended by the original equipment manufacturer (BHEL).</p> <p>Somehow, we have managed to send the first valve to Hyderabad through Air India Cargo. As informed by the Station Manager, they have suffered inconvenience while transporting the first valve due to COVID-19 situation. In view of COVID-19 there was load restriction in their conveyor belt system. They conveyed their inability at the time of lifting the second valve for transportation. At last the second valve was transported through TCI road transport. To repair the second valves in shortest possible time, second valve was diverted to M/s. S.V.Turbo Engineering Service Pvt. Ltd. Hyderabad.</p> |
| 11 | Probable cause | Due to high thrust at the time of sudden tripping of both Gas Turbine and Steam Turbine resulting damage in Governor valve Assembly, which is accidental in nature. |

Jadhav


Alor

| | | |
|----|--------------------------------|--|
| | | <p>STG graphical trend is attached for supporting of healthiness of STG parameters before the incident.</p> <p>After thorough inspection and field study it is concluded that the main cause of damages may be due to the reason:</p> <p>132 KV Grid of Tripura become sensitive particularly during rainy and stormy season, number of machine tripping is higher during that period.</p> |
| 12 | Recommendation for improvement | <p>(I) It is recommended to repair existing two number damaged control valves assemblies at the earliest to restore the STG Generation at the earliest.</p> <p>(II) It is recommended to procure a new complete set control valve assembly at the earliest for use in case of urgency and to avoid long term generation loss.</p> |



Shri Jayanta Das

उप महाप्रबंधक (वि.या.)
Dy. General Manager (E/M),
राज्यीय वि. नि.प.को. (TGBPP, NEEPCO)



Shri Ajit Dubey



Shri Bijoy Krishna Das



जिपूरा त्रिपुरा TRIPURA

00AA 217602

POWER SUPPLY AGREEMENT
BETWEEN
NORTH EASTERN ELECTRIC POWER CORPORATION LIMITED
AND
TRIPURA STATE ELECTRICITY CORPORATION LIMITED.
AGARTALA

THIS POWER SUPPLY AGREEMENT is entered into on this Nineteenth day of March Two Thousand Eight between **North Eastern Electric Power Corporation Limited**, a Company incorporated under the Companies Act, 1956 having its registered office at Brookland Compound, Lower New Colony, Shillong - 793003 (hereinafter called "NEEPCO" which expression shall unless repugnant to the context or meaning thereof include its successors and assigns) as party of the first part and the **Tripura State Electricity Corporation Limited**, a company registered under the Companies Act, 1956 having its registered office at Vidyut Bhawan, North Banamalipur, Agartala, Tripura - 799001 (herein after called "Bulk Power Customer", which expressions shall unless repugnant to the context shall include their respective successors and assigns) as party of the second part.

WHEREAS NEEPCO is the generating company of Government of India and Tripura State Electricity Corporation Limited, the Bulk Power Customer shall be the sole off taker of power from Tripura Gas Based Power Project owned and to be operated by NEEPCO for further consumption / trading by the Bulk Power Customer.

Now, therefore, in consideration of the premises and mutual covenant and conditions set forth herein, it is hereby agreed by the parties hereto as follows:-

1.0 DEFINITIONS

The words/expressions used in this Agreement, unless repugnant to the context shall have the same meanings as respectively assigned to them by the Electricity Act, 2003, as amended from time to time and Act that would come into force as a substitute or otherwise to the above stated Act. The words/expressions mentioned below shall have the same meanings as respectively assigned to them hereunder:-

- a. Month : Means English calendar month.
- b. Year : Means financial year commencing on 1st April and ending on 31st March.
- c. Project : Means Tripura Gas Based Power Project situated at Monarchak, Sonamura Sub-Division, West Tripura District, Tripura owned & to be operated by NEEPCO.
- d. Energy : Means the Electrical energy.
- e. Power : Means the Electrical Power.
- f. REA : Means a monthly statement prepared by the North Eastern Regional Power Committee (NERPC) showing Regional Energy Accounting for each State of North Eastern Region for the purpose of billing.
- h. LC : Means Letter (s) of Credit.
- i. CERC : Means Central Electricity Regulatory Commission.
- j. GOI : Means Govt. of India
- k. IEGC : Means Indian Electricity Grid Code.
- l. MOP : Means Ministry of Power.
- m. Outage : Means the State of component when it is not available to perform its intended function due to some event directly associated with that component.
- n. NERPC : Means North Eastern Regional Power Committee.
- o. NERLDC : Means North Eastern Regional Load Despatch Center.
- p. DPR : Means Detailed Project Report as submitted to MOP at August, 2006 Price level.
- q. TPA : Means Tripartite Agreement signed between Govt. of India, Govt. of Tripura and Reserve Bank of India regarding realisation of dues by NEEPCO from the Bulk Power Customer against sale of electricity.
- r. HOD : Means Head of Department.

2.0 INSTALLED CAPACITY & ALLOCATION OF POWER:

- 2.1 The installed capacity of Tripura Gas Based Power Project shall be **104 MW**. The installed capacity is however, subject to de-rating/up-rating of the generating units as determined from time to time by CEA.
- 2.2 The allocation of power from the project to the Bulk Power Customer, here Tripura State Electricity Corporation Ltd, shall be the entire Ex-Bus power (about 100 MW) of the Project for their consumption and trading outside the State in case of surplus.

3.0 GENERAL OBLIGATIONS:

- 3.1 NEEPCO is a generating company as defined under Section 2(28) of Electricity Act, 2003 and shall perform duties as defined under section 10 of Electricity Act, 2003 for supply & transmit of Electricity to the Bulk Power Customer.
- 3.2 NEEPCO shall obtain in principle clearance for setting up the project from appropriate commission / authority including approval of capital cost of project. No time and cost overrun due to reasons attributable to NEEPCO shall be entertained by the Bulk Power Customer.
- 3.3 The energy to be supplied under this agreement shall be in the form of three phase, 50 Hertz Alternating Current at a Voltage of 132 KV or as applicable. The frequency and voltage shall be subject to fluctuations as per provisions contained in IEGC and as amended from time to time.

4.0 DELIVERY POINT / EVACUATION OF POWER FROM NEEPCO STATION.

The Delivery Point of the power shall be 132KV Bus-Bar of the Project. Evacuation of power from the delivery point of the project up to Surjamaninagar Sub-Station of the Bulk Power Customer shall be through the 132 KV Double Circuit Transmission Line, as will be constructed by NEEPCO or the Bulk Power Customer. The Bulk Power Customer shall convey their decision regarding construction of the above mentioned Transmission Line by them to NEEPCO by 15th April, 2008. In case the Transmission Line is constructed by NEEPCO, the wheeling charge to be worked out by NEEPCO in line with Tariff Regulations of CERC, as applicable from time to time, shall be paid by the Bulk Power Customer to NEEPCO.

5.0 METERING ARRANGEMENTS:

Metering arrangements including its installation, testing, maintenance of meters and collection, transmission and processing of data required for energy exchange shall be governed as per the notification/directives issued by CERC from time to time and as per relevant provisions contained in IEGC and as amended from time to time.

6.0 ACCOUNTING OF ENERGY:

The quantum of energy sold to the Bulk Power Customer out of the energy available for sale shall be the energy as indicated in the REAs issued by NERPC. The REA including amendments, if any, as issued by NERPC shall form the basis for billing purposes and shall be binding on both the parties.

7.0 TARIFF:

- 7.1 The tariff to be charged and its associated terms and conditions for the energy to be supplied by NEEPCO from the Project shall be determined by CERC and NEEPCO shall file tariff petition before CERC within 6 (six) month from the date of commercial operation of the Project.
- 7.2 In case the tariff is not determined by CERC or any other competent authority prior to the commencement of commercial operation of the Project, the parties shall agree that NEEPCO may workout the provisional tariff based on CERC's terms and conditions as applicable from time to time as per estimated completion cost for the Project. NEEPCO shall inform the Bulk Power Customer of such provisional tariff. Both the parties shall mutually agree to the provisional tariff for the purpose of billing on provisional basis subject to adjustment as and when the tariff is determined by CERC.
- 7.3 In addition to the energy tariff and wheeling charge (if applicable) set out, the Bulk Power Customer shall also be liable to pay to NEEPCO, in accordance with any law in force, all payments payable by it on account of taxes, duties, cess, levy, fees or other imposition etc., levied or to be levied in future as a new tax by the GOI or other authority in respect of generation, transmission and supply of energy including activities incidental and ancillary thereto as per orders of CERC / GOI in this regard.

8.0 BILLING:

- 8.1 NEEPCO shall prepare bills for the energy supplied to the Bulk Power Customer on the basis of REAs issued by NERPC/NERLDC and Bulk Power Customer shall accept these bills for payment. The bill shall be the aggregate of charges as approved/notified by CERC/GOI from time to time.
- 8.2 In case Bulk Power Customer has any objection as to the accuracy of any bill(s), it shall lodge a written objection with NEEPCO within 15 days on presentation of such bill(s). On such objection being upheld by NEEPCO, the same shall be rectified within a period of 30 days from the date of receipt of written objection and necessary effect of the same shall be given in the subsequent bill(s). However, payment of such bills should not be kept withheld by the Bulk Power Customer.

- 8.3 The settlement of all disputed current dues shall be governed as per the directives of CERC/GOI, as issued from time to time.

9.0 PAYMENT:

- 9.1 For the 1st 12 months of operation, NEEPCO shall raise the bills as per Clause-8.1 of this Agreement against energy supplied and the Bulk Power Customer shall pay the bill within 30 days of receipt of the bill every month. After 12 months of operation, the Bulk Power Customer shall establish a confirmed, revolving, irrevocable Letter of Credit to be established in favour of NEEPCO for an amount equivalent to 105 percent of their average monthly billing of preceding 12 months with appropriate bank, as mutually acceptable to the parties. The LC shall be kept valid at all the time during the validity of this agreement or extended period. The amount of LC shall be reviewed quarterly. NEEPCO shall intimate the revised amount of LC one month in advance of start of the quarter. If still the amount of energy supplied is more than the amount of LC, the payment of excess amount shall be made by the Bulk Power Customer directly on presentation of such bill(s). All the bank charges shall be borne by the Bulk Power Customer.
- 9.2 NEEPCO shall present bill(s) to the said Bankers with a copy to the Bulk Power Customer. The bill(s) so presented by NEEPCO to the said Bankers shall be promptly paid on their presentation.
- 9.3 Notwithstanding the above, if the Bulk Power Customer has not signed the TPA, shall pursue to obtain guarantee from its State Government, as per mutually agreed draft to guarantee the performance of the obligations of Bulk Power Customer to make regular payments of the energy bills presented by NEEPCO for power supplied/ to be supplied to Bulk Power Customer from the Project.

10.0 SURCHARGE ON LATE PAYMENT AND REBATE:

- 10.1 The provision for levy of surcharge and rebate shall be governed as per CERC Regulations applicable from time to time.
- 10.2 Notwithstanding what is contained above, if the bill(s) are not paid by Bulk Power Customer to NEEPCO within 60 days from the date of billing, NEEPCO shall have the option to regulate the supply of energy to Bulk Power Customer in accordance with the provisions of TPA or directives/guidelines issued by CERC/GOI from time to time.

11.0 ARBITRATION:

- 11.1 All questions, differences or disputes between the parties arising out of or in connection with this Agreement save and except as provided under clause 6.0 of the agreement to the extent of power vested with NERPC, shall be settled through arbitration in accordance with the provision of Arbitration and Conciliations Act, 1996 and any statutory modifications thereto. However, before referring the matter to arbitration, efforts shall be made by the parties to settle the disputes through conciliation.
- 11.2 In the event of such question, differences or disputes between the parties, any party may by a written notice of 30 days to the other party, request for appointment of a Sole Arbitrator to be decided mutually by the parties and in case of disagreement within 15 days thereafter to be decided by Chairman, Central Electricity Authority. The appointment of Sole Arbitrator either mutually agreed by the parties or decided by the Chairman, CEA, SHALL be made by Head of Commercial Department of either of the parties along with the reference of dispute between the parties for adjudication by the Sole Arbitrator. The venue of the arbitration proceedings shall be decided by the Arbitrator with the consent of parties. The High Court of Guwahati shall have exclusive jurisdiction in all matters arising under this Agreement.
- 11.3 The Arbitrator shall reasonably decide his fees. However, the Arbitrator's fees and cost of arbitration proceedings shall be borne equally by the parties. The arbitrator shall publish the award, within a reasonable time.

11.4 Notwithstanding the existence of any question, disputes and differences referred to arbitration, the parties hereto shall continue to perform their respective obligations under this Agreement.

12.0 FORCE MAJEURE:

Both the parties shall ensure compliance of the terms of this agreement. However, no party shall be liable for any loss or damage whatsoever arising out of failure to carry out the terms of this Agreement to the extent that such failure is due to force majeure events such as rebellion, mutiny, civil commotion, riot, strike, lock out, fire, explosion, flood, drought, cyclone, lightening, earthquake, war or other forces, accident, landslide, sabotage, terrorism, malicious act of kidnapping or act of God. But, any party claiming the benefit of this clause shall satisfy the other party of the existence of such an event(s).

13.0 DURATION OF AGREEMENT:

This agreement shall come into force from the date of signing of this Agreement and shall remain operative for 5(five) years from the commercial operation date of the last unit of project provided that this Agreement may be mutually extended, renewed or replaced by another Agreement on such terms and for such further period of time as the parties may agree to. However, the provisions of this agreement shall continue to operate till this Agreement is formally renewed, extended, or replaced, in case the Bulk Power Customer continues to get power from the Project even after expiry of this Agreement without further renewal or formal extension thereof.

14.0 NOTICES:

All notices required or referred to under this Agreement shall be in writing and signed by the authorities mentioned herein below unless otherwise notified. Each such notice shall be deemed to have been duly given, if delivered or sent by registered mail with an acknowledgement due, to the other party.

A. TO NEEPCO :

General Manager (Comm.),
NEEPCO Ltd., Brookland Compound,
Lower New Colony, Shillong-793 003

With a copy to:

Head of Project,
Tripura Gas Based Power Project,
Monarchak, West Tripura District, Tripura

B. BY NEEPCO :

General Manager (Comm.)
NEEPCO Ltd., Brookland Compound,
Lower New Colony, Shillong - 793 003.

With a copy to:

Head of Project,
Tripura Gas Based Power Project,
Monarchak, West Tripura District, Tripura

ANNEXURE - 16

C. TO Bulk Power Customer :

The Director (Technical),
Tripura State Electricity Corporation Ltd.,
North Banamalipur,
Agartala - 799 001, Tripura.


D. BY Bulk Power Customer :

The Additional General Manager,
Commercial & System Operation,
Tripura State Electricity Corporation Ltd.,
North Banamalipur,
Agartala - 799 001, Tripura.

15.0 IMPLEMENTATION OF THE AGREEMENT:

Any Tripartite Agreement signed between Govt. of India, Govt. of Tripura and Reserve Bank of India regarding realisation of dues by NEEPCO from the Bulk Power Consumer against sale of electricity shall form an integral part of this agreement. In case, any of the provisions of this Agreement are inconsistent with the provisions of the Tripartite Agreement, mentioned above, then the provisions of Tripartite Agreement shall prevail.

IN WITNESS WHEREOF the parties have executed these presents through their duly authorised representatives caused on the day month and year first above written.


 19/3/08
C.P.K. BORAH

For and on behalf of
North Eastern Electric Power Corporation Ltd.

नीरको डि., रितांग
General Manager (Comm),
NEEPCO. Ltd. Shillong.


WITNESS:-

1.

 19/03/08
Arup ch. Sarmah

2.


उपरि प्रबंधक (विद्युत)
प्रशासक (वाणिज्यिक) का कार्यालय
नीरको डि., रितांग
Sr. Manager (E)
of the General Manager (Comm)
NEEPCO. Ltd., Shillong

 19/3/08

For and on behalf of
Tripura State Electricity Corporation Ltd.

WITNESS:-

1.

 19/3/08
E.M. Debbarma
Addl. General Manager
Commercial & System Operation
Tripura State Electricity Corporation Limited
Agartala, Tripura

Dipak Ganguli
Chairman-Managing Director
Tripura State Electricity Corporation Ltd.

2.

TGBPP- KEY PERFORMANCE INDICATOR, 2019-20 (PERIOD: APRIL 2019 TO MARCH 2020)

| Month | ACTUAL GEN | | STATION CONSUMPTION (Auxiliary) | | Colony Consumption | | GAS CONSUMPTION | TOTAL LANDED COST OF GAS | CALORIFIC VALUE | | SP. GAS CONS | STATION HEAT RATE | | PLF | PAF |
|-------------------|------------|------------|------------------------------------|------|--------------------|------|-----------------|--------------------------|-----------------|----------|--------------|-------------------|----------|--------|--------|
| | GROSS GEN | EX-BUS GEN | | | | | | | NET | GROSS | | ON NCV | ON GCV | | |
| | MU | MU | MU | % | MU | % | SCM | Rs in Crore | Kcal/SCM | Kcal/SCM | SCM/KWh | Kcal/KWh | Kcal/KWh | % | % |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 |
| Apr-19 | 55.159 | 52.961 | 2.198 | 3.98 | 0.031 | 0.06 | 12171791 | 10.4889092 | 8273.471 | 9180.700 | 0.2207 | 1825.69 | 2025.88 | 74.85 | 82.15 |
| May-19 | 54.841 | 52.521 | 2.269 | 4.14 | 0.051 | 0.09 | 12211494 | 10.5142520 | 8266.649 | 9173.804 | 0.2227 | 1840.74 | 2042.74 | 71.99 | 87.95 |
| Jun-19 | 56.771 | 54.453 | 2.268 | 3.99 | 0.050 | 0.09 | 12207286 | 10.5060040 | 8263.125 | 9169.863 | 0.2150 | 1776.79 | 1971.77 | 77.30 | 85.62 |
| Jul-19 | 55.898 | 53.570 | 2.259 | 4.04 | 0.069 | 0.12 | 12299877 | 10.8098570 | 8261.847 | 9168.435 | 0.2200 | 1817.95 | 2017.44 | 73.18 | 87.96 |
| Aug-19 | 57.755 | 55.393 | 2.328 | 4.03 | 0.034 | 0.06 | 12837382 | 11.3625665 | 8259.442 | 9165.953 | 0.2223 | 1835.85 | 2037.34 | 75.74 | 89.32 |
| Sep-19 | 52.370 | 50.075 | 2.525 | 4.82 | 0.031 | 0.06 | 11980994 | 10.4063325 | 8273.471 | 9165.659 | 0.2288 | 1892.77 | 2096.88 | 70.91 | 84.16 |
| Oct-19 | 63.629 | 61.349 | 2.737 | 4.30 | 0.030 | 0.05 | 13623301 | 11.8312818 | 8258.133 | 9164.559 | 0.2141 | 1768.11 | 1962.18 | 83.99 | 90.23 |
| Nov-19 | 64.546 | 62.239 | 2.269 | 3.52 | 0.0376 | 0.06 | 13719550 | 11.9146793 | 8258.006 | 9164.408 | 0.2126 | 1755.28 | 1947.94 | 88.30 | 91.32 |
| Dec-19 | 71.872 | 69.392 | 2.444 | 3.40 | 0.035629 | 0.05 | 14804711 | 12.8473153 | 8257.599 | 9164.005 | 0.2060 | 1700.96 | 1887.67 | 95.28 | 97.43 |
| Jan-20 | 48.265 | 46.235 | 1.996 | 4.14 | 0.034065 | 0.07 | 10500485 | 9.1205594 | 8265.187 | 9167.470 | 0.2176 | 1798.17 | 1994.47 | 63.70 | 64.12 |
| Feb-20 | 62.839 | 60.642 | 2.164 | 3.44 | 0.032838 | 0.05 | 13009001 | 11.2895986 | 8258.224 | 9164.68 | 0.2070 | 1709.63 | 1897.28 | 88.91 | 94.41 |
| Mar-20 | 69.513 | 67.268 | 2.206 | 3.17 | 0.039002 | 0.06 | 14357480 | 12.4634872 | 8260.484 | 9166.924 | 0.2065 | 1706.15 | 1893.37 | 92.21 | 95.48 |
| TOTAL/ AVERAGE | 713.458 | 686.098 | 27.66387 | 3.92 | 0.475215 | 0.07 | 153723352 | 122.1922763 | 8262.970 | 9168.039 | 0.216 | 1785.674 | 1981.246 | 79.697 | 87.513 |

ED (O&M), PI.

U. Anurag D. Lamb
03/04/2020
Operation incharge, DGM - (E/M)
TGBPP, NEEPCO, Monarchak.

K. Sreedhar
03/04/2020
Shift Incharge- (E/M)
TGBPP, Monarchak

TGBPP- KEY PERFORMANCE INDICATOR, 2020-21 (PERIOD: APRIL 2020 TO MARCH 2021)

| Month | ACTUAL GEN | | STATION CONSUMPTION (Auxiliary) | | Colony Consumption | | GAS CONSUMPTION | TOTAL LANDED COST OF GAS | CALORIFIC VALUE | | SP. GAS CONS | STATION HEAT RATE | | PLF | PAF |
|---------------------------|----------------|----------------|---------------------------------------|-------------|-----------------------|--------------|--------------------|--------------------------------|-----------------|-----------------|-----------------|-------------------|-----------------|---------------|---------------|
| | GROSS GEN | EX-BUS GEN | | | | | | | NET | GROSS | | ON NCV | ON GCV | | |
| | MU | MU | MU | % | MU | % | SCM | Rs in Crore | Kcal/SCM | Kcal/SCM | SCM/KWh | Kcal/KWh | Kcal/KWh | % | % |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 |
| Apr-20 | 45.905 | 43.695 | 2.1717 | 4.73 | 0.0383 | 0.083 | 10426269 | 9.4083119 | 8257.005 | 9163.327 | 0.2271 | 1875.39 | 2081.24 | 61.84 | 67.19 |
| May-20 | 44.673 | 42.218 | 2.4167 | 5.41 | 0.03833 | 0.086 | 10401392 | 9.5963441 | 8257.409 | 9163.738 | 0.2328 | 1922.61 | 2133.63 | 57.93 | 59.90 |
| Jun-20 | 39.972 | 37.555 | 2.3828 | 5.96 | 0.034 | 0.086 | 9916643 | 9.2606060 | 8258.971 | 9165.403 | 0.2481 | 2048.97 | 2273.84 | 53.37 | 53.78 |
| Jul-20 | 26.799 | 25.417 | 1.3500 | 5.04 | 0.030 | 0.112 | 9952279 | 9.2936526 | 8258.794 | 9165.214 | 0.3714 | 3067.05 | 3403.66 | 34.80 | 34.82 |
| Aug-20 | 28.085 | 26.603 | 1.4503 | 5.16 | 0.0317 | 0.113 | 9786065 | 9.1339395 | 8254.702 | 9160.994 | 0.3484 | 2876.31 | 3192.10 | 36.36 | 36.46 |
| Sep-20 | 31.098 | 29.316 | 1.7490 | 5.62 | 0.033 | 0.106 | 7258530 | 6.7721308 | 8252.200 | 9158.364 | 0.2334 | 1926.13 | 2137.64 | 41.74 | 42.33 |
| Oct-20 | 22.794 | 21.711 | 1.0519 | 4.61 | 0.031 | 0.136 | 5601655 | 5.2387212 | 8264.741 | 9171.671 | 0.2458 | 2031.07 | 2253.95 | 29.95 | 30.87 |
| Nov-20 | 52.894 | 50.691 | 2.1792 | 4.12 | 0.02385 | 0.045 | 11733326 | 10.9656498 | 8259.232 | 9165.738 | 0.2218 | 1832.12 | 2033.21 | 71.69 | 78.94 |
| Dec-20 | 48.009 | 45.882 | 2.0981 | 4.37 | 0.0289 | 0.060 | 10847621 | 10.1040489 | 8253.279 | 9159.497 | 0.2259 | 1864.83 | 2069.59 | 62.95 | 65.92 |
| Jan-21 | 63.987 | 61.700 | 2.2583 | 3.53 | 0.0287 | 0.045 | 13443361 | 12.4752998 | 8241.796 | 9147.200 | 0.2101 | 1731.56 | 1921.78 | 84.71 | 95.48 |
| Feb-21 | 60.119 | 57.986 | 2.1074 | 3.51 | 0.0256 | 0.04 | 12632471 | 11.7360867 | 8251.063 | 9157.39 | 0.2101 | 1733.75 | 1924.19 | 88.20 | 103.10 |
| Mar-21 | 68.334 | 66.035 | 2.2727 | 3.33 | 0.0263 | 0.04 | 14260929 | 13.2419303 | 8246.328 | 9152.143 | 0.2087 | 1720.96 | 1910.00 | 90.98 | 94.32 |
| TOTAL/ AVERAGE | 532.669 | 508.809 | 23.48807 | 4.62 | 0.36988 | 0.079 | 126260541 | 117.2267216 | 8254.626 | 9160.890 | 0.249 | 2052.562 | 2277.903 | 59.543 | 63.593 |

ED (O&M), Pl.

Operation incharge, DGM - (E/M)

TGBPP NEEPCO Monarchak
 Dy. General Manager (E/M)
 TGBPP NEEPCO Ltd. Monarchak.

Shift Incharge- (E/M)

TGBPP, Monarchak

TGBPP- KEY PERFORMANCE INDICATOR, 2021-22 (PERIOD: APRIL 2021 TO MARCH 2022)

| Month | ACTUAL GEN | | STATION CONSUMPTION (Auxiliary) | | Colony Consumption | | GAS CONSUMPTION | TOTAL LANDED COST OF GAS | CALORIFIC VALUE | | SP. GAS CONS | STATION HEAT RATE | | PLF | PAF |
|---------------------------|----------------|----------------|---------------------------------------|-------------|-----------------------|--------------|--------------------|-----------------------------|-----------------|-----------------|-----------------|-------------------|-----------------|--------------|--------------|
| | GROSS GEN | EX-BUS GEN | | | | | | | NET | GROSS | | ON NCV | ON GCV | | |
| | MU | MU | MU | % | MU | % | SCM | Rs in Crore | Kcal/SCM | Kcal/SCM | SCM/KWh | Kcal/KWh | Kcal/KWh | % | % |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 |
| Apr-21 | 54.448 | 52.582 | 1.8801 | 3.45 | 0.0259 | 0.048 | 12065839 | 11.6682369 | 8255.334 | 9160.268 | 0.2216 | 1829.41 | 2029.94 | 74.72 | 76.19 |
| May-21 | 69.426 | 67.065 | 2.3340 | 3.36 | 0.0270 | 0.039 | 14802027 | 14.3107606 | 8253.158 | 9159.367 | 0.2132 | 1759.62 | 1952.83 | 92.61 | 97.20 |
| Jun-21 | 66.576 | 64.257 | 2.2612 | 3.40 | 0.0578 | 0.087 | 14251942 | 13.7781934 | 8252.729 | 9158.858 | 0.2141 | 1766.66 | 1960.64 | 91.73 | 97.31 |
| Jul-21 | 61.045 | 59.046 | 1.9335 | 3.17 | 0.0654 | 0.107 | 14349116 | 13.8572722 | 8252.159 | 9158.347 | 0.2351 | 1939.74 | 2152.74 | 81.65 | 85.14 |
| Aug-21 | 63.973 | 61.738 | 2.1824 | 3.41 | 0.0526 | 0.082 | 14570263 | 14.0651618 | 8248.568 | 9154.801 | 0.2278 | 1878.66 | 2085.06 | 85.24 | 88.72 |
| Sep-21 | 54.234 | 52.131 | 2.0604 | 3.80 | 0.0426 | 0.079 | 12278460 | 11.8600673 | 8253.762 | 9160.451 | 0.2264 | 1868.63 | 2073.91 | 74.53 | 80.51 |
| Oct-21 | 62.794 | 60.597 | 2.1531 | 3.43 | 0.0439 | 0.070 | 14009635 | 13.5255699 | 8249.873 | 9156.378 | 0.2231 | 1840.59 | 2042.83 | 84.64 | 89.84 |
| Nov-21 | 66.342 | 64.169 | 2.1161 | 3.19 | 0.0568 | 0.086 | 14752112 | 14.2904043 | 8249.029 | 9155.450 | 0.2224 | 1834.29 | 2035.85 | 91.16 | 92.20 |
| Dec-21 | 43.469 | 41.943 | 1.4554 | 3.35 | 0.0706 | 0.162 | 9240886 | 8.9820798 | 8248.476 | 9154.864 | 0.2126 | 1753.51 | 1946.19 | 58.00 | 58.33 |
| Jan-22 | 53.848 | 52.113 | 1.7218 | 3.20 | 0.0802 | 0.149 | 11985862 | 11.9858620 | 8240.931 | 9146.632 | 0.2226 | 1834.32 | 2035.92 | 72.04 | 73.42 |
| Feb-22 | 55.903 | 53.884 | 1.9579 | 3.50 | 0.0611 | 0.109 | 12273054 | 11.9246073 | 8245.370 | 9151.591 | 0.2195 | 1810.20 | 2009.16 | 83.94 | 85.67 |
| Mar-22 | 65.904 | 63.499 | 2.3711 | 3.60 | 0.0339 | 0.051 | 14237721 | 13.8500220 | 8255.014 | 9161.800 | 0.2160 | 1783.39 | 1979.29 | 88.68 | 89.86 |
| TOTAL/ AVERAGE | 717.962 | 693.024 | 24.4268 | 3.40 | 0.618 | 0.089 | 158816917 | 154.0982375 | 8250.367 | 9156.567 | 0.2212 | 1825.024 | 2025.480 | 81.54 | 84.50 |

ED (O&M), PI.

f/ *Barma.*
04/04/2022
Operation incharge, GM (E/M)
TGBPS, NEEPCO, Monarchak.

Barma
03/04/2022
Shift Incharge- (E/M)
TGBPS, Monarchak

TGBPS OUTAGES

| | | 2019-2020 | 2020-2021 | 2021-2022 |
|-----|------------------------|-----------|-----------|-----------|
| GTG | Force Outage in Hrs. | 120.9 | 123.12 | 234.68 |
| | Planned Outage in Hrs. | 5.099 | 621.07 | 439.06 |
| STG | Force Outage in Hrs. | 434.8 | 1426 | 570.3 |
| | Planned Outage in Hrs. | 9.2006 | 739.99 | 684.183 |

OEMs OF CRITICAL PLANT / EQUIPMENT /MACHINERIES AT TGBPP, NEEPCO LTD, MONARCHAK

| Sl. No. | Description of Plant/ Equipment/ Machineries. | Make/Specification |
|---------|--|--|
| 1 | GBC (Gas Booster Compressor) Unit 1 & 2 and their Auxiliaries | <u>Motor:</u> Make: BHEL Frame: 1MA7712-2, applicable standard: IS:325/1996, SCIM, 800KW, 2987RPM, 6.6 KV, 83.0 Amp, No load current: 13 Amp. <u>Compressor:</u> Type: BCL:306, Q: 23015 SM ³ /hr, 11250 RPM, WP: 30.1 kg/cm ² , Max: 37.6 kg/cm ² , Imp: 06 nos. Imp dia: 300 mm |
| | GAS TURBINE SYSTEM | |
| 2 | Gas Turbine System Unit 1 and their Auxiliaries. | Make: GE Type: Frame 6FA, Base Load: 65.42 MW, Compressor: 18 Stage, RPM: 5231, Altitude: 30.9 M from Sea level. Air In: 30.5°C Relative humidity: 85%. |
| 3 | Gas Turbine SFC System | GE Converteam |
| 4 | Gas Turbine AVR System | BHEL |
| 5 | Gas Turbine Generator: 65.42MW Capacity. | BHEL |
| 6 | Gas Turbine Generator Transformers 100MVA | BHEL |
| 7 | Gas Turbine Duct including Diverter Damper & Guillotine Damper | Supplied by BHEL Diverter Damper: Bachmann Industries Ltd. Guillotine Damper: Indira Damper |
| 8 | GT Lube Oil system & Gas Turbine Air intake system. | <u>Lube oil system:</u> BHEL <u>Air Intake system:</u> Camfil |
| 9 | Gas Turbine Co2 Fire Fighting System | Make:Agni Control Pvt. Ltd. |
| 10 | Closed Cooling Water Module Fans & Pumps | BHEL |
| | HRSG SYSTEM | |
| 11 | HRSG (Heat Recovery Steam Generator) | BHEL |
| | HP BFP (Boiler Feed Pumps)Unit 1, 2, 3 | Pump: KSB 101M ³ /hr, H: 1568MWC, 2950 RPM, 608.6 KW, Suction Pr.: 2.307Kg/cm ² . Motor: BHEL |
| | STEAM TURBINE SYSTEM | |
| 12 | Steam Turbine | BHEL Type: HNK/2.8-4, Rating: Base Load: 35.58 MW, Sale Order: MGA1011001 |
| 13 | Steam Turbine Generator | BHEL |
| 14 | Steam Turbine AVR System | BHEL |
| 15 | Pressure parts (Steam Piping & Steam Valves) | BHEL |
| 16 | Steam Turbine Generator | BHEL |
| 17 | Steam Turbine Lube Oil system | <u>BHEL</u> |
| 18 | Steam Turbine Generator Transformers 55MVA | <u>BHEL</u> |

| | | |
|----|---|--|
| 19 | STG Co2 Fire Fighting System. | Make: New Fire Engineering Pvt. Ltd. |
| 20 | CW Pump 1,2,3 | |
| 21 | ACW Pump 1,2 | |
| 22 | CEP (Condensate Extraction pumps) 1 & 2 | |
| | SWITCH YARD & SWITCHGEAR SYSTEM | |
| 23 | 132 KV Switch Yard. 132 KV SF6 Breakers: 9 Nos. Alstom Make & CT, PT, EMVT, LA, CVT | Electro- magnetic Voltage Transformer (at Bus), Capacitive Voltage Transformer (at Line) |
| 24 | SST Unit 1 & 2 (132/6.6 KV): One in service and one Spare. 20MVA each | Make: BHEL |
| 25 | SAT Unit 1,2,3,4 (6.6KV/415V): Two in service and two spares. 2.5MVA each | Make: BHEL |
| 26 | 132 KV, 11 KV, 6.6 KV, 415 V Switchgear Systems | |
| 27 | Cable Galleries | |
| 28 | 1010 KVA EDG | Cummins engine, Generator: Stamford and overall make: Jackson |
| | COOLING TOWER SYSTEM | |
| 29 | Cooling Tower and CT Fans 1,2,3,4,5,6 | <u>Hamman Shriram</u> |
| 30 | WATER SYSTEM | |
| 31 | Intake Water Pump Unit 1,2 | BHEL |
| 32 | Raw Water Reservoir | |
| 33 | HRSCC Unit 1 & 2 | |
| 34 | DM Plant | |
| | CONTROL SYSTEM | |
| 35 | Mark-VI e for Gas Turbine, CDM System | |
| 36 | Max-DNA for Steam Turbine | |
| | AIR COMPRESSOR SYSTEM | |
| 37 | IAPA & NITROGEN SYSTEM, Compressor 1,2,3 | IngersollRand |
| 38 | Gas Scrubber Unit & entire pipelines system | <u>Scrubber make: Grand Prix</u> |
| 39 | Water Pipelines from Intake to TGBPP | <u>BHEL</u> |
| 40 | Transformer at Intake: 11/0.415 KV. Transformer at TGBPP: 6.6/11KV substation for Intake Power supply, 11 KV Transmission Lines. | |
| | FIRE PROTECTION SYSTEM | |
| 41 | Pressurized Hydrant system | Supplied by BHEL Vendor: Thermo- System |
| 42 | Automatic HVW Spray System | -do- |
| 43 | Automatic MVW Spray System | -do- |
| 44 | Fire Alarm and Detection System | -do- |
| 45 | Plant Emergency AC & DC Power supply System, Battery Chargers/ Inverters etc. | BHEL |
| 46 | Clarified Water Tank | BHEL |

DC back up facility

- For switchyard control and protection system **220 Volt DC/ 250 AH** charger and battery back-up system.
- For PLCC power supply **48 Volt DC/ 150 AH** charger and battery back-up system.
- For Station HT and LT panels control and protection power **supply 220 Volt DC/ 550 AH** charger and battery backup system.
- For Gas Turbine emergency drives and control system power supply **125 Volt DC/ 85 AH and 125 Volt DC/170 AH** charger and battery back-up system.
- For UPS system for control panels, HMI, etc. power supply **390 Volt DC / 362 AH UPS battery back-up system**

Transmission line (132 KV)

- **Line 1 and 2 (Monarchak to Rabindranagar) Double Circuit Line, 2.6 KM**
- **Line 3 (Monarchak To Rokhia) 28.96 KM**
- **Line 4 (Monarchak to Banduar) 41.45 kM**

FIRST ANGLE PROJECTION

(ALL DIMENSIONS ARE IN mm)

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY

SIGN. AND DATE
REF. DRG. NO.
COMPUTER FILE NAME

INVENTORY NO

BHEL DRAWING NO.
OF
SHT. 11

DRIVE CONTROL PHILOSOPHY



नॉर्थ ईस्टर्न इलैक्ट्रिक पावर कॉरपोरेशन लिमिटेड
भारत सरकार का उपक्रम
NORTH EASTERN ELECTRIC POWER CORPORATION LTD.
(A GOVERNMENT OF INDIA ENTERPRISE)

त्रिपुरा गैस आधारित सी सी विद्युत परियोजना
त्रिपुरा
TRIPURA GAS BASED CC POWER PROJECT
(TRIPURA)



DESEIN PRIVATE LTD., NEW DELHI



BHARAT HEAVY ELECTRICALS LTD.
HYDERABAD

| | NAME | SIGN. | DATE | NO. OF VAR. |
|-------|--------------|-------|----------|-------------|
| DRN. | GANESH KUMAR | -SD- | 04.08.11 | |
| CHD. | GANESH KUMAR | -SD- | 04.08.11 | -N.A.- |
| APPD. | PRAKASH | -SD- | 04.08.11 | |

DEPT.
PE&SD
CODE
450UNTOL. DIMS.
GR.
G/M/F

SCALE

WEIGHT (KG)

REF. TO ASSY. DRG.

ITEM NO.

NO. OF ITEMS

-N.A.-

-N.A.-

-N.A.-

| REV. | DATE | ALTERED | REV. | DATE | ALTERED | REV. | DATE | ALTERED | REV. | DATE | ALTERED |
|------|------|------------|------|--|------------|------|---|------------|------|------|------------|
| | | CHD./ISSD. | | | CHD./ISSD. | | | CHD./ISSD. | | | CHD./ISSD. |
| | | APPD. | 02 | 16.06.12 | APPD. | 01 | 25.01.12 | APPD. | | | APPD. |
| ZONE | | | ZONE | REVISED AS PER NEEPCO COMMENTS DATED 26.04.12 | | ZONE | REVISED AS PER NEEPCO COMMENTS DATED 30.11.11. | | | | |

BHEL'S CONSULTANT:
TRACTEBEL Engineering
SDF SVS
TRACTEBEL Engineering pvt. Ltd.
NEW DELHI

TITLE
DRIVE CONTROL
PHILOSOPHY


CARD
CODE
N.A.


DRAWING NO.
4-381-21-02883


REV.
02


SHT. No 1


NO. OF SHT. 11


|  BHEL Consultant TRACTEBEL Engineering <i>GDF SUEZ</i> | Project: 1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD DRIVE CONTROL PHILOSOPHY | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date: 16.06.12 | | | |
|---|--|------------|----------------|------------|---|----------------|------------|-----------------------------------|
| Type of Drive | Local Control Station | | Valve Actuator | | DCS HMI (Control Room) | | Switchgear | |
| | Control | Indication | Control | Indication | Control | Indication | Control | Indication |
| HT Uni-directional Drives | Start PB(Green) | | | | Start Command | Run --- Red | Stop PB | Run --- Red |
| | Stop PB(Red) (lockable) | | | | Stop Command | Stop --- Green | | Stop --- Green |
| | L/R Selection | | | | A/M Selection | Trip --- Amber | | Trip --- Amber |
| | | | | | | RTS-Yellow | | Spring Charged - Blue |
| | | | | | | | | Breaker Test Position - White |
| | | | | | | | | Breaker Service Position - Yellow |
| | | | | | | | | Trip Circuit Healthy - Clear |
| | | | | | | | | DC Supply Healthy - Clear |
| | | | | | | Motor Current | | Ammeter [#] |
| LT Uni-directional Drives | Start PB(Green) | | | | Start Command | Run --- Red | Stop PB | Run --- Red |
| | Stop PB(Red) (lockable) | | | | Stop Command | Stop --- Green | | Stop --- Green |
| | L/R Selection | | | | A/M Selection | Trip --- Amber | | Trip --- Amber |
| | | | | | | RTS-Yellow | | |
| | | | | | | | | Spring Charged - Blue |
| | | | | | | | | Breaker Test Position - White |
| | | | | | | | | Breaker Service Position - Yellow |
| | | | | | | | | Trip Circuit Healthy - Clear |
| | | | | | | | | DC Supply Healthy - Clear |
| | | | | | | Motor Current | | Ammeter [#] |


| | | | | | | | | |
|--|---|-------|-----------|----------|-----------------|-----------------------------|--|--------------------------------|
|  BHEL Consultant TRACTEBEL Engineering GDF 3VEZ | Project: 1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD DRIVE CONTROL PHILOSOPHY | | | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date: 16.06.12 | |
| MOV's | | | Open PB | Open | Open Command | Open --- Red | | |
| | | | Close PB | Close | Close Command | Close --- Green | | |
| | | | Stop PB | | A/M Selection | RTS---Yellow | | |
| | | | L/R SS | | | TS Open---Red with flash | | |
| | | | | | | TS Close---Green with flash | | |
| MOV's with Inching Operation | | | Open PB | Open | Open Command | Open --- Red | | |
| | | | Close PB | Close | Close Command | Close --- Green | | |
| | | | Stop PB | | | RTS --- Yellow | | |
| | | | L/R SS | | | Valve Position | | |
| | | | Handwheel | | | | | |
| Solenoid Operated Valves (SOVs) | | | | | A/M Selection | Open --- Red | | |
| | | | | | Open Comm | Close --- Green | | |
| | Manual Reset* | | | | Close Comm | | | |
| Analog Drives (Pneumatic Control Valves) | | | Handwheel | Position | | Position | | |
| | | | | | Regulation(A/M) | Process Value | | |
| | | | | | | | | |
| | | | | | | | | |
| 6.6 kv Incomer Breaker | | | | | | ON --- Red | | ON --- Red |
| | | | | | CLOSE Command | OFF --- Green | | OFF --- Green |
| | | | | | TRIP Command | Trip --- Amber | | Trip --- Amber |
| | | | | | | RTS-Yellow | | Spring Charged --- Blue |
| | | | | | | Incomer Current(R,Y,B) | | Test Position --- White |
| | | | | | | Incomer Voltage(R,Y,B) | | Service Position---Yellow |
| | | | | | | Incomer Power | | Trip Circuit Healthy --- Clear |
| | | | | | | Incomer Reactive Power | | DC Supply Healthy --- Clear |
| 6.6 kv Bus Coupler | | | | | | ON --- Red | | Same as 6.6 kv Incomer Breaker |
| | | | | | CLOSE Command | OFF --- Green | | |
| | | | | | TRIP Command | Trip --- Amber | | |
| | | | | | | RTS-Yellow | | |
| | | | | | | Bus Voltage(R,Y,B) | | |


| | | | | | | | | |
|--|--|-------|-------|-------|---------------|--------------------------------|--|--------------------------------|
|  BHEL Consultant TRACTEBEL Engineering GDF SUEZ | Project: 1x 100 MW NEEPCO Combined Cycle Power Project, Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD DRIVE CONTROL PHILOSOPHY | | | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date: 16.06.12 | |
| 6.6 kv Outgoing Feeder | | | | | | ON --- Red | | Same as 6.6 kv Incomer Breaker |
| | | | | | CLOSE Command | OFF --- Green | | |
| | | | | | TRIP Command | Trip --- Amber | | |
| | | | | | | RTS-Yellow | | |
| | | | | | | Outgoing feeder Current(R,Y,B) | | |
| 415V PMCC Incomer Breaker | | | | | | ON --- Red | | Same as 6.6 kv Incomer Breaker |
| | | | | | CLOSE Command | OFF --- Green | | |
| | | | | | TRIP Command | Trip --- Amber | | |
| | | | | | | RTS-Yellow | | |
| | | | | | | Incomer Current(R,Y,B) | | |
| 415V PMCC Bus Coupler | | | | | | ON --- Red | | Same as 6.6 kv Incomer Breaker |
| | | | | | CLOSE Command | OFF --- Green | | |
| | | | | | TRIP Command | Trip --- Amber | | |
| | | | | | | RTS-Yellow | | |
| 415V PMCC Outgoing Feeder | | | | | | ON --- Red | | Same as 6.6 kv Incomer Breaker |
| | | | | | CLOSE Command | OFF --- Green | | |
| | | | | | TRIP Command | Trip --- Amber | | |
| 415V MCC Incomer Breaker | | | | | | RTS-Yellow | | Same as 6.6 kv Incomer Breaker |
| | | | | | | Incomer Current(R,Y,B) | | |
| | | | | | | Incomer Voltage(R,Y,B) | | |
| 415V MCC Bus Coupler | | | | | | Incomer Power | | Same as 6.6 kv Incomer Breaker |
| | | | | | | Bus Voltage(R,Y,B) | | |


| | | | | | |
|---|--|--|------|-----|--|
|  BHEL Consultant TRACTEBEL Engineering <i>GDF SUEZ</i> | <p align="center">Project: 1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD</p> <p align="center"><u>DRIVE CONTROL PHILOSOPHY</u></p> | <p align="right">DOC. NO: 4-381-21-02883 Rev. no: 02 Date: 16.06.12</p> | | | |
| <p>LEGEND:</p> <p>PB --- Push Button SS --- Selector Switch L/R --- Local /Remote selection A/M --- Auto/Manual Selection MV--- Main Valve IBV--- Integral Bypass Valve IPR--- Interposing Relay NO--- Normally Open (make to alarm) NC--- Normally Close (break to alarm) RTS--- Ready to Start NRTS--- Not in Ready to Start R --- Redundant NR --- Non-Redundant CV --- Control Valve SOV --- Solenoid Valve XL --- Drive feed back HS --- Drive Command NA--- Not Applicable TS-----Torque Switch</p> <p>NOTES:</p> | <p align="center">Tag Numbering Philosophy :</p> <table border="1" data-bbox="1024 375 1438 402"> <tr> <td>XL</td> <td>xxxx</td> <td>RUN</td> </tr> </table> <p>FeedbackS (DI's) XL Commands (DO's) HS (Analog(motor) current) AI (Position feedback) ZI (Position Indication) PI (Psn) PI (Analog Voltage) AV (Analog Power) AP (Analog Energy) AE (Analog Reactive Power) ARP</p> <p align="center">Drive Tag No</p> | XL | xxxx | RUN | <p>RUN : Run Indi TRP: Trip Indi RTS: Ready to start STP: STOP Indication/Command STR: START Command AM: Auto/Manual OPN: Open Indication/Command CLS: Close Indication/Command R: Current/Voltage for R-phase Y: Current/Voltage for Y-phase B: Current/Voltage for B-phase</p> <p>1 This control philosophy is applicable for Power block drives only. This is not applicable for Soot blower drives 2 All MOVs are integral starter type. Open and Close indication of all types of MOVs shall be provided in respective MCCs of Valves 3 # - Ammeter will be provided for motors rated above 30 KW in LCS & MCC, and the corresponding current signals shall be wired to DCS. 4 Drives will be considered as ready to start (RTS) when the following conditions are met a. Stop PB in MCC or in LCS/Actuator not pressed. b. MCC/Actuator power supply is healthy. c. Remote operation is selected. e. All permissives and interlocks are satisfied.. For contact wiring, break to alarm philosophy shall be used for tripping circuit. 5 Isolators are not considered for AI, AO and DI as the isolation facility is already available on board in the I/O cards. 6 Barriers for AI, AO, DI and DO will be provided for hazardous area signals only. 7 Relay Contact-----NC for trip signal, NO for other signals 8 Interogation voltage for MCC, MOV's feedback signal and other potential free contacts shall be 24 V DC from DCS System. 9 Interogation voltage for DCS start/stop cmd to MCC should be 230 V AC from MCC control circuit. 10 Interogation voltage for MOV actuator's cmd should be 24 V DC from actuator. 11 SOVs will be operating with 24 V DC and all are single coils SOVs. 12 MCC & MOV outputs from DCS shall be routed through Interposing relays. 13 All Interposing relays shall have 4 NO,4 NC contacts. All IPRs shall be part of DCS 14 BHEL will use either 6 pair or 12 pair overall shielded signal cables as required for connecting signals from field/MCC etc to DCS. 15 MOV DI & DO signals are clubbed in multipair cable as the voltage levels are same(i.e 24V DC) 16 Energy signal shall be obtained from Power signal by multiplying with time in DCS 17 IPR Contact rating shall be suitable for breaker closing coil & tripping coil current requirements.</p> |
| XL | xxxx | RUN | | | |


|  TRACTEBEL Engineering <small>GDF SVEZ</small> | | Project: 1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD <u>DRIVE CONTROL PHILOSOPHY</u> | | | | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date: 16.06.12 | |
|--|------------|---|-----------------------|---------------|--------------------|--------------------------------|---------------------|--------------|---|-----|
| S No | Signal Tag | Signal Description | Type of I/O w.r.t DCS | Signal Source | Signal Destination | Contact Type before activation | I/O card Redundancy | IPR/ Barrier | Remarks | Rev |
| I/Os for HT Uni-directional Drives | | | | | | | | | | |
| 1 | XLxxxxRUN | Run Indi | Hard DI | MCC | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxSTP | Stop Indi | Hard DI | MCC | DCS | NC | NR | No | | 00 |
| 3 | XLxxxxTRP | Trip Indi | Hard DI | MCC | DCS | NC | NR | No | | 00 |
| 4 | XLxxxxRTS | RTS Indi | Hard DI | MCC | DCS | NO | NR | No | | 00 |
| 5 | HSxxxxAM | A/M Sel | Soft DO | DCS HMI | DCS | NA | NA | No | | 00 |
| 6 | HSxxxxSTR | Start Cmd | Hard DO | DCS | MCC | NO | R | Y | Momentary contact | 00 |
| 7 | HSxxxxSTP | Stop Cmd | Hard DO | DCS | MCC | NO | R | Y | Momentary contact | 00 |
| 8 | AIxxxx | Motor current | Hard AI | SWGR | DCS | 4-20mA | NR | NA | Note-3 | 00 |
| I/Os for LT Uni-directional Drives | | | | | | | | | | |
| 1 | XLxxxxRUN | Run Indi | Hard DI | MCC | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxSTP | Stop Indi | Hard DI | MCC | DCS | NC | NR | No | | 00 |
| 3 | XLxxxxTRP | Trp Indi | Hard DI | MCC | DCS | NC | NR | No | | 00 |
| 4 | XLxxxxRTS | RTS Indi | Hard DI | MCC | DCS | NO | NR | No | | 00 |
| 5 | HSxxxxAM | A/M Sel | Soft DO | DCS HMI | DCS | NA | NA | No | | 00 |
| 6 | HSxxxxSTR | Start Cmd | Hard DO | DCS | MCC | NO | R | Y | Momentary contact | 01 |
| 7 | HSxxxxSTP | Stop Cmd | Hard DO | DCS | MCC | NO | R | Y | Momentary contact | 01 |
| 8 | AIxxxx | Motor current | Hard AI | SWGR | DCS | 4-20mA | NR | NA | Note-3 | 00 |
| I/Os for MOVs | | | | | | | | | | |
| 1 | XLxxxxOPN | Opn Indi | Hard DI | Actuator | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxCLS | Cls Indi | Hard DI | Actuator | DCS | NO | NR | No | | 00 |
| 3 | XLxxxxRTS | RTS Indi | Hard DI | Actuator | DCS | NO | NR | No | This i/p consists of L/R selection. | 00 |
| 4 | HSxxxxOPN | Open Cmd | Hard DO | DCS | Actuator | NO | NR | No | Momentary contact | 00 |
| 5 | HSxxxxCLS | Close Cmd | Hard DO | DCS | Actuator | NO | NR | No | Momentary contact | 00 |

|  TRACTEBEL Engineering <small>GDF SVEZ</small> | | Project:1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD <u>DRIVE CONTROL PHILOSOPHY</u> | | | | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date:16.06.12 | |
|--|---------------|--|-----------------------|---------------|--------------------|--------------------------------|---------------------|--------------|--|-----|
| S No | Signal Tag | Signal Description | Type of I/O w.r.t DCS | Signal Source | Signal Destination | Contact Type before activation | I/O card Redundancy | IPR/ Barrier | Remarks | Rev |
| 6 | HSxxxxAM | A/M Sel | Soft DO | DCS HMI | DCS | NA | NA | No | Wherever Applicable. | 00 |
| 7 | HSxxxxSTP | Stop Cmd | Soft DO | DCS HMI | DCS | NA | NA | No | | 01 |
| I/Os for MOVs with inching type | | | | | | | | | | |
| 1 | XLxxxxOPN | Opn Indi | Hard DI | Actuator | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxCLS | Cls Indi | Hard DI | Actuator | DCS | NO | NR | No | | 00 |
| 3 | XLxxxxRTS | RTS Indi | Hard DI | Actuator | DCS | NO | NR | No | | 00 |
| 4 | HSxxxxOPN | Open Cmd | Hard DO | DCS | Actuator | NO | NR | No | Momentory | 00 |
| 5 | HSxxxxCLS | Close Cmd | Hard DO | DCS | Actuator | NO | NR | No | Momentory | 00 |
| 6 | HSxxxxAM | A/M Sel | Soft DO | DCS HMI | DCS | NA | NA | No | Wherever Applicable. | 00 |
| 7 | ZIxxxx | Valve position | Hard AI | Actuator | DCS | 4-20mA | NR | NA | | 00 |
| 8 | HSxxxxSTP | Stop Cmd | Soft DO | DCS HMI | DCS | NA | NA | No | | 01 |
| I/Os for Solenoid Operated Valves | | | | | | | | | | |
| 1 | XLxxxxOPN | Opn Indi | Hard DI | SOV | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxCLS | Cls Indi | Hard DI | SOV | DCS | NO | NR | No | | 00 |
| 3 | HSxxxxOPN/CLS | Open/Close Cmd | Hard DO | DCS | SOV | NO | NR | Y | | 00 |
| 4 | HSxxxxAM | A/M Sel | Soft DO | DCS HMI | DCS | NA | NA | No | Wherever Applicable. | 00 |
| I/Os for Analog Drives | | | | | | | | | | |
| 1 | ZIxxxx | Position feedback | Hard AI | CV | DCS | 4-20mA | NR | NA | Wherever Applicable | 00 |
| 2 | XIxxxx | Process Value | Hard AI | Field | DCS | 4-20mA | NR | NA | | 00 |
| 3 | XYxxxx | Psn | Hard AO | DCS | CV | 4-20mA | R | NA | | 00 |

|  TRACTEBEL Engineering <small>GDF SUEZ</small> | | Project:1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD <u>DRIVE CONTROL PHILOSOPHY</u> | | | | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date:16.06.12 | |
|--|------------|--|-----------------------|---------------|--------------------|--------------------------------|---------------------|--------------|--|-----|
| S No | Signal Tag | Signal Description | Type of I/O w.r.t DCS | Signal Source | Signal Destination | Contact Type before activation | I/O card Redundancy | IPR/ Barrier | Remarks | Rev |
| I/Os for 6.6 kv Incoming & Tie Breakers | | | | | | | | | | |
| 1 | XLxxxxON | ON Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxOFF | OFF Indi | Hard DI | SWGR | DCS | NC | NR | No | | 00 |
| 3 | XLxxxxTRP | TRIP Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 4 | XLxxxxRTS | RTS Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 5 | HSxxxxCLS | CLOSE Cmd(on dead bus) | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 6 | HSxxxxTRP | TRIP Cmd | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 7 | AIxxxxR | current for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 8 | AIxxxxY | current for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 9 | AIxxxxB | current for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 10 | AVxxxxR | voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 11 | AVxxxxY | voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 12 | AVxxxxB | voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 13 | APxxxx | Power | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 14 | AExxxx | Energy | - | - | - | - | - | - | Refer Note (17) | 00 |
| 15 | ARPxxxx | Reactive Power | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| I/Os for 6.6 kv Bus Coupler Breakers | | | | | | | | | | |
| 1 | XLxxxxON | ON Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxOFF | OFF Indi | Hard DI | SWGR | DCS | NC | NR | No | | 00 |
| 3 | XLxxxxTRP | TRIP Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 4 | XLxxxxRTS | RTS Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 5 | HSxxxxCLS | CLS Cmd(on dead bus) | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 6 | HSxxxxTRP | TRIP Cmd | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 7 | AVxxxxAR | Bus-A voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |

|  TRACTEBEL Engineering <small>GDF SVEZ</small> | | Project:1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD <u>DRIVE CONTROL PHILOSOPHY</u> | | | | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date:16.06.12 | |
|--|------------|--|-----------------------|---------------|--------------------|--------------------------------|---------------------|--------------|--|-----|
| S No | Signal Tag | Signal Description | Type of I/O w.r.t DCS | Signal Source | Signal Destination | Contact Type before activation | I/O card Redundancy | IPR/ Barrier | Remarks | Rev |
| 8 | AVxxxxAY | Bus-A voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 9 | AVxxxxAB | Bus-A voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 10 | AVxxxxBR | Bus-B voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 11 | AVxxxxBY | Bus-B voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 12 | AVxxxxBB | Bus-B voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| I/Os for 6.6 kv Outgoing (Non-motors) Breakers | | | | | | | | | | |
| 1 | XLxxxxON | ON Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxOFF | OFF Indi | Hard DI | SWGR | DCS | NC | NR | No | | 00 |
| 3 | XLxxxxTRP | TRIP Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 4 | XLxxxxRTS | RTS Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 5 | HSxxxxCLS | CLS Cmd | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 6 | HSxxxxTRP | TRIP Cmd | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 7 | AIxxxxR | current for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 8 | AIxxxxY | current for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 9 | AIxxxxB | current for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 10 | APxxxx | Power | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| I/Os for 415V PMCC Incoming Breakers | | | | | | | | | | |
| 1 | XLxxxxON | ON Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxOFF | OFF Indi | Hard DI | SWGR | DCS | NC | NR | No | | 00 |
| 3 | XLxxxxTRP | TRIP Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 4 | XLxxxxRTS | RTS Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 5 | HSxxxxCLS | CLS Cmd(on dead bus) | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 6 | HSxxxxTRP | TRIP Cmd | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |

|  TRACTEBEL Engineering <small>GDF SVEZ</small> | | Project:1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD <u>DRIVE CONTROL PHILOSOPHY</u> | | | | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date:16.06.12 | |
|--|------------|--|-----------------------|---------------|--------------------|--------------------------------|---------------------|--------------|--|-----|
| S No | Signal Tag | Signal Description | Type of I/O w.r.t DCS | Signal Source | Signal Destination | Contact Type before activation | I/O card Redundancy | IPR/ Barrier | Remarks | Rev |
| 7 | AIxxxxR | current for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 8 | AIxxxxY | current for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 9 | AIxxxxB | current for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 10 | AVxxxxR | voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 11 | AVxxxxY | voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 12 | AVxxxxB | voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 13 | APxxxx | Power | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| I/Os for 415V PMCC Bus Coupler Breakers | | | | | | | | | | |
| 1 | XLxxxxON | ON Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxOFF | OFF Indi | Hard DI | SWGR | DCS | NC | NR | No | | 00 |
| 3 | XLxxxxTRP | TRIP Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 4 | XLxxxxRTS | RTS Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 5 | HSxxxxCLS | CLS Cmd(on dead bus) | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 6 | HSxxxxTRP | TRIP Cmd | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 7 | AVxxxxAR | Bus-A voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 8 | AVxxxxAY | Bus-A voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 9 | AVxxxxAB | Bus-A voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 10 | AVxxxxBR | Bus-B voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 11 | AVxxxxBY | Bus-B voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 12 | AVxxxxBB | Bus-B voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 13 | AVxxxxCR | Bus-C voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | If applicable | 00 |
| 14 | AVxxxxCY | Bus-C voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | If applicable | 00 |
| 15 | AVxxxxCB | Bus-C voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | If applicable | 00 |

|  TRACTEBEL Engineering <small>GDF SUEZ</small> | | Project: 1x 100 MW NEEPCO Combined Cycle Power Project , Monarchak Customer: M/s NEEPCO, Monarchak, Tripura BHEL - HYDERABAD <u>DRIVE CONTROL PHILOSOPHY</u> | | | | | | | DOC. NO: 4-381-21-02883 Rev. no: 02 Date: 16.06.12 | |
|--|------------|---|-----------------------|---------------|--------------------|--------------------------------|---------------------|--------------|---|-----|
| S No | Signal Tag | Signal Description | Type of I/O w.r.t DCS | Signal Source | Signal Destination | Contact Type before activation | I/O card Redundancy | IPR/ Barrier | Remarks | Rev |
| I/Os for 415V PMCC Outgoing (Non-motors) Breakers | | | | | | | | | | |
| 1 | XLxxxxON | ON Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 2 | XLxxxxOFF | OFF Indi | Hard DI | SWGR | DCS | NC | NR | No | | 00 |
| 3 | XLxxxxTRP | TRIP Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 4 | XLxxxxRTS | RTS Indi | Hard DI | SWGR | DCS | NO | NR | No | | 00 |
| 5 | HSxxxxCLS | CLS Cmd | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| 6 | HSxxxxTRP | TRIP Cmd | Hard DO | DCS | SWGR | NO | NR | Y | Momentary contact, Note (18) | 00 |
| I/Os for 415V MCC Incoming Breakers | | | | | | | | | | |
| 1 | AIxxxxR | current for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 2 | AIxxxxY | current for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 3 | AIxxxxB | current for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 4 | AVxxxxR | voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 5 | AVxxxxY | voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 6 | AVxxxxB | voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 7 | APxxxx | Power | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| I/Os for 415V MCC Bus Coupler Breakers | | | | | | | | | | |
| 1 | AVxxxxAR | Bus-A voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 2 | AVxxxxAY | Bus-A voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 3 | AVxxxxAB | Bus-A voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 4 | AVxxxxBR | Bus-B voltage for R-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 5 | AVxxxxBY | Bus-B voltage for Y-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |
| 6 | AVxxxxBB | Bus-B voltage for B-Phase | Hard AI | SWGR | DCS | 4-20mA | NR | NA | | 00 |

FIRST ANGLE PROJECTION

(ALL DIMENSIONS ARE IN mm)

DRG. NO. 4-38121-02891

SHT. 01 OF 48

DCS LOGIC DIAGRAMS—BOP AREA

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY

COMPUTER FILE NAME

SIGN. AND DATE REF. DRG. NO.

INVENTORY NO

| REV. | DATE | ALTERED |
|------|------|----------|
| | | CHD/APPD |

ZONE

| REV. | DATE | ALTERED |
|------|------|----------|
| | | CHD/APPD |

ZONE

BHEL'S CONSULTANT:

TRACTEBEL Engineering
GDF SVEZ
TRACTEBEL Engineering pvt. ltd.
NEW DELHI

| CATEGORY OF DWG | APPROVAL | INFORMATION | RECORD | REFERENCE | | | | | | | | | | | | | | | | | | |
|---|---------------------------|--|--------------------|------------------------|-------|------|-------------|------|--------|-------------------|----------|--|------|--------|-------------------|----------|--------|-------|---------|-------------------|----------|--|
| | | ✓ | | | | | | | | | | | | | | | | | | | | |
|  नॉर्थ ईस्टर्न इलेक्ट्रिक पावर कॉर्पोरेशन लिमिटेड भारत सरकार का उपक्रम NORTH EASTERN ELECTRIC POWER CORPORATION LTD. (A GOVERNMENT OF INDIA ENTERPRISE) | | | | | | | | | | | | | | | | | | | | | | |
| त्रिपुरा गैस आधारित सी सी विद्युत परियोजना त्रिपुरा TRIPURA GAS BASED CC POWER PROJECT (TRIPURA) | | | | | | | | | | | | | | | | | | | | | | |
| CONSULTANT:  DESEIN PRIVATE LTD., NEW DELHI | | | | | | | | | | | | | | | | | | | | | | |
|  भारत भारी इलेक्ट्रिकल लिमिटेड BHARAT HEAVY ELECTRICALS LTD. HYDERABAD | | <table border="1"> <thead> <tr> <th></th> <th>NAME</th> <th>SIGN.</th> <th>DATE</th> <th>NO. OF VAR.</th> </tr> </thead> <tbody> <tr> <td>DRN.</td> <td>GANESH</td> <td><i>Ap. Ramani</i></td> <td>16.06.12</td> <td></td> </tr> <tr> <td>CHD.</td> <td>GANESH</td> <td><i>Ap. Ramani</i></td> <td>16.06.12</td> <td>-N.A.-</td> </tr> <tr> <td>APPD.</td> <td>PRAKASH</td> <td><i>Ap. Ramani</i></td> <td>16.06.12</td> <td></td> </tr> </tbody> </table> | | NAME | SIGN. | DATE | NO. OF VAR. | DRN. | GANESH | <i>Ap. Ramani</i> | 16.06.12 | | CHD. | GANESH | <i>Ap. Ramani</i> | 16.06.12 | -N.A.- | APPD. | PRAKASH | <i>Ap. Ramani</i> | 16.06.12 | |
| | NAME | SIGN. | DATE | NO. OF VAR. | | | | | | | | | | | | | | | | | | |
| DRN. | GANESH | <i>Ap. Ramani</i> | 16.06.12 | | | | | | | | | | | | | | | | | | | |
| CHD. | GANESH | <i>Ap. Ramani</i> | 16.06.12 | -N.A.- | | | | | | | | | | | | | | | | | | |
| APPD. | PRAKASH | <i>Ap. Ramani</i> | 16.06.12 | | | | | | | | | | | | | | | | | | | |
| DEPT. PEASD CODE 450 | UNTOL. DIMS. GR. G/M/F |  | SCALE | WEIGHT (KG) | | | | | | | | | | | | | | | | | | |
| TITLE DCS LOGIC DIAGRAMS—BOP AREA | | REF. TO ASSY. DRG. -N.A.- | ITEM NO. -N.A.- | NO. OF ITEMS -N.A.- | | | | | | | | | | | | | | | | | | |
| CARD CODE N.A. | | DRAWING NO. 4-38121-02891 | | REV. 00 | | | | | | | | | | | | | | | | | | |
| | | SHT. No 01 | NO. OF SHT. 48 | | | | | | | | | | | | | | | | | | | |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 02 OF 48

INDEX

| SHT NO | DESCRIPTION | REV NO | | | |
|-----------|---------------------------------------|--------|----|----|----|
| | | 00A | 01 | 02 | 03 |
| 1 | TITLE SHEET | X | | | |
| 2 | INDEX | X | | | |
| 3 | LEGEND | X | | | |
| 4 | TECHNICAL NOTES | X | | | |
| 5 | REFERENCE DRAWINGS | X | | | |
| 6 | LOGIC SCHEME - A1 | X | | | |
| 7 | APPLICABLE TAGS FOR SCHEME - A1 | X | | | |
| 8 | LOGIC SCHEME - A2 | X | | | |
| 9 | APPLICABLE TAGS FOR SCHEME - A2 | X | | | |
| 10 | LOGIC SCHEME - A3 | X | | | |
| 11 | APPLICABLE TAGS FOR SCHEME - A3 | X | | | |
| 12 | LOGIC SCHEME - A4 | X | | | |
| 13 | APPLICABLE TAGS FOR SCHEME - A4 | X | | | |
| 14 | LOGIC SCHEME - A5 | X | | | |
| 15 | APPLICABLE TAGS FOR SCHEME - A5 | X | | | |
| 16 | LOGIC SCHEME - A6 | X | | | |
| 17 | APPLICABLE TAGS FOR SCHEME - A6 | X | | | |
| 18 | LOGIC SCHEME - A7 | X | | | |
| 19 | APPLICABLE TAGS FOR SCHEME - A7 | X | | | |
| 20 | LOGIC SCHEME - A8 | X | | | |
| 21 | LOGIC SCHEME - A8A | X | | | |
| 22 | APPLICABLE TAGS FOR SCHEME - A8 & A8A | X | | | |
| 23 | LOGIC SCHEME - A9 | X | | | |
| 24 | APPLICABLE TAGS FOR SCHEME - A9 | X | | | |
| 25 | LOGIC SCHEME - A10 | X | | | |
| 26 | APPLICABLE TAGS FOR SCHEME - A10 | X | | | |
| 27 | LOGIC SCHEME - A11 | X | | | |

| SHT NO | DESCRIPTION | REV NO | | | |
|-----------|---|--------|----|----|----|
| | | 00A | 01 | 02 | 03 |
| 28 | LOGIC SCHEME - B1 | X | | | |
| 29 | APPLICABLE TAGS FOR SCHEME - B1 | X | | | |
| 30 | LOGIC SCHEME - B2A | X | | | |
| 31 | LOGIC SCHEME - B2B | X | | | |
| 32 | APPLICABLE TAGS FOR SCHEME - B2A & B2B | X | | | |
| 33 | LOGIC SCHEME - B3 | X | | | |
| 34 | APPLICABLE TAGS FOR SCHEME - B3 | X | | | |
| 35 | LOGIC SCHEME - B4 | X | | | |
| 36 | APPLICABLE TAGS FOR SCHEME - B4 | X | | | |
| 37 | LOGIC SCHEME - B5 | X | | | |
| 38 | APPLICABLE TAGS FOR SCHEME - B5 | X | | | |
| 39 | LOGIC SCHEME - B6 | X | | | |
| 40 | APPLICABLE TAGS FOR SCHEME - B6 | X | | | |
| 41 | LOGIC SCHEME - C1 | X | | | |
| 42 | LOGIC SCHEME - C2 | X | | | |
| 43 | LOGIC SCHEME - C3 | X | | | |
| 44 | LOGIC SCHEME - C4 | X | | | |
| 45 | LOGIC SCHEME - C5 | X | | | |
| 46 | LOGIC SCHEME - C6 | X | | | |
| 47 | LOGIC SCHEME - C7 | X | | | |
| 48 | APPLICABLE TAGS FOR SCHEME - C1,C2,C3....C7 | X | | | |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 03 OF 48

LEGEND

| | | | |
|---|---|---|-------------------------------------|
| | LOGIC OUTPUT "Q" EXISTS IF ATLEAST ONE OF THE INPUTS EXISTS. | | ON DELAY OF x MINUTES |
| | LOGIC OUTPUT "Q" EXISTS IF AND ONLY IF ALL LOGIC INPUTS EXIST. | | ANALOG TO DIGITAL SIGNAL CONVERSION |
| | LOGIC OUTPUT "Q" EXISTS AS SOON AS INPUT "A" EXISTS, "Q" CONTINUES TO EXIST, REGARDLESS OF THE SUBSEQUENT STATUS OF "A" UNTIL THE MEMORY IS TERMINATED BY LOGIC INPUT "B", EXISTING "Q" REMAINS TERMINATED REGARDLESS OF THE SUBSEQUENT STATE OF "B" UNTIL "A" CAUSES THE MEMORY TO BE SET. S = SET MEMORY R = RESET MEMORY | | 2 OUT OF 3 SIGNAL SELECTOR |
| | LOGIC OUTPUT "B" EXISTS IF AND ONLY IF LOGIC INPUT "A" DOESN'T EXIST. | | 1 OUT OF 2 SIGNAL SELECTOR |
| | SOFT ALARM TO HMI/DCS | | |
| HMI : HUMAN MACHINE INTERFACE MCC : MOTOR CONTROL CENTER PMP : PUMP ACT : ACTUATOR LCP : LOCAL CONTROL PANEL 1W + 1S : 1 WORKING + 1 STANDBY | | XLxxxxxxRUN : FEED BACK SIGNALS DCS RECIEVED FROM MCC XLxxxxxxTRP : FEED BACK SIGNALS DCS RECIEVED FROM MCC XLxxxxxxRTS : FEED BACK SIGNALS DCS RECIEVED FROM MCC XLxxxxxxOPN : FEED BACK SIGNALS DCS RECIEVED FROM ACT/LCP XLxxxxxxCLS : FEED BACK SIGNALS DCS RECIEVED FROM ACT/LCP HSxxxxxxSTR : COMMAND SIGNALS FROM DCS SENT TO MCC HSxxxxxxSTP : COMMAND SIGNALS FROM DCS SENT TO MCC HSxxxxxxOPN : COMMAND SIGNALS FROM DCS SENT TO ACT HSxxxxxxCLS : COMMAND SIGNALS FROM DCS SENT TO ACT | |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 04 OF 48

TECHNICAL NOTES:

1. COMMON LOGIC DIAGRAMS FOR HT, LT, MOV AND ON-OFF DRIVES ARE DRAWN SEPERATELY AND INDICATED AS A1, A2, ... A11, B1,.....B6, C1....C7.
2. IN THE EACH SCHEME RELEVANT TAG NO'S ARE INDICATED SEPARATELY IN "APPLICABLE TAGS FOR SCHEME-A1, ETC".
3. TYPICAL EXAMPLE FOR TAGS SHEET PHILOSOPHY TO BE FOLLOWED:
 - a) For S.no. 1, IN SCHEME A1, REPLACE PMP1 WITH P6901, PMP2 WITH P6902, PROCESS1 WITH LI6939, AND SET PINTS AS INDICATED IN "APPLICABLE TAGS" SHEET.
 - b) SIMILARLY FOR ALL OTHERS CASES, THIS PHILOSOPHY HAS TO BE FOLLOWED.
4. IN AUTO/MANUAL SIGNAL, AUTO = 1 (I.E. HEALTHY SIGNAL) MANUAL = 0.
5. 2 OUT OF 3 SELECTION: AVERAGE VALUE WILL BE SELECTED IN CASE ALL TRANSMITTERS ARE HEALTHY OR ANY TWO OF THE TRANSMITTERS ARE HEALTHY. AUTOMATIC CHANGEOVER TO THIRD TRANSMITTER WILL BE DONE IF TWO TRANSMITTERS ARE FAILED. ALSO MANUAL SELECTION OF ANY TRANSMITTER WILL ALSO BE AVAILABLE. OR VALUE WILL BE SELECTED BASED 2 OUT OF 3 VOTING IN CASE ALL TRANSMITTERS ARE HEALTHY.
- 6 THE SET POINT AS INDICATED IS TENTATIVE.
FINAL SET POINTS WILL BE ADJUSTED DURING COMMISSIONING OF THE SYSTEM.



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 05 OF 48

REFERENCE DRG'S


| S. NO | LIST OF P & ID's CONSIDERED | P & ID NO. | NO. OF SHEETS | Rev. No. |
|-------|--|----------------|---------------|----------|
| | | BHEL DRG NO: | | |
| 1 | NUMBERING PHILOSOPHY | 2-38101-02788 | 1 | 00 |
| 2 | STANDARD LEGEND FOR PROCESS & INSTRUMENTATION DIAGRAM | 2-38101-02789 | 1 | 00 |
| 3 | P&ID FOR OFF-BASE FUEL GAS SYSTEM FOR GT | 1-38101-04110 | 3 | 01 |
| 4 | P&ID FOR HP STEAM SYSTEM | 1-38101-04104 | 1 | 01 |
| 5 | P & ID FOR IP STEAM SYSTEM | 1-38101-04105 | 1 | 01 |
| 6 | P & ID FOR LP STEAM SYSTEM | 1-38101-04106 | 1 | 01 |
| 7 | P & ID FOR CONDENSATE SYSTEM UPTO GLAND STEAM CONDENSER | 1-38101-04107 | 1 | 01 |
| 8 | P & ID FOR CONDENSATE SYSTEM DOWNSTREAM OF GLAND STEAM CONDENSER UPTO DEAERATOR(UCFT, CPH & DEAERATOR) | 1-38101-04108 | 1 | 01 |
| 9 | P & ID FOR FEED WATER SYSTEM(HP, IP, LP & RECIR) | 1-38101-04109 | 2 | 01 |
| 10 | P & ID FOR CONDENSER COOLING WATER SYSTEM | 1-38101-04355 | 1 | 02 |
| 11 | P & ID FOR AUXILIARY COOLING WATER SYSTEM | 1-38101-04368 | 1 | 01 |
| 12 | P & ID FOR LP DOSING SYSTEM (HYDRAZINE) | 3-38101-03053 | 1 | 01 |
| 13 | P & ID FOR LP DOSING SYSTEM (AMMONIA) | 3-38101-03054 | 1 | 01 |
| 14 | P & ID FOR SERVICE WATER DISTRIBUTION SYSTEM | 3-38101-03080 | 1 | 01 |
| 15 | P & ID FOR POTABLE WATER DISTRIBUTION SYSTEM | 3-38101-03081 | 1 | 01 |
| 16 | P & ID FOR DM WATER DISTRIBUTION SYSTEM | 3-38101-03082 | 1 | 01 |
| 17 | P & ID FOR IA/PA/NITROGEN DISTRIBUTION SYSTEM | 3-38101-03083 | 1 | 01 |
| 18 | P & ID FOR PRE TREATMENT PLANT | 1-381-01-04455 | 2 | 00 |
| 19 | P & ID FOR CLARIFIED WATER SYSTEM | 1-381-01-04456 | 1 | 01 |
| 20 | P & ID FOR DM PLANT | 1-38101-04357 | 4 | 00 |
| 21 | P & ID FOR CLOSED COOLING WATER SYSTEM | 3-38101-03063 | 1 | 02 |
| 22 | FLOW DIAGRAM FOR SLUDGE TREATMENT SYSTEM | 3-38101-03078 | 1 | 00 |
| 23 | P&ID FOR CIRC. WATER CHLORINATION & TREATMENT SYSTEM | 3-38101-04613 | 1 | 00 |
| 24 | SCHEME OF WATER AND STEAM CIRCUIT WITH VALVES, FITTING & INSTRUMENTS-HP CIRCUIT | 0-24-400-80910 | 1 | 01 |
| 25 | SCHEME OF WATER AND STEAM CIRCUIT WITH VALVES, FITTING & INSTRUMENTS-IP & LP CIRCUIT | 0-24-400-80911 | 1 | 01 |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 06 OF 48

LOGIC SCHEME – A1



NOTE:-

* APPLICABLE FOR NOTE NUMBER 3 OF DRIVE CONTROL PHILOSOPHY.



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 07 OF 48

APPLICABLE TAGS FOR SCHEME-A1


| S. No. | PMP1 | PMP2 | PROCESS-1 | Set points Refer Note-6 | | Applicable Scheme | P & ID | LOGIC DESCRIPTION |
|-----------|---------|---------|-----------|----------------------------|-----|----------------------|---------------------|---|
| | TAG NO. | TAG NO. | TAG NO. | SP1 | SP2 | | | |
| 1 | P6901 | P6902 | LI6939 | 70% | 30% | A1 | 1-381-01-04110(3/3) | 1)Auto start on Drain tank level high 2)Auto close on Drain tank level low |
| 2 | P6902 | P6901 | LI6939 | 70% | 30% | A1 | 1-381-01-04110(3/3) | 1)Auto start on Drain tank level high 2)Auto close on Drain tank level low |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 08 OF 48

LOGIC SCHEME – A2



NOTE:-

* APPLICABLE FOR NOTE NUMBER 3 OF DRIVE CONTROL PHILOSOPHY.



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 09 OF 48

APPLICABLE TAGS FOR SCHEME-A2


| S. No. | PMP1 | PMP2 | PROCESS-1 | PROCESS-2 | PROCESS-3 | Set points Refer Note-6 | | | | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|-----------|---------|---------|-----------|-----------|-----------|----------------------------|-----|-----|-----------|----------------------|---------------------|---|
| | TAG NO. | TAG NO. | TAG NO. | TAG NO. | TAG NO. | SP1 | SP2 | SP3 | SP4 | | | |
| 1 | P001A | P001B | LI1603 | GTV1601 | PI1609 | 60% | 70% | 20% | 10 ata | A2 | 1-381-01-04107(1/1) | 1) Start permissive for any CEP on Hotwell-1 level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low or Hotwell-1 level high, 3) Auto trip working pump on Hotwell-1 level low low |
| 2 | P001B | P001A | LI1603 | GTV1602 | PI1609 | 60% | 70% | 20% | 10 ata | A2 | 1-381-01-04107(1/1) | 1) Start permissive for any CEP on Hotwell-2 level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low or Hotwell-2 level high, 3) Auto trip working pump on Hotwell-2 level low low |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 10 OF 48

LOGIC SCHEME – A3






1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 11 OF 48

APPLICABLE TAGS FOR SCHEME-A3

| S. No. | PMP1 | PMP2 | PMP3 | PROCESS-1 | Set points | | | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|-----------|---------|------------|---------|-----------|--------------|-------------|------------|----------------------|---------------------|---|
| | TAG NO. | TAG NO. | TAG NO. | TAG NO. | SP1 | SP2 | SP3 | | | |
| 1 | P003A | P003B | P003C | GTV1801A | 1631 mmWC | 500 mmWC | 120 ATA | A3 | 1-381-01-04109(1/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low 4) Auto trip on Pump or motor temp high high 5) Auto trip on pump vibration hi |
| 2 | P003B | P003A | P003C | GTV1801B | 1631 mmWC | 500 mmWC | 120 ATA | A3 | 1-381-01-04109(1/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low 4) Auto trip on Pump or motor temp high high 5) Auto trip on pump vibration hi |
| 3 | P003C | P003A | P003B | GTV1801C | 1631 mmWC | 500 mmWC | 120 ATA | A3 | 1-381-01-04109(1/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low 4) Auto trip on Pump or motor temp high high 5) Auto trip on pump vibration hi |



Page No. : 12 OF 48

[illegible]




1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 13 OF 48

APPLICABLE TAGS FOR SCHEME-A4

| S. No. | Applicable for PUMP | PROCESS-6 | | S. No. | Applicable for PUMP | PROCESS-6 | |
|--------|---------------------|--|---|--------|---------------------|--|---|
| 1 | P003A | TIP003ABT1 TIP003ABT2 TIPM003ABT1 TIPM003ABT2 TIPM003AWT1 TIPM003AWT2 TIPM003AWT3 TIPM003AWT4 | TIPM003AWT5 TIPM003AWT6 TIPM003AWT7 TIPM003AWT8 TIPM003AWT9 TIPM003AWT10 TIPM003AWT11 TIPM003AWT12 | 6 | P5202C | TIP5202CBT1 TIP5202CBT2 TIPM5202CBT1 TIPM5202CBT2 TIPM5202CWT1 TIPM5202CWT2 TIPM5202CWT3 TIPM5202CWT4 | TIPM5202CWT5 TIPM5202CWT6 TIPM5202CWT7 TIPM5202CWT8 TIPM5202CWT9 TIPM5202CWT10 TIPM5202CWT11 TIPM5202CWT12 |
| 2 | P003B | TIP003BBT1 TIP003BBT2 TIPM003BBT1 TIPM003BBT2 TIPM003BWT1 TIPM003BWT2 TIPM003BWT3 TIPM003BWT4 | TIPM003BWT5 TIPM003BWT6 TIPM003BWT7 TIPM003BWT8 TIPM003BWT9 TIPM003BWT10 TIPM003BWT11 TIPM003BWT12 | 7 | P5301A | TIP5301ABT1 TIP5301ABT2 TIPM5301ABT1 TIPM5301ABT2 TIPM5301AWT1 TIPM5301AWT2 TIPM5301AWT3 TIPM5301AWT4 | TIPM5301AWT5 TIPM5301AWT6 TIPM5301AWT7 TIPM5301AWT8 TIPM5301AWT9 TIPM5301AWT10 TIPM5301AWT11 TIPM5301AWT12 |
| 3 | P003C | OTIP003CBT1 OTIP003CBT2 TIPM003CBT1 TIPM003CBT2 TIPM003CWT1 TIPM003CWT2 TIPM003CWT3 TIPM003CWT4 | TIPM003CWT5 TIPM003CWT6 TIPM003CWT7 TIPM003CWT8 TIPM003CWT9 TIPM003CWT10 TIPM003CWT11 TIPM003CWT12 | 8 | P5301B | TIP5301BBT1 TIP5301BBT2 TIPM5301BBT1 TIPM5301BBT2 TIPM5301BWT1 TIPM5301BWT2 TIPM5301BWT3 TIPM5301BWT4 | TIPM5301BWT5 TIPM5301BWT6 TIPM5301BWT7 TIPM5301BWT8 TIPM5301BWT9 TIPM5301BWT10 TIPM5301BWT11 TIPM5301BWT12 |
| 4 | P5202A | TIP5202ABT1 TIP5202ABT2 TIPM5202ABT1 TIPM5202ABT2 TIPM5202AWT1 TIPM5202AWT2 TIPM5202AWT3 TIPM5202AWT4 | TIPM5202AWT5 TIPM5202AWT6 TIPM5202AWT7 TIPM5202AWT8 TIPM5202AWT9 TIPM5202AWT10 TIPM5202AWT11 TIPM5202AWT12 | | | | |
| 5 | P5202B | TIP5202BBT1 TIP5202BBT2 TIPM5202BBT1 TIPM5202BBT2 TIPM5202BWT1 TIPM5202BWT2 TIPM5202BWT3 TIPM5202BWT4 | TIPM5202BWT5 TIPM5202BWT6 TIPM5202BWT7 TIPM5202BWT8 TIPM5202BWT9 TIPM5202BWT10 TIPM5202BWT11 TIPM5202BWT12 | | | | |



Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 14 OF 48

[illegible]




1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 15 OF 48

APPLICABLE TAGS FOR SCHEME-A5

| S. No. | PMP1 | PMP2 | PROCESS-1 | PROCESS-2 | PROCESS-3 | PROCESS-4 | Set points | | | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|-----------|---------|---------|-----------|-----------|------------|-----------|--------------|-----------|-------------|----------------------|----------------------|--|
| | TAG NO. | TAG NO. | TAG NO. | TAG NO. | TAG NO. | TAG NO. | SP1 | SP2 | SP3 | | | |
| 1 | P004A | P004B | LI1801A | LI1801B | GTV1835A | PI1827 | 1631 mmWC | 30 ATA | 500 mmWC | A5 | 1-381-01-04109 (1/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low |
| 2 | P004B | P004A | LI1801A | LI1801B | GTV1835B | PI1827 | 1631 mmWC | 30 ATA | 500 mmWC | A5 | 1-381-01-04109 (1/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low |
| 3 | P005A | P005B | LI1801A | LI1801B | GTV1871A | PI1852 | 1631 mmWC | 7 ATA | 500 mmWC | A5 | 1-381-01-04109(2/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low |
| 4 | P005B | P005A | LI1801A | LI1801B | GTV1871B | PI1852 | 1631 mmWC | 7 ATA | 500 mmWC | A5 | 1-381-01-04109(2/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low |
| 5 | P006A | P006B | LI1801A | LI1801B | GTV18105A | PI1869 | 1631 mmWC | 7 ATA | 500 mmWC | A5 | 1-381-01-04109(2/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low |
| 6 | P006B | P006A | OLI1801A | OLI1801B | OGTV18105B | PI1869 | 1631 mmWC | 7 ATA | 500 mmWC | A5 | 1-381-01-04109(2/2) | 1) Start permissive for any BFP on DEAE level normal & Suction valve open, 2) Auto start of stand by pump on Discharge pr. Low 3) Auto trip working pump on DEAE level low low |



Page No. : 16 OF 48

[illegible]



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 17 OF 48

APPLICABLE TAGS FOR SCHEME-A6


| S. No. | PMP1 | PROCESS-1 | PROCESS-2 | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|-----------|---------|-----------|-----------|----------------------|---------------------|--|
| | TAG NO. | TAG NO. | TAG NO. | | | |
| 1 | CTF5204 | LAL5246 | VAH5147 | A6 | 1-381-01-04355(1/1) | 1) Auto trip on low oil level in gear box, 2) Auto trip on fan vibration high |
| 2 | CTF5206 | LAL5248 | VAH5149 | A6 | 1-381-01-04355(1/1) | 1) Auto trip on low oil level in gear box, 2) Auto trip on fan vibration high |
| 3 | CTF5208 | LAL5250 | VAH5151 | A6 | 1-381-01-04355(1/1) | 1) Auto trip on low oil level in gear box, 2) Auto trip on fan vibration high |
| 4 | CTF5210 | LAL5252 | VAH5153 | A6 | 1-381-01-04355(1/1) | 1) Auto trip on low oil level in gear box, 2) Auto trip on fan vibration high |
| 5 | CTF5212 | LAL5254 | VAH5155 | A6 | 1-381-01-04355(1/1) | 1) Auto trip on low oil level in gear box, 2) Auto trip on fan vibration high |
| 6 | CTF5214 | LAL5256 | VAH5157 | A6 | 1-381-01-04355(1/1) | 1) Auto trip on low oil level in gear box, 2) Auto trip on fan vibration high |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 18 OF 48

LOGIC SCHEME – A7






1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 19 OF 48


APPLICABLE TAGS FOR SCHEME-A7

| S. No. | PMP1 | PMP2 | PMP3 | PROCESS-1 | PROCESS-2 | PROCESS-3 | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|--------|---------|---------|---------|-----------|-----------|-----------|----------------------|---------------------|--|
| | TAG NO. | TAG NO. | TAG NO. | TAG NO. | TAG NO. | TAG NO. | | | |
| 1 | P5202A | P5202B | P5202C | PSL5208 | RRIS259 | ZT5204 | A7 | 1-381-01-04355(1/1) | 1) Auto start of standby on discharge pressure low 2) Start permissive for any pump on CW sump level Normal & discharge MOV closed & pump not in reverse rotation 3) Auto trip on CW sump level low low 4) Discharge valve 10% open. 5) Winding Temp. and Vibration. |
| 2 | P5202B | P5202C | P5202A | PSL5208 | RRIS260 | ZT5205 | A7 | 1-381-01-04355(1/1) | 1) Auto start of standby on discharge pressure low 2) Start permissive for any pump on CW sump level Normal & discharge MOV closed & pump not in reverse rotation 3) Auto trip on CW sump level low low 4) Discharge valve 10% open. 5) Winding Temp. and Vibration. |
| 3 | P5202C | P5202A | P5202B | PSL5208 | RRIS261 | ZT5206 | A7 | 1-381-01-04355(1/1) | 1) Auto start of standby on discharge pressure low 2) Start permissive for any pump on CW sump level Normal & discharge MOV closed & pump not in reverse rotation 3) Auto trip on CW sump level low low 4) Discharge valve 10% open. 5) Winding Temp. and Vibration. |
| 4 | P5301A | P5301B | NA | PSL5384 | RRIS390A | ZT5389A | A7 | 2-381-01-04368(1/1) | 1) Auto start of standby on discharge pressure low 2) Start permissive for any pump on CW sump level Normal & discharge MOV closed & pump not in reverse rotation 3) Auto trip on CW sump level low low 4) Discharge valve 10% open. 5) Winding Temp. and Vibration. |
| 5 | P5301B | P5301A | NA | PSL5384 | RRIS390B | ZT5389B | A7 | 2-381-01-04368(1/1) | 1) Auto start of standby on discharge pressure low 2) Start permissive for any pump on CW sump level Normal & discharge MOV closed & pump not in reverse rotation 3) Auto trip on CW sump level low low 4) Discharge valve 10% open. 5) Winding Temp. and Vibration. |



Page No. : 20 OF 48

[illegible]



Page No. : 21 OF 48

[illegible]

THIS LOGIC IS APPLICABLE FOR HRSG FILL PUMP.



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 22 OF 48

APPLICABLE TAGS FOR SCHEME-A8 & A8A


| S. No. | PMP1 | PMP2 | PROCESS-1 | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|-----------|---------|---------|-----------|----------------------|---------------------|---|
| | TAG NO. | TAG NO. | TAG NO. | | | |
| 1 | DMPT-01 | DMPT-02 | PAL5805 | A8 | 1-381-01-04357(3/4) | 1)Discharge pressure low ---> Start-Stand by pump |
| 2 | DMPT-02 | DMPT-01 | PAL5805 | A8 | 1-381-01-04357(3/4) | 1)Discharge pressure low ---> Start-Stand by pump |
| 3 | RWP-01 | RWP-02 | PALxxxx | A8 | 1-381-01-04357(3/4) | 1)Discharge pressure low ---> Start-Stand by pump |
| 4 | RWP-02 | RWP-01 | PALxxxx | A8 | 1-381-01-04357(3/4) | 1)Discharge pressure low ---> Start-Stand by pump |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 23 OF 48

LOGIC SCHEME – A9



NOTE: -

- * APPLICABLE FOR NOTE NUMBER 3 OF DRIVE CONTROL PHILOSOPHY.
- ** THIS SIGNAL IS APPLICABLE ONLY FOR RWP.



**1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA**

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 24 OF 48

APPLICABLE TAGS FOR SCHEME-A9


| S. No. | PMP1 TAG NO. | PMP2 TAG NO. | PROCESS-1 TAG NO. | PROCESS-2 TAG NO. | PROCESS-3 TAG NO. | Set points | | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|-----------|-----------------|-----------------|----------------------|----------------------|----------------------|------------|------------|----------------------|-------------------------|--|
| | | | | | | SP1 | SP2 | | | |
| 1 | P5901A | P5901B | LI5901 | PAN1601 | PAL5904 | 3600 mm | 1600 mm | A9 | 1-381-01- 04456(1/1) | 1) Start permissive for any RWP on RAW water reservoir level normal. 2) Auto start of stand by pump on Discharge pr. Low. 3) Auto trip working pump on RAW water reservoir level low low. 4) Auto trip running pump on discharge pressure high. |
| 2 | P5901B | P5901A | LI5901 | PAN1601 | PAL5904 | 3600 mm | 1600 mm | A9 | 1-381-01- 04456(1/1) | 1) Start permissive for any RWP on RAW water reservoir level normal. 2) Auto start of stand by pump on Discharge pr. Low. 3) Auto trip working pump on RAW water reservoir level low low. 4) Auto trip running pump on discharge pressure high. |
| 3 | P5903A | P5903B | LI5908 | NA | PAL5913 | 3250 mm | 2190 mm | A9 | 1-381-01- 04456(1/1) | 1) Start permissive for any potable water pump on clarified water reservoir level normal. 2) Auto start of stand by pump on Discharge pr. Low. 3) Auto trip working pump on potable water reservoir level low low. |
| 4 | P5903B | P5903A | LI5908 | NA | PAL5913 | 3250 mm | 2190 mm | A9 | 1-381-01- 04456(1/1) | 1) Start permissive for any potable water pump on clarified water reservoir level normal. 2) Auto start of stand by pump on Discharge pr. Low. 3) Auto trip working pump on potable water reservoir level low low. |
| 5 | P5905A | P5905B | LI5908 | NA | PAL5919 | 3250 mm | 2190 mm | A9 | 1-381-01- 04456(1/1) | 1) Start permissive for any service water pump on clarified water reservoir level normal. 2) Auto start of stand by pump on Discharge pr. Low. 3) Auto trip working pump on clarified water reservoir level low low. |
| 6 | P5905B | P5905A | LI5908 | NA | PAL5919 | 3250 mm | 2190 mm | A9 | 1-381-01- 04456(1/1) | 1) Start permissive for any service water pump on clarified water reservoir level normal. 2) Auto start of stand by pump on Discharge pr. Low. 3) Auto trip working pump on clarified water reservoir level low low. |
| 7 | P5907A | P5907B | LI5908 | NA | PAL5925 | 3250 mm | 2190 mm | A9 | 1-381-01- 04456(1/1) | 1) Start permissive for any CT makeup pump on clarified water reservoir level normal. 2) Auto start of stand by pump on Discharge pr. Low. 3) Auto trip working pump on clarified water reservoir level low low. |
| 8 | P5907B | P5907A | LI5908 | NA | PAL5925 | 3250 mm | 2190 mm | A9 | 1-381-01- 04456(1/1) | 1) Start permissive for any CT makeup pump on clarified water reservoir level normal. 2) Auto start of stand by pump on Discharge pr. Low. 3) Auto trip working pump on clarified water reservoir level low low. |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 25 OF 48

LOGIC SCHEME – A10






1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 26 OF 48

APPLICABLE TAGS FOR SCHEME-A10

| S. No. | PMP1 | PMP2 | PROCESS-1 | PROCESS-2 | Set points | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|-----------|---------|---------|-----------|-----------|------------|----------------------|---------------------|--|
| | TAG NO. | TAG NO. | TAG NO. | TAG NO. | SP1 | | | |
| 1 | P1504A | P1504B | PAL1507 | LI1502 | 30% | A10 | 3-381-01-03053(1/1) | 1) Discharge pr. Low --> Auto start of stand by pump, 2) Hydrozine Tank level low --> trip working pump |
| 2 | P1504B | P1504A | PAL1507 | LI1502 | 30% | A10 | 3-381-01-03053(1/1) | 1) Discharge pr. Low --> Auto start of stand by pump, 2) Hydrozine Tank level low --> trip working pump |
| 3 | P1404A | P1404B | PAL1407 | LI1402 | 30% | A10 | 3-381-01-03054(1/1) | 1) Discharge pr. Low --> Auto start of stand by pump, 2) Ammonia Tank level low --> trip working pump |
| 4 | P1404B | P1404A | PAL1407 | LI1402 | 30% | A10 | 3-381-01-03054(1/1) | 1) Discharge pr. Low --> Auto start of stand by pump, 2) Ammonia Tank level low --> trip working pump |




Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 27 OF 48

LOGIC SCHEME – A11

NOTE:—

1. THIS LOGIC IS APPLICABLE TO REMOTE OPERATED DRIVES LIKE AGITATOR ETC.



Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 28 OF 48

LOGIC SCHEME – B1

[illegible]




1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 29 OF 48

APPLICABLE TAGS FOR SCHEME-B1

| S.No. | MOV TAG NO. | PROCESS-1 | SCHEME | P&ID |
|-------|-------------|-----------|--------|---------------------|
| | XXXX | | | |
| 1 | MOV-1115 | NA | B1 | 0-381-01-04104(1/1) |
| 2 | MOV-1113 | NA | B1 | 0-381-01-04104(1/1) |
| 3 | MOV-1217 | NA | B1 | 0-381-01-04105(1/1) |
| 4 | MOV-1314 | PT1314 | B1 | 0-381-01-04106(1/1) |
| 5 | MOV-1321 | NA | B1 | 0-381-01-04106(1/1) |
| 6 | MOV-1332 | NA | B1 | 0-381-01-04106(1/1) |
| 7 | MOV-1676 | NA | B1 | 0-381-01-04107(1/1) |
| 8 | MOV-1637 | NA | B1 | 0-381-01-04107(1/1) |
| 9 | MOV-1632 | NA | B1 | 0-381-01-04107(1/1) |
| 10 | MOV-1704 | NA | B1 | 0-381-01-04108(1/1) |
| 11 | MOV-1717 | NA | B1 | 0-381-01-04108(1/1) |
| 12 | LCL11AA001 | NA | B1 | 0-24-400-80910(1/1) |
| 13 | LBA10AA003 | NA | B1 | 0-24-400-80910(1/1) |
| 14 | LCL10AA002 | NA | B1 | 0-24-400-80910(1/1) |
| 15 | LCL10AA001 | NA | B1 | 0-24-400-80910(1/1) |
| 16 | LDJ40AA002 | NA | B1 | 0-24-400-80911(1/1) |
| 17 | LCL31AA002 | NA | B1 | 0-24-400-80911(1/1) |
| 18 | LCL30AA001 | NA | B1 | 0-24-400-80911(1/1) |
| 19 | LCL30AA002 | NA | B1 | 0-24-400-80911(1/1) |
| 20 | LCL30AA003 | NA | B1 | 0-24-400-80911(1/1) |
| 21 | LCL21AA001 | NA | B1 | 0-24-400-80911(1/1) |
| 22 | LBA20AA003 | NA | B1 | 0-24-400-80911(1/1) |
| 23 | LCL20AA002 | NA | B1 | 0-24-400-80911(1/1) |
| 24 | LCL20AA001 | NA | B1 | 0-24-400-80911(1/1) |



Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 30 OF 48

LOGIC SCHEME – B2A


| INPUT SIGNALS | | | | | LOGIC STRUCTURE | OUTPUT SIGNALS | | | | |
|---------------|------------------------|-------|-----------|----------|-----------------|----------------|-----------|-------------------|--------------------------|----------|
| TAG No. | DESCRIPTION | LOC | CONT TYPE | SIG TYPE | | SIG TYPE | CONT TYPE | LOC | DESCRIPTION | TAG No. |
| | | | | | | | | | | |
| MOV1104B | IBV A/M SELECTION | HMI | – | Soft DI | | Hard DO | NO | MCC | IBV OPEN cmd | MOV1104B |
| MOV1104B | IBV OPEN cmd | HMI | – | Soft DI | | Hard DI | NO | HMI | IBV RTS F/B IND. | |
| MOV1104B | IBV RTS F/B | MCC | NO | Hard DI | | | | | | |
| | | | | | | Hard DI | NO | HMI | IBV OPEN F/B INDICATION | MOV1104B |
| MOV1104B | IBV OPEN F/B | MCC | NO | Hard DI | | Hard DI | NO | HMI | IBV CLOSE F/B INDICATION | MOV1104B |
| MOV1104B | IBV CLOSE F/B | MCC | NO | Hard DI | | Hard DO | NO | MCC | IBV CLOSE cmd | MOV1104B |
| MOV1104B | IBV CLOSE cmd | HMI | – | Soft DI | | | | | | |
| | | | | | | | | | | |
| MOV1104A | MAIN MOV A/M SELECTION | HMI | – | Soft DI | | Hard DO | NO | MCC | MAIN MOV OPEN cmd | MOV1104A |
| MOV1104A | MAIN MOV OPEN cmd | HMI | – | Soft DI | | Hard DI | NO | HMI | MAIN MOV RTS F/B IND. | |
| MOV1104A | MAIN MOV RTS F/B | MCC | NO | Hard DI | | | | | | |
| | | | | | | Hard DI | NO | HMI | MAIN MOV OPEN F/B IND. | |
| MOV1104A | MAIN MOV OPEN F/B | MCC | NO | Hard DI | | Hard DI | NO | HMI | MAIN MOV CLOSE F/B IND. | |
| MOV1104A | MAIN MOV CLOSE F/B | MCC | NO | Hard DI | | | | | | |
| MOV1104A | MAIN MOV CLOSE cmd | HMI | – | Soft DI | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| MOV1104B | IBV POSITION F/B | Field | – | Hard AI | Hard AI | – | HMI | POSITION F/B IND. | MOV1104B | |
| | | | | | | | | | | |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 31 OF 48

LOGIC SCHEME – B2B






1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 32 OF 48

APPLICABLE TAGS FOR SCHEME-B2A & B2B

| S.No. | MOV TAG NO. | SCHEME | P&ID |
|-------|-------------------------------|--------|---------------------|
| | XXXXX | | |
| 1 | MOV-1104A AND MOV-1104B | B2A | 0-381-01-04104(1/1) |
| 2 | MOV-1607 | B2B | 0-381-01-04107(1/1) |
| 3 | MOV-1608 | B2B | 0-381-01-04107(1/1) |



Page No. : 33 OF 48

[illegible]



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 34 OF 48

APPLICABLE TAGS FOR SCHEME-B3

| S.No. | MOV TAG NO. | SCHEME | P&ID |
|-------|-------------|--------|---------------------|
| | XXXX | | |
| 1 | MOV-1124 | B3 | 0-381-01-04104(1/1) |
| 2 | MOV-1117 | B3 | 0-381-01-04104(1/1) |
| 3 | MOV-1130 | B3 | 0-381-01-04104(1/1) |
| 4 | MOV-1136 | B3 | 0-381-01-04104(1/1) |
| 5 | MOV-1150 | B3 | 0-381-01-04104(1/1) |
| 6 | MOV-1143 | B3 | 0-381-01-04104(1/1) |
| 7 | MOV-1210 | B3 | 0-381-01-04105(1/1) |
| 8 | MOV-1204 | B3 | 0-381-01-04105(1/1) |
| 9 | MOV-1319 | B3 | 0-381-01-04106(1/1) |
| 10 | MOV-1674 | B3 | 0-381-01-04107(1/1) |
| 11 | MOV-1679 | B3 | 0-381-01-04107(1/1) |
| 12 | MOV-1635 | B3 | 0-381-01-04107(1/1) |
| 13 | MOV-1630 | B3 | 0-381-01-04107(1/1) |
| 14 | MOV-1702 | B3 | 0-381-01-04108(1/1) |
| 15 | MOV-1821 | B3 | 0-381-01-04109(1/2) |
| 16 | MOV-1825 | B3 | 0-381-01-04109(1/2) |
| 17 | MOV-1829 | B3 | 0-381-01-04109(1/2) |
| 18 | MOV-1855 | B3 | 0-381-01-04109(1/2) |
| 19 | MOV-1859 | B3 | 0-381-01-04109(1/2) |
| 20 | MOV-1891 | B3 | 0-381-01-04109(2/2) |
| 21 | MOV-1895 | B3 | 0-381-01-04109(2/2) |
| 22 | MOV-5210 | B3 | 0-381-01-04355(1/1) |
| 23 | MOV-5214 | B3 | 0-381-01-04355(1/1) |
| 24 | MOV-5219 | B3 | 0-381-01-04355(1/1) |
| 25 | MOV-5220 | B3 | 0-381-01-04355(1/1) |
| 26 | LCL11AA002 | B3 | 0-24-400-80910(1/1) |
| 27 | LCL12AA001 | B3 | 0-24-400-80910(1/1) |
| 28 | LCH10AA001 | B3 | 0-24-400-80910(1/1) |
| 29 | LCH11AA001 | B3 | 0-24-400-80910(1/1) |

| S.No. | MOV TAG NO. | SCHEME | P&ID |
|-------|-------------|--------|---------------------|
| | XXXX | | |
| 30 | HAH10AA001 | B3 | 0-24-400-80910(1/1) |
| 31 | HAH11AA001 | B3 | 0-24-400-80910(1/1) |
| 32 | LBA10AA001 | B3 | 0-24-400-80910(1/1) |
| 33 | LBA10AA002 | B3 | 0-24-400-80910(1/1) |
| 34 | LBA10AA003 | B3 | 0-24-400-80910(1/1) |
| 35 | LBA10AA004 | B3 | 0-24-400-80910(1/1) |
| 36 | LAE10AA002 | B3 | 0-24-400-80910(1/1) |
| 37 | LAE10AA001 | B3 | 0-24-400-80910(1/1) |
| 38 | HBW047 | B3 | 0-24-400-80910(1/1) |
| 39 | LCL10AA003 | B3 | 0-24-400-80910(1/1) |
| 40 | LBW028 | B3 | 0-24-400-80911(1/1) |
| 41 | LDJ40AA001 | B3 | 0-24-400-80911(1/1) |
| 42 | LDJ40AA002 | B3 | 0-24-400-80911(1/1) |
| 43 | LAB30AA001 | B3 | 0-24-400-80911(1/1) |
| 44 | LMS001 | B3 | 0-24-400-80911(1/1) |
| 45 | LMS031 | B3 | 0-24-400-80911(1/1) |
| 46 | LCL31AA001 | B3 | 0-24-400-80911(1/1) |
| 47 | LCL30AA003 | B3 | 0-24-400-80911(1/1) |
| 48 | LBA30AA001 | B3 | 0-24-400-80911(1/1) |
| 49 | LBA30AA002 | B3 | 0-24-400-80911(1/1) |
| 50 | LAB20AA001 | B3 | 0-24-400-80911(1/1) |
| 51 | LCL21AA002 | B3 | 0-24-400-80911(1/1) |
| 52 | LCL22AA001 | B3 | 0-24-400-80911(1/1) |
| 53 | IBS031 | B3 | 0-24-400-80911(1/1) |
| 54 | LCH20AA001 | B3 | 0-24-400-80911(1/1) |
| 55 | LBA20AA001 | B3 | 0-24-400-80911(1/1) |
| 56 | LCH20AA002 | B3 | 0-24-400-80911(1/1) |
| 57 | LCL20AA003 | B3 | 0-24-400-80911(1/1) |



Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 35 OF 48

LOGIC SCHEME – B4

[illegible]




1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 36 OF 48

APPLICABLE TAGS FOR SCHEME-B4

| S.No. | MOV TAG NO. | PROCESS-1 | SCHEME | P&ID |
|-------|-------------|-------------|--------|---------------------|
| | XXXX | | | |
| 1 | MOV-1852A | PMP004A-RUN | B4 | 0-381-01-04109(1/2) |
| 2 | MOV-1852B | PMP004B-RUN | B4 | 0-381-01-04109(1/2) |
| 3 | MOV-1888A | PMP005A-RUN | B4 | 0-381-01-04109(2/2) |
| 4 | MOV-1888B | PMP005B-RUN | B4 | 0-381-01-04109(2/2) |
| 5 | MOV-18117A | PMP006A-RUN | B4 | 0-381-01-04109(2/2) |
| 6 | MOV-18117B | PMP006B-RUN | B4 | 0-381-01-04109(2/2) |
| 7 | LAB10AA001A | NA | B4 | 0-24-400-80910(1/1) |
| 8 | LAB10AA001 | NA | B4 | 0-24-400-80910(1/1) |
| 9 | LBA10AA005A | NA | B4 | 0-24-400-80910(1/1) |
| 10 | LBA10AA005 | NA | B4 | 0-24-400-80910(1/1) |
| 11 | LBA30AA005A | NA | B4 | 0-24-400-80911(1/1) |
| 12 | LBA30AA005 | NA | B4 | 0-24-400-80911(1/1) |
| 13 | LBA20AA005A | NA | B4 | 0-24-400-80911(1/1) |
| 14 | LBA20AA005 | NA | B4 | 0-24-400-80911(1/1) |



Page No. : 37 OF 48

[illegible]

1. HOLDING OF OPEN AND CLOSE COMMAND WILL BE PROVIDED IN DCS THEREFOR IT IS NOT REQUIRE IN ACTUATOR DUE TO LOGIC CONDITIONS.



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 38 OF 48

APPLICABLE TAGS FOR SCHEME-B5


| S.No. | MOV TAG NO. | PMP1 | PROCESS-1 | SCHEME | P&ID | Remarks |
|-------|-------------|--------|-----------|--------|----------------------|---|
| | XXXX | | | | | |
| 1 | MOV-5204 | P5202A | PAN5209A | B5 | 0-381-01-04355(1/1) | 1) On start of suction pump --> Open the valve by 10 deg. 2)After 10 deg opening of valve, if discharge pres is normal -->Fully open the valve for 90 deg. 3) On suction pump trip --> Close the valve. |
| 2 | MOV-5205 | P5202B | PAN5209B | B5 | 0-381-01-04355(1/1) | 1) On start of suction pump --> Open the valve by 10 deg. 2)After 10 deg opening of valve, if discharge pres is normal -->Fully open the valve for 90 deg. 3) On suction pump trip --> Close the valve. |
| 3 | MOV-5206 | P5202C | PAN5209C | B5 | 0-381-01-04355(1/1) | 1) On start of suction pump --> Open the valve by 10 deg. 2)After 10 deg opening of valve, if discharge pres is normal -->Fully open the valve for 90 deg. 3) On suction pump trip --> Close the valve. |
| 4 | MOV-5389A | P5302A | PAN5301 | B5 | 0-381-01-014368(1/1) | 1) On start of suction pump --> Open the valve by 10 deg. 2)After 10 deg opening of valve, if discharge pres is normal -->Fully open the valve for 90 deg. 3) On suction pump trip --> Close the valve. |
| 5 | MOV-5389B | P5302B | PAN5302 | B5 | 0-381-01-014368(1/1) | 1) On start of suction pump --> Open the valve by 10 deg. 2)After 10 deg opening of valve, if discharge pres is normal -->Fully open the valve for 90 deg. |



1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 39 OF 48

LOGIC SCHEME – B6






1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 40 OF 48

APPLICABLE TAGS FOR SCHEME-B6


| S.No. | MOV TAG NO. | PROCESS-1 | PROCESS-2 | SCHEME | P&ID | DESCRIPTION |
|-------|------------------------|-------------|-----------------|--------|---------------------|---|
| | XXXX | TAG NO. | TAG NO. | | | |
| 1 | MOV-1-1818A & 1818B | XLP003A RUN | P-003A TRIP/OFF | B6 | 0-381-01-04109(1/2) | AUTO OPEN ON RECEIPT OF HP BFP-1 RUN FEEDBACK |
| 2 | MOV-2-1818A & 1818B | XLP003B RUN | P-003B TRIP/OFF | B6 | 0-381-01-04109(1/2) | AUTO OPEN ON RECEIPT OF HP BFP-2 RUN FEEDBACK |
| 3 | MOV-3-1818A & 1818B | XLP003C RUN | P-003C TRIP/OFF | B6 | 0-381-01-04109(1/2) | AUTO OPEN ON RECEIPT OF HP BFP-3 RUN FEEDBACK |



Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 41 OF 48


LOGIC SCHEME – C1

[illegible]



Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 42 OF 48

[illegible]



Page No. : 43 OF 48


[illegible]




1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 44 OF 48

LOGIC SCHEME – C4




NOTE:
1. THIS LOGIC IS APPLICABLE FOR SOV6907, SOV6915 AND SOV6916.



Page No. : 45 OF 48


[illegible]

1. THIS LOGIC IS APPLICABLE FOR SOV6907, SOV6915 AND SOV6916.



Page No. : 46 OF 48

[illegible]



Page No. : 47 OF 48

[illegible]



**1X100MW TRIPURA GAS BASED CC
POWER PROJECT
BHEL-HYDERABAD
DCS LOGIC DIAGRAMS – BOP AREA**

Doc. No. : 4-381-21-02891
Rev. No. : 00
Page No. : 48 OF 48

APPLICABLE TAGS FOR SCHEME-C1,C2,C3...C7

| S. No. | VALVE TAG NO. | | | PROCESS-1 | PROCESS-2 | PROCESS-3 | Set points | | Applicable SCHEME | P & ID | LOGIC DESCRIPTION |
|--------|---------------|---|------|-----------|-----------|-----------|--------------|--------------|----------------------|---------------------|---|
| | | | XXXX | TAG NO. | TAG NO. | TAG NO. | SP1 | SP2 | | | |
| 1 | XV | - | 1801 | LI1801A | LI1801B | NA | 1681 mmWC | 1581 mmWC | C1 | 1-381-01-04109(1/2) | 1)Auto open valve on 50mm above high level of DEAE 2)Auto close valve on 50mm below high level of DEAE |
| 2 | BDV | - | 6938 | NA | NA | NA | NA | NA | C2 | 1-381-01-04110(3/3) | 1) Auto open on Gas scrubber level high high 2) Auto open in case of fire in GT 3) Manual open in case emergency/long shutdown |
| 3 | ESD | - | 6937 | NA | NA | NA | NA | NA | C3 | 1-381-01-04110(3/3) | 1) Auto close on Gas scrubber level high high 2) Auto close in case of fire in GT 3) Manual close in case emergency/long shutdown |
| 4 | BDV | - | 6915 | NA | NA | NA | NA | NA | C4 | 1-381-01-04110(2/3) | 1) Auto open on Gas scrubber level high high 2) Auto open in case of fire in GT 3) Manual open in case emergency/long shutdown |
| 5 | BDV | - | 6916 | NA | NA | NA | NA | NA | C4 | 1-381-01-04110(2/3) | 1) Auto open on Gas scrubber level high high 2) Auto open in case of fire in GT 3) Manual open in case emergency/long shutdown |
| 6 | BDV | - | 6907 | NA | NA | NA | NA | NA | C4 | 1-381-01-04110(1/3) | 1) Auto open on Gas scrubber level high high 2) Auto open in case of fire in GT 3) Manual open in case emergency/long shutdown |
| 7 | UB | - | 6904 | NA | NA | NA | NA | NA | C5 | 1-381-01-04110(1/3) | 1) Auto close on Gas scrubber level high high 2) Auto close in case of fire in GT 3) Manual close in case emergency/long shutdown |
| 8 | UV | - | 5258 | NA | NA | NA | 4450 mmWC | 4750 mmWC | C6 | 1-381-01-04355(1/1) | 1)Auto open valve on CW sump level normal 2)Auto close valve on CW sump level high |
| 9 | LCV | - | 6905 | LI6905A | LI6906A | NA | 70% | 30% | C7 | 1-381-01-04110(1/3) | 1)Auto open on gas scrubber level high 2)Auto close on gas scrubber level low |

Annexure-VII

Details of Major and Critical Spares

| SL No | Main Equipment /Area | Material Description | Stock Quantity (No/Set) | Availability status |
|-------|---|---|-------------------------|--|
| 1 | GBC (Gas Booster Compressor) Unit 1 & 2 and their Auxiliaries | Control valve positioner(Make-Metso) | 2 | Available |
| | | Vibration probe(Make-Bently Nevada) | 6 | Available |
| | | Temp Control valve positioner(Make-Fisher) | 1 | Available |
| | | Proximeter(Make-Bently Nevada) | 6 | Available |
| | | Compressor Axial displacement probe(Make-Bently Nevada) | 1 | Available |
| | | Gear box vibration probe(Make-Bently Nevada) | 6 | Available |
| | | SUCTION CONTROL VALVE DIAPHRAGM | 2 | Available |
| | | GBC MOROR BEARING DE | 1 | Available |
| | | GBC MOROR BEARING NDE | 1 | Available |
| | | GEAR BOX BEARING SET | 1 | Available |
| | | COMPRESSOR MECHANICAL SEAL DE | 1 | Available |
| | | COMPRESSOR MECHANICAL SEAL NDE | 1 | Available |
| | | COMPRESSOR THRUST BEARING | | Available |
| | | COMPRESSOR THRUST BEARING | 1 | Available |
| 2 | Gas Turbine | TURNINE GEAR MOTOR(Make-LEROY SOMER CE) | 1 | Available |
| | | GCV | 1 | Available |
| | | Wheelspace and exhus thermocouples | 1set | Available |
| | | Servo valves for GCV, SRV and IGV(Make-Moog) | 1 set for each valve | Available |
| | | AOP motor (GE make) | 1 | Available |
| | | Spark plug | 2 | Available |
| | | IBH Control valve positioner(Make-Flowserve) | 1 | Available |
| | | Air filter pulsing card | 1 | Available |
| | | HYDROLIC PUMP COMPLETE SET | 1 | Available |
| | | GENERATOR JOUNAL BEARING DE SIDE | 1 | Available |
| | | GENERATOR JOUNAL BEARING NDE SIDE | 1 | Available |
| | | GEAR BOX HAND BEARING MOTOR | 1 | Available |
| | | STOP RATIO VALVE | 2 | Available |
| | | P1 CONTROL VALVE FULL SET | 1 | Available |
| | | P1 FLEXIBLE GAS PIPE | 1 | Available |
| | | P2 FLEXIBLE GAS PIPE | 1 | Available |
| | | P3 FLEXIBLE GAS PIPE | 1 | Available |
| | | P4 FLEXIBLE GAS PIPE | 2 | Available |
| | | CARBON BRUSH | 1 SET | Available |
| | | Fuel nozzle assembly | 1 Set | Available (refurbished spare) |
| | | Transition Piece Assembly | 1 Set | Sent for refurbishment |
| | | Cap Assembly | 1 Set | Available (refurbished spare) |
| | | Liner assembly | 1 Set | Available (refurbished spare) |
| | | Nozzle Kit Turbine Stage 1 | 1 Set | Sent for refurbishment |
| | | Nozzle Kit Turbine Stage 2 | 1 Set | Sent for refurbishment |
| | | Nozzle Kit Turbine Stage 3 | 1 Set | Sent for refurbishment |
| | | Shroud set Turbine Stage 1 | 1 Set | Sent for refurbishment |
| | | Shroud set Turbine Stage 2 | 1 Set | Available (refurbished spare) |
| | | Shroud set Turbine Stage 3 | 1 Set | Available (refurbished spare) |
| | | Bucket Kit Turbine Stage 1 | 1 Set | Sent for refurbishment |
| | | Bucket Kit Turbine Stage 2 | 1 Set | Sent for refurbishment |
| | | Bucket Kit Turbine Stage 3 | 1 Set | Sent for refurbishment |
| 3 | Diverting damper | SBC CARD | 2 | All cards are available &Order for complete set is placed (materials are to be received within April 2022) |
| | | POWER CARD | 1 | |
| | | Terminal card | 2 | |
| | | GEAR BOX | 1 SET | Available |
| | | PAD BEARING | 2 SET | Available |
| 4 | HRSG | HP main steam valve actuator HMS 42(Make-Auma) | 1 | Available (repaired spare) |
| | | HP start up vent actuator HMS 30 (Make-Auma) | 1 | Available |
| | | DRUM MAN HOLE GASKIT | 6 SET | Available |
| | | MECHANICAL SEAL DE SIDE | 1 | Available |
| | | MECHANICAL SEAL NDE SIDE | 2 | Available |

| | | | | |
|----|-------------------|--|-------|-----------|
| 5 | HP BFP | IMPELLAR | 1 | Available |
| | | JOURNAL BEARING DE SIDE | 1 | Available |
| | | JOURNAL BEARING NDE SIDE | 1 | Available |
| | | THRUST BEARING | 1 | Available |
| | | COUPLING BETWEEN MOTOR TO VOITH | 2 SET | Available |
| | | COUPLING BETWEEN VOITH TO PUMP | 2 SET | Available |
| | | LUBE OIL FILTER | 2 | Available |
| | | AUTO RECIRCULATION VALVE | 1 | Available |
| | | Vibration probe(Make-Bently Nevada) | 5 | Available |
| | | Proximeter(Make-Bently Nevada) | 5 | Available |
| 6 | IPBFP | MECHANICAL SEAL DE SIDE | 1 | Available |
| | | MECHANICAL SEAL NDE SIDE | 2 | Available |
| | | AUTO RECIRCULATION VALVE | 1 | Available |
| 7 | LPBFP | MECHANICAL SEAL DE SIDE | 1 | Available |
| | | MECHANICAL SEAL NDE SIDE | 1 | Available |
| | | AUTO RECIRCULATION VALVE | 1 | Available |
| 8 | CPHRC | MECHANICAL SEAL | 1 | Available |
| 9 | CEP | MECHANICAL SEAL | 1 | Available |
| | | PUMP MECHANICAL SEAL | 1 | Available |
| 10 | COOLING TOWER FAN | CT FAN GEAR BOX | 1 | Available |
| | | CT FAN BLADE | 5 | Available |
| | | WATER NOZZLE | 20 | Available |
| | | CT FAN MOTOR(Make-ABB) | 1 | Available |
| 11 | INTAKE RIVER PUMP | PUMP MOTOR | 1 | Available |
| | | PARTING PLANE FASTENERS FOR OUTER CASING | | Available |
| | | STUD M80X6X530X482 P/N HY301010062989 | 1 | Available |
| | | STUD M80X6X430X382 P/N HY301010082989 | 1 | Available |
| | | HEX NUT M80 x 6 P/N HY301010102989 | 2 | Available |
| | | STUD M90X6X450X397 P/N HY301010122989 | 6 | Available |
| | | HEX NUT M90 x 6 P/N HY301010142989 | 6 | Available |
| | | STUD M100X6X475X417 P/N HY301010162989 | 2 | Available |
| | | HEX NUT M100 x 6 P/N HY301010182989 | 2 | Available |
| | | STUD M110X6X580X517 P/N HY301010202989 | 2 | Available |
| | | HEX.NUT M110X6 P/N HY301010222989 | 2 | Available |
| | | EXHAUST HOOD | | Available |
| | | SILICON RUBBER 8X3 FOR EXHAUST HOOD P/N HY301253062989 | 32 | Available |
| | | INNER CASING ASSEMBLY P/N | | Available |
| | | SEALING FIN FOR INNER CASING P/N HY301020282989 | 1 | Available |
| | | CAULKING WIRE FOR INNER CASING P/N HY301020302989 | 1 | Available |
| | | STEAM GLANDS | | Available |
| | | SEALING FIN FOR FRONT STEAM GLAND P/N HY301210072989 | 1 | Available |
| | | CAULKING WIRE FOR FRONT STEAM GLAND P/N HY301210092989 | 1 | Available |
| | | SEALING FIN FOR BALANCE PISTON GLAND P/N HY301220152989 | 1 | Available |
| | | CAULKING WIRE FOR BALANCE PISTON GLAND P/N HY301220142989 | 1 | Available |
| | | SEALING FIN FOR REAR STEAM GLAND P/N HY301320092989 | 1 | Available |
| | | CAULKING WIRE FOR REAR STEAM GLAND P/N HY301320112989 | 1 | Available |
| | | H.P GUIDE BLADE CARRIER | | Available |
| | | SEALING FIN FOR HP GUIDE BLADE CARRIERS P/N HY301757952989 | 1 | Available |
| | | CAULKING WIRE FOR HP GUIDE BLADE CARRIERS P/N HY301757972989 | 1 | Available |
| | | OIL GLANDS | | Available |
| | | SCRAPPING RING FOR FRONT OIL GLAND P/N HY302320062989 | 5 | Available |
| | | SCRAPPING RING FOR REAR-FRONT OIL GLAND P/N HY302330062989 | 7 | Available |
| | | SCRAPPING RING FOR REAR-REAR OIL GLAND P/N HY302340102989 | 7 | Available |
| | | ROTOR ASSEMBLY | | Available |
| | | SEALING FIN FOR ROTOR P/N HY303010172989 | 1 | Available |
| | | CAULKING WIRE FOR ROTOR P/N HY303010192989 | 1 | Available |
| | | PACKING RING P/N HY305020102989 | 1 | Available |
| | | MAIN STOP VALVE | | Available |
| | | PIN 20X170 P/N HY305020202989 | 1 | Available |
| | | VALVE SPINDLE P/N HY305020342989 | 1 | Available |
| | | PACKING RING P/N HY305020402989 | 5 | Available |
| | | PACKING P/N HY305020462989 | 1 | Available |
| | | PLATE 1 P/N HY305020502989 | 3 | Available |
| | | PLATE 2 P/N HY305020522989 | 1 | Available |
| | | PISTON SPINDLE P/N HY305020542989 | 1 | Available |

| | | |
|--|----|-----------|
| CAP NUT P/N HY305020562989 | 1 | Available |
| NUT M30X1.5 P/N HY305020582989 | 1 | Available |
| CAP SCREW P/N HY305020602989 | 1 | Available |
| CAP NUT P/N HY305020662989 | 1 | Available |
| SL HEAD GRUB SCREW P/N HY305020772989 | 1 | Available |
| HEX SCREW P/N HY305020792989 | 4 | Available |
| ABSTREIFER P/N HY305020802989 | 1 | Available |
| MCD WASHER P/N HY305020832989 | 4 | Available |
| TURCON STEP SEAL P/N HY305020852989 | 3 | Available |
| TRDL SEALING RING ID 61 P/N HY305020862989 | 1 | Available |
| TRDL SEALING RING ID 54 P/N HY305020872989 | 1 | Available |
| CIRCLIP P/N HY305020882989 | 1 | Available |
| CLAMPING SLEEVE 6X60 P/N HY305020892989 | 3 | Available |
| TRDL SEALING RING ID400 P/N HY305020932989 | 1 | Available |
| HYDRAULIC ACTUATOR FOR MAIN STOP VALVE | | Available |
| HELICOIL INSERT M24 P/N HY305030222989 | 3 | Available |
| SEALING WASHER P/N HY305030232989 | 2 | Available |
| TRDL SEALING RING ID440 P/N HY305030272989 | 1 | Available |
| TRDL SEALING RING ID460 P/N HY305030282989 | 1 | Available |
| IP/LP INJECTION STOP VALVE | | Available |
| CLAMPING PIN P/N HY305560282989 | 1 | Available |
| SCRU SLT CHS A P M5 P/N HY305560322989 | 3 | Available |
| CLAMPING SLEEVE 4X32 P/N HY305560332989 | 1 | Available |
| TRDL SEALING RING ID20 P/N HY305560342989 | 1 | Available |
| TRDL SEALING RING ID64 P/N HY305560352989 | 1 | Available |
| SEALING WASHER P/N HY305560482989 | 1 | Available |
| PLUG SCREW P/N HY305560492989 | 1 | Available |
| CYL CMPSN SPRING P/N HY305070252989 | 1 | Available |
| HYDRAULIC ACTUATOR FOR INJECTION STOP VALVE | | Available |
| HELICOIL INSERT M16 P/N HY305070302989 | 3 | Available |
| VALVE SPINDLE PACKING P/N HY305460102989 | 2 | Available |
| DISC SPRING P/N HY305460582989 | 10 | Available |
| CIRCLIP P/N HY305460622989 | 2 | Available |
| SPH PLAIN BRG P/N HY305460632989 | 1 | Available |
| CLAMPING SLEEVE 2.5X18 P/N HY305460742989 | 1 | Available |
| DEVA-SWIVEL BEARING PG09-50.02 P/N HY305470282989 | 1 | Available |
| CIRCLIP P/N HY305470312989 | 2 | Available |
| DU-BUSH P/N HY305470342989 | 2 | Available |
| CYL CMPSN SPRING P/N HY305470392989 | 2 | Available |
| THREADED PIN M30 P/N HY305470402989 | 2 | Available |
| HP CONTROL VALVE | | Available |
| DISC SPRING P/N HY305470482989 | 4 | Available |
| BUSH P/N HY305470512989 | 1 | Available |
| BUSH P/N HY305470532989 | 1 | Available |
| DEVA-SWIVEL BEARING PG09-60.02 P/N HY305470552989 | 1 | Available |
| PIN DIA 60F7 P/N HY305470602989 | 1 | Available |
| CIRCLIP P/N HY305470622989 | 2 | Available |
| DEVA-SWIVEL BEARING PG09-50.02 P/N HY305470632989 | 2 | Available |
| CIRCLIP P/N HY305470662989 | 4 | Available |
| SCREW CAP SOC P M10 P/N HY305470672989 | 2 | Available |
| IP/LP INJECTION CONTROL VALVE | | Available |
| VALVE CONE P/N HY305260082989 | 1 | Available |
| VALVE SPINDLE P/N HY305260102989 | 1 | Available |
| PIN DIA 10X20 P/N HY305260162989 | 3 | Available |
| VALVE SPINDLE PACKING P/N HY305260182989 | 1 | Available |
| CLAMPING SLEEVE 2.5X28 P/N HY305260402989 | 4 | Available |
| THREADED PIN M16 P/N HY305260432989 | 1 | Available |
| THREADED BUSH P/N HY305260452989 | 1 | Available |
| GRUB SCREW P/N HY305260472989 | 1 | Available |
| CIRCLIP P/N HY305260532989 | 2 | Available |
| CYL CMPSN SPRING P/N HY305260542989 | 1 | Available |
| MCD WASHER P/N HY305260612989 | 2 | Available |
| DU-BUSH P/N HY305260642989 | 2 | Available |
| THRST WASHER P/N HY305260672989 | 2 | Available |
| CIRCLIP P/N HY305260682989 | 2 | Available |
| CLAMPING SLEEVE 2.5X18 P/N HY305260772989 | 1 | Available |
| SPH PLAIN BEARING P/N HY305260882989 | 1 | Available |

| | | |
|---|----|-----------|
| CIRCLIP P/N HY305260932989 | 2 | Available |
| DISC SPRING P/N HY305260962989 | 10 | Available |
| CIRCLIP P/N HY305261022989 | 2 | Available |
| TAPER PIN WITH THREADS DIA8X60 P/N HY305261102989 | 1 | Available |
| MCD WASHER P/N HY305261122989 | 1 | Available |
| PIN 8M6 P/N HY305261142989 | 2 | Available |
| HP PILOT VALVE | | Available |
| HELICOIL INSERT M16 P/N HY306030142989 | 4 | Available |
| HELICOIL INSERT M12 P/N HY306030152989 | 6 | Available |
| HELICOIL INSERT M10 P/N HY306030162989 | 10 | Available |
| BUSH P/N HY306030262989 | 1 | Available |
| BUSH P/N HY306030302989 | 1 | Available |
| CONTROL SLIDE P/N HY306030322989 | 1 | Available |
| STHR BALL BEARING P/N HY306030452989 | 1 | Available |
| SPRING SEAT P/N HY306030462989 | 1 | Available |
| CYL CMPSN SPRING P/N HY306030482989 | 1 | Available |
| TRDL SEALING RING ID28 P/N HY306030642989 | 1 | Available |
| SLOT TYPE FLOW CONTROL VALVE 12 P/N HY306030752989 | 1 | Available |
| SLOT TYPE FLOW CONTROL VALVE 16 P/N HY306030762989 | 1 | Available |
| TRDL SEALING RING ID16 P/N HY306030772989 | 1 | Available |
| TURCON STEP SEAL P/N HY306030822989 | 1 | Available |
| ABSTREIFER P/N HY306030832989 | 1 | Available |
| MCD WASHER P/N HY306030842989 | 1 | Available |
| HP SERVOMOTOR | | Available |
| TRDL SEALING RING ID56 P/N HY306110872989 | 4 | Available |
| HELICOIL INSERT P/N HY306110882989 | 1 | Available |
| CIRCLIP P/N HY306110892989 | 4 | Available |
| CIRCLIP P/N HY306110902989 | 1 | Available |
| DU-BUSH P/N HY306110912989 | 1 | Available |
| DU-BUSH P/N HY306110922989 | 1 | Available |
| DU-BUSH P/N HY306110932989 | 1 | Available |
| DU-BUSH P/N HY306110942989 | 1 | Available |
| PROT ROLLER BEARING P/N HY306110952989 | 2 | Available |
| SEAL KIT FOR HYDRAULIC CYLINDER OF HP P/N HY306112002989 | 1 | Available |
| SM | | Available |
| DAMPING DEVICE FOR HP SERVOMOTOR P/N HY306140022989 | 1 | Available |
| IP/LP PILOT VALVE P/N | 1 | Available |
| BUSH P/N HY306070142989 | 1 | Available |
| BUSH P/N HY306070182989 | 1 | Available |
| CONTROL SLIDE P/N HY306070222989 | 1 | Available |
| TRDL SEALING RING ID130 P/N HY306070322989 | 2 | Available |
| STHR BALL BEARING P/N HY306070352989 | 1 | Available |
| SPRING SEAT P/N HY306070362989 | 1 | Available |
| CYL CMPSN SPRING P/N HY306070382989 | 1 | Available |
| SPRING SEAT P/N HY306070392989 | 1 | Available |
| TRDL SEALING RING ID26 P/N HY306070452989 | 1 | Available |
| MCD WASHER P/N HY306070562989 | 2 | Available |
| SLOT TYPE FLOW CONTROL VALVE 10 P/N HY306070572989 | 2 | Available |
| TURCON STEP SEAL P/N HY306070642989 | 1 | Available |
| ABSTREIFER P/N HY306070652989 | 1 | Available |
| CYL CMPSN SPRING P/N HY306070662989 | 1 | Available |
| IP/LP SERVOMOTOR | | Available |
| HELICOIL INSERT M12 P/N HY306120682989 | 1 | Available |
| CIRCLIP P/N HY306120692989 | 2 | Available |
| CIRCLIP P/N HY306120702989 | 1 | Available |
| CIRCLIP P/N HY306120712989 | 2 | Available |
| CIRCLIP P/N HY306120722989 | 8 | Available |
| DU-BUSH P/N HY306120752989 | 3 | Available |
| DU-BUSH P/N HY306120762989 | 2 | Available |
| HELICOIL INSERT M6 P/N HY306120772989 | 1 | Available |
| PROT ROLLER BEARING P/N HY306120782989 | 2 | Available |
| SEAL KIT FOR HYDRAULIC CYLINDER OF LP SM P/N HY306122002989 | 1 | Available |
| DAMPING DEVICE FOR LP SERVOMOTOR P/N HY306150022989 | 1 | Available |
| CONNECTING PARTS FOR INNER CASING | | Available |
| ECCENTRIC GUIDE ASSLY P/N HY307680512989 | 1 | Available |
| ANGLE RING P/N HY307682562989 | 4 | Available |

| | | |
|--|-------|-----------|
| THREADED BUSH P/N HY307682582989 | 4 | Available |
| CYL. PIN P/N HY307682602989 | 8 | Available |
| CONNECTING PARTS FOR B.P. GLAND | | Available |
| ECCENTRIC GUIDE ASSLY P/N HY307680092989 | 1 | Available |
| SPHERICAL WASHER P/N HY307680242989 | 4 | Available |
| THREADED CUP 1 P/N HY307680262989 | 2 | Available |
| THREADED CUP 2 P/N HY307680282989 | 2 | Available |
| CONNECTING PARTS FOR GBC-1 | | Available |
| ECCENTRIC GUIDE ASSLY P/N HY307682102989 | 1 | Available |
| SPHERICAL WASHER P/N HY307682312989 | 4 | Available |
| THREADED CUP 1 P/N HY307682332989 | 2 | Available |
| THREADED CUP 2 P/N HY307682352989 | 2 | Available |
| CONNECTING PARTS FOR GBC-2 | | Available |
| ECCENTRIC GUIDE ASSLY P/N HY307681762989 | 1 | Available |
| SPHERICAL WASHER P/N HY307681972989 | 4 | Available |
| THREADED CUP 1 P/N HY307681992989 | 2 | Available |
| THREADED CUP 2 P/N HY307682012989 | 2 | Available |
| CONNECTING PARTS FOR GBC-3 | | Available |
| ECCENTRIC GUIDE ASSLY P/N HY307681422989 | 1 | Available |
| SPHERICAL WASHER P/N HY307681632989 | 4 | Available |
| THREADED CUP 1 P/N HY307681652989 | 2 | Available |
| THREADED CUP 2 P/N HY307681672989 | 2 | Available |
| CONNECTING PARTS FOR GBC-4 | | Available |
| ECCENTRIC GUIDE ASSLY P/N HY307681122989 | 1 | Available |
| SPHERICAL WASHER P/N HY307681292989 | 4 | Available |
| THREADED CUP 1 P/N HY307681312989 | 2 | Available |
| THREADED CUP 2 P/N HY307681332989 | 2 | Available |
| ADDL. SPARES | | Available |
| DISC SPRING FOR CASING TO FRONT PEDESTAL HOLDING P/N HY302360402989 | 4 | Available |
| COMPRESSION BELLOW - REAR BEARING HOUSING P/N HY301320642989 | 1 | Available |
| LEVER OF HAND BARRING DEVICE P/N HY307640072989 | 1 | Available |
| SOCKET SPANNER M56 FOR TURB-GEN COUPLING BOLTS P/N HY311070112989 | 1 | Available |
| TURBINE JOURNAL BEARING DE SIDE | 1 | Available |
| TURBINE JOURNAL BEARING NDE SIDE | 1 | Available |
| TURBINE THRUST BEARING | 1 | Available |
| GENERATOR JOURNAL BEARING DE SIDE | 1 | Available |
| GENERATOR JOURNAL BEARING NDE SIDE | 1 | Available |
| GOVERNING SKID LUBE OIL FILTER | 1 | Available |
| HP GOVERNING VALVE SPARE | 1 SET | Available |
| HP ESV SPARE | 1 SET | Available |
| HP PILOT VALVE | 1 | Available |
| IL AND LP PILOT VALVE | 1 | Available |
| IL AND LP ESV OIL SIDE O-RING SET | 2 SET | Available |
| HP STEAM DUMP VALVE GLANG PACKING | 1 | Available |
| IP STEAM DUMP VALVE GLANG PACKING | 1 | Available |
| LP STEAM DUMP VALVE GLANG PACKING | 1 | Available |
| CPC Positioner for electronic governor(Make- Woodward) | 1 | Available |
| Siemens positioner for APRDS valves | 1 | Available |
| Control valve positoner(Make-Metso) | 1 | Available |
| Spares for Rotrok/Auma make actuators | 2 Set | Available |
| Bharat Limitorque actuator spares | 1 Set | Available |
| Casing expansion probe | 1 | Available |
| HRSg Super heater sparay contol valve positioner (Make-Baker Hugues Masonelian) | 2 | Available |
| Axial displacement probe(Make-Bently Nevada) | 1 | Available |
| Generator vibration probe(Make-Bently Nevada) | 2 | Available |
| AOP/MOP Motor (MAKE-BHARAT BIJLEE) | 1 | Available |
| Control valve l/p converter | 3 | Available |
| RTD for Generator Bearing | 4 | Available |
| RTD for Turbine Journal/Thrust Bearing | 8 | Available |
| Solenoid valve for Stop valve Open/Close | 1 | Available |
| Solenoid valve for remote engaged trip device | 1 | Available |
| Solenoid valve for turbine tripping | 1 | Available |
| Solenoid valve for Jet spray cooler | 1 | Available |
| Vibration Probe | 3 | Available |

| | | | | |
|----|-------------|--|--------|------------|
| | | Proximeter | 6 | Available |
| | | Casing Expansion Probe | 1 | Available |
| | | (-1)to 1.5 Kg/cm ² 150mm dial local bottom mounting | 1 | Available |
| | | 0-6 Kg/cm ² 150mm dial local bottom mounting | 4 | Available |
| | | 0- 160Kg/cm ² 150mm dial local bottom mounting | 2 | Available |
| | | 0-200 Kg/cm ² 150mm dial local bottom mounting | 2 | Available |
| | | 0-60 Kg/cm ² 150mm dial local bottom mounting | 1 | Available |
| | | STG vacuum breaker | 1 | Available |
| | | STG Aux. Steam (TCV-1103,PCV-1301,UV 5228,XV-1801) | 2 | Available |
| | | GENERATOR HOT/COLD AIR RTD | 2 | Available |
| | | GENERATOR SPACE HEATER | 2 | Available |
| | | EARTHING BRUSH-A | 8 | Available |
| | | EARTHING BRUSH-B | 8 | Available |
| | | BRUSH HOLDER | 2 | Available |
| | | FIRE DETECTOR 100°C | 3 | Available |
| | | FIRE DETECTOR 80°C | 3 | Available |
| | | CLAMPING PIECE | 8 | Available |
| | | BEARING SEALING RING | 4 | Available |
| | | SCRAPPER FIN PROFILE | 3 | Available |
| | | INSULATION SET FOR GENERATOR BEARING | 1 SET | Available |
| 13 | EDG | PUMP,FUEL TLN | 1 | Available |
| | | INJECTOR | 8 | Available |
| | | SWITCH MAGNETIC | 2 | Available |
| | | MOTOR, STARTING | 1 | Available |
| 14 | CCWM SYSTEM | CCWM Fan Motor(MAKE-BHARAT BIJLEE) | 2 No | Available |
| 15 | IAPA | PLC with programming (Make-Allen Bradley) | 1 | Available |
| | | For Dry air skid Control valve with actuator(Make-Aira) | 8 | Available |
| | | IAPA MOTOR (Make-ABB) | 1 | Available |
| | | V- Belt | 2 Sets | Available |
| | | LP side valve set | 1 Set | Available |
| | | HP Side Valve set | 1 Set | Available |
| | | LP side channel and spring set | 1 Set | Available |
| | | HP side channel and spring set | 1 Set | Available |
| 16 | SFC | Instantaneous relay plug -in 230 V 50 Hz CO | 1 | Availabale |
| | | Relay Switching DC 24 V | 5 | Availabale |
| | | Current Transformer 1500/1 A 20 VA (0 to 1) | 1 | Availabale |
| | | Current Transformer Built-in bar-crossed primary winding | 1 | Availabale |
| | | Analogical Converter Type | 1 | Availabale |
| | | Voltage Sensor output 10 V for 2000 V | 1 | Availabale |
| | | PSU Quint PS-100-240 AC/24 DC/5 | 1 | Availabale |
| | | PSU Quint PS-100-240 AC/24 DC/6 | 1 | Availabale |
| | | PSU Mini 100-240 VAC 15 VDC 1 A | 1 | Availabale |
| | | Assembly PSU CU20-09 85-264 VAC | 1 | Availabale |
| | | Resistor 4.99 Ohms 10 W, A +/-0.5% | 10 | Availabale |
| | | Resistor 475 Ohms +/- 5% | 20 | Availabale |
| | | Resistor 4120 Ohms 3 W, 0.5% | 20 | Availabale |
| | | Module Power nterface 315 B | 1 | Availabale |
| | | PIB measurement board with data processing PIB 101 C | 1 | Availabale |
| | | PIB measurement board with Optical link,PIB 100G, Unconfigured | 1 | Availabale |
| | | Module 16 Inputs/16 Outputs BIO 232.1 | 1 | Availabale |
| | | VME card REF: VP 325/022-23 | 1 | Availabale |
| | | Module RC012A, Tropicalised | 1 | Availabale |
| | | Transformer 3 Ph, 1600/100 V-50 Hz, 200 VA-10 KV | 1 | Availabale |
| | | SMPS mini power O/P 15V DC(Make-Phoenix contact) | 1 | Availabale |
| | | SMPS O/P 48V DC JSW 100 | 1 | Availabale |
| | | SMPS O/P 24V DC(Make-Phoenix contact) | 1 | Availabale |
| | | AC DC contoller card module(CCMI) | 1 | Availabale |
| | | Auxillary card module | 1 | Availabale |

| | | | | |
|----|---|---|---|------------|
| 17 | 220 V DC station Charger(Make-Dubas) | F-range coil LX4FK220 | 1 | Availabale |
| | | Power supply card | 3 | Availabale |
| | | Static card | 2 | Availabale |
| | | Input voltage divider card | 2 | Availabale |
| | | Power supply Txm fuse resistor assembly | 2 | Availabale |
| | | Control supply Txm fuse resistor assembly | 2 | Availabale |
| | | DC DC card module(CCM-2) | 1 | Availabale |
| | | AC DC card module(CCM-1) | 1 | Availabale |
| | | Contactore(LC1FDP500A)(Make-C&S) | 1 | Availabale |
| 18 | GT & STG AVR Spares | AC DC converter | 2 | Availabale |
| | | Pulse Transformer | 2 | Availabale |
| | | Over voltage protection | 1 | Availabale |
| | | Discharge field Resistor | 1 | Availabale |
| | | Thyristor power Module | 6 | Availabale |
| | | Thyristor fuse | 6 | Availabale |
| | | UN00663 Module | 1 | Availabale |
| | | UN00661 Module | 1 | Availabale |
| | | UN00610 Module | 1 | Availabale |
| | | UN00662 Module | 1 | Availabale |
| | | UN52650 Module | 1 | Availabale |
| | | UN0094 Module | 2 | Availabale |
| | | UN0096 Module | 2 | Availabale |
| | | UN0097 Module | 2 | Availabale |
| | | UN0098 Module | 2 | Availabale |
| | | UN0099 Module | 1 | Availabale |
| | | UN0053 Module | 1 | Availabale |
| | | Switch | 1 | Availabale |
| | | Transducer 0-60mV/3X(4-20) | 1 | Availabale |
| | | Transducer Dc volt 0-600V/4-20mA | 1 | Availabale |
| | | Transformer ,DC VOLT -15-0+15/4-20mA | 1 | Availabale |
| | | Transformer ,Control 100VA,220/240V | 1 | Availabale |
| | | Transformer ,200VA YNYNO 110/560V | 1 | Availabale |
| | | Transformer, 200VA 3PH, YNYNO 400/110V | 1 | Availabale |
| | | Transducer,0-10V/4-20mA | 1 | Availabale |
| | | Transducer,AC VOLT,0-165V/4-20mA | 1 | Availabale |
| | | Transducer,DC VOLT,0-500V/4-20mA | 1 | Availabale |
| | | Relay AUX 24VDC | 1 | Availabale |
| | | Relay AUX 240VAC | 2 | Availabale |
| | | Relay AUX 220VDC | 1 | Availabale |
| | | Lamp PI Green | 1 | Availabale |
| | | Fuse HRC 6A | 1 | Availabale |
| | | Fuse 10A | 1 | Availabale |
| | | Fuse HRC 25A | 1 | Availabale |
| | | Fuse HRC 8A | 1 | Availabale |
| | | Fuse HRC 10A,500V | 1 | Availabale |
| | | Fuse HRC 2A | 1 | Availabale |
| | | Fuse HRC 80A | 1 | Availabale |
| | | Fuse HRC 16A | 1 | Availabale |
| | | Fuse HRC 16A,415VAC,600VDC | 1 | Availabale |
| | | Fuse HRC 10A,1000v | 1 | Availabale |
| 19 | GT MARK Vie | IO net NTRON ethernet switch | 1 | Availabale |
| | | Phonix power supply 28vdc | 1 | Availabale |
| | | TSVC Servo IO board | 1 | Availabale |
| | | TBAI Aanalog IO board | 1 | Availabale |
| | | TBCI combet input board | 1 | Availabale |
| | | TRLY Relay o/p board* | 0 | Availabale |
| | | TTUR primary turbine protection | 1 | Availabale |
| | | TPRO Turbine protection board | 1 | Availabale |
| | | TVBA vibration IO board | 1 | Availabale |
| | | PDM Power distribution board | 1 | Availabale |
| | | MarK Vie processor card | 1 | Availabale |
| | | PAIC Analog IO pack | 1 | Availabale |
| | | PDA discrete input IO pack | 1 | Availabale |
| | | PVIB vibration IO pack | 1 | Availabale |
| | | PPDA PDM Diagonostic | 1 | Availabale |

| | | | | |
|----|---------------|--------------------------------------|----|---|
| | | PDOA discrete output IO pack | 1 | Availabale |
| | | PTOR turbine specific trip IO pack | 1 | Availabale |
| | | PSVO servo IO pack | 1 | Availabale |
| | | PPRO backup turbine protection pack* | 0 | Availabale |
| 20 | DCS cards | IOP330B | 20 | Availabale |
| | | I320A | 2 | Availabale |
| | | S901A | 1 | Availabale |
| | | S305A | 3 | Availabale |
| | | I334A | 1 | Availabale |
| | | CPO 401 | 1 | Availabale |
| | | I304A | 2 | Availabale |
| | | I301B | 10 | Availabale |
| | | I320A | 2 | Availabale |
| | | I351A | 15 | Availabale |
| | | D403D | 2 | Availabale |
| | | D401D | 3 | Availabale |
| | | S901A | 1 | Availabale |
| | | R306B | 1 | Availabale |
| | | D403D | 1 | Availabale |
| | | D408D | 1 | Availabale |
| | | D406D | 1 | Availabale |
| 21 | GTG & STG GRP | P345(Make-SCHNEIDER ELECTRIC) | 2 | Available |
| | | P642(Make-SCHNEIDER ELECTRIC) | 3 | Available |
| | | P741 (Make-ALSTOM) | 1 | Available |
| | | P127(Make-ALSTOM) | 1 | Available |
| | | P643(Make-ALSTOM) | 1 | Available |
| 22 | Switchyard | Spares for 132 KV circuit breaker | | Minimal quantity available. Offer being collected as per recomnedations after maintenance during APM Dec 2021 |
| | | CT | 5 | Optimal Quanity available |
| | | CVT | 3 | Optimal Quanity available |
| | | EMVT | 1 | Optimal Quanity available |